

RD Plumbing & Gas

3 Colvin Place
Frenchs Forest NSW 2086
Australia
Phone: 0403903145
ryan@rdplumbing.com.au

www.rdplumbing.com.au ABN: 12 421 703 364

Re: 19 Malbara Crescent, Frenchs Forest

Services

Stormwater to the Council easement.

Pipeline of 150mm diameter has been located as per attached sketch at depth of 500mm and tested to its downstream outlet, and is functional with sufficient capacity to cater for its intended catchment as per AS3500.

See attached plan.

R-Down

Ryan Dowsett

19 Malbara Crescent, Frenchs Forest

Stormwater Connection Plan

