



18 January 2024

Contact Amanda Herringe
Email Amanda.herringe@waternsw.com.au

General Manager
Northern Beaches Council

Our ref IDAS1153140
Our file A-77419
Your ref DA2023/1869

Annabelle.lindsay@northernbeaches.nsw.gov.au

Dear Council,

Re: Request for Further Information of Proposed Development

Reference is made to A-77419

WaterNSW has reviewed the information provided with the development application related to water supply works.

WaterNSW requests that the consent authority stop-the-clock for this development and arrange for the applicant to provide the following information to enable assessment of the application:

WaterNSW note section 4.4 *Groundwater Considerations* of the Geotechnical Report. As a drained basement design is proposed, WaterNSW and the Department of Climate Change, Energy, the Environment and Water (DCCEEW) will require additional modelled data to support a hydrogeological review and assessment. The Geotechnical report (or equivalent) will need to be updated accordingly and satisfy requirements detailed in the [Minimum requirements for building site groundwater investigations and reporting](#). Further information can also be found at <https://www.industry.nsw.gov.au/water/science/groundwater/aquifer-interference-activities>.

Please address the information requested as soon as possible. If the information has not been received by WaterNSW **within 28 days**, and no request for an extension of time has been received, WaterNSW may refuse to issue General Terms of Approval.

Should there be any further enquiry in this matter, please email Amanda.herringe@waternsw.com.au

Yours sincerely

Amanda Herringe

Amanda Herringe

Water Regulation Specialist

WaterNSW