

Natural Environment Referral Response - Coastal

Application Number:	DA2024/0685
Proposed Development:	Alterations and additions to a dwelling house including a swimming pool and carport
Date:	27/06/2024
Responsible Officer	Lachlan Rose
Land to be developed (Address):	Lot A DP 106210 , 58 Alexander Street MANLY NSW 2095

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

Proposed Works

- This application seeks approval for the construction of a carport, plunge pool and landscape works ancillary to an existing dwelling house

Officer comments

The application has been assessed in consideration of the *Coastal Management Act 2016*, State Environmental Planning Policy Resilience & Hazards) 2021 and has also been assessed against requirements of the Manly LEP 2013 and Manly DCP.

Comment: **SUPPORTED WITH CONDITIONS**

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development.

The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' map under the State Environmental Planning Policy (Resilience & Hazards) 2021 (SEPP R & H). Hence, Clauses 2.10 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment and as assessed in the submitted Statement of Environmental Effects (SEE) report prepared by Nolan Planning dated May 2024, the DA satisfies requirements under clause 2.10 & 2.12 of the SEPP R&H. As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021.

Manly LEP 2013 and Manly DCP

No coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Manly LEP 2013 and Manly DCP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site