

Building Assessment Referral Response

Application Number:	DA2020/0579
Date:	22/06/2020
To:	Tony Collier
Land to be developed (Address):	Lot 29 DP 5464 , 27 Warriewood Road WARRIEWOOD NSW 2102 Lot 28 DP 5464 , 25 Warriewood Road WARRIEWOOD NSW 2102

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application proposes a residential flat building containing 32 dwellings, 10 semi-detached dwellings, a dwelling house and community title subdivision.

No objections subject to conditions to ensure compliance with the Building Code of Australia (BCA). It is noted that the proposed development may not fully comply with some requirements of the BCA in the absence of fully detailed plans for assessment, however it is considered that these matters may be readily determined at Construction Certificate Stage and by way of an acceptable 'Alternate Solution' Design where required.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must

be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.