



10 December 2018

General Manager
Northern Beaches Council
PO Box 82
MANLY NSW 1655

Dear Sir/ Madam,

Re: Stormwater Management Plan – 57 MacMillian Street, Seaforth

With reference to the Development Application for the above property, please find enclosed copies of the site Stormwater Management Plan No. Sheet-1 for your perusal.

The plan shows runoff collected from the roof and hard surface areas of the site draining to the existing kerb & gutter in MacMillian Street.

Note that the required OSD storage of 11,000 litres has been offset by 100% via the provision of 11,000 litres of rainwater storage located behind the garage.

Should you require any further information please contact the undersigned.

Yours faithfully
TAYLOR CONSULTING

D M SCHAEFER - Director
B.E. Civil (Hons) M.I.E. Aust.
N.P.E.R. Eligible

