

Natural Environment Referral Response - Riparian

Application Number:	DA2019/0915
To:	Kevin Short
Land to be developed (Address):	Lot 34 DP 11356 , 48 Nareen Parade NORTH NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as “DCP Map Waterways and Riparian Land”.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application has been assessed under Pittwater 21 DCP B4.8 Freshwater Wetlands EEC, B5.8 Water Quality, SEPP Coastal Management 2018 - Coastal Wetlands Proximity Area and Coastal Environment Zone.

As the proposal does not increase impervious area by more than 50sqm water quality controls do not apply. Given the proximity to highly sensitive habitats however, sediment and erosion controls must be managed to ensure that no sediment enters Nareen Creek via the stormwater system.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.