

## Building Assessment Referral Response

<b>Application Number:</b>	DA2020/0705
<b>Date:</b>	06/07/2020
<b>To:</b>	Tony Collier
<b>Land to be developed (Address):</b>	Lot 3 SP 72732 , 3 / 1 Sydenham Road BROOKVALE NSW 2100

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### Fire Safety Upgrade

The Building Code of Australia works and fire upgrading measures to upgrade the building as detailed and recommended in the Fire Engineering Report prepared by Building anatomy, dated 3 May 2020, Report Ref NCC2019 Review(20-0052-r1.1,3/5/20) are to be carried out to the building.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety and for building occupant safety

>.