

Landscape Referral Response

| | |
|--|--|
| Application Number: | DA2019/1124 |
| Date: | 31/10/2019 |
| Responsible Officer: | Catriona Shirley |
| Land to be developed (Address): | Lot 23 DP 33000 , 88 Idaline Street COLLAROY PLATEAU NSW 2097 |

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The plans indicate that no significant landscape features are affected by the works.

The landscape plan indicates removal of a street tree in the Acacia Street road verge. No particular reason for removal is noted and it is recommended that the tree be retained.

No objections to approval subject to conditions as recommended.

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

- (a) Existing trees which must be retained
 - i) All trees located on adjoining land
 - ii) All street trees
- (b) Tree protection
 - i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.

- ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
- iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
- iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
- v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Landscape completion certification

a) Prior to the issue of an Occupation Certificate, a landscape report prepared by a landscape architect or landscape designer shall be submitted to the Certifying Authority, certifying that the landscape works have been completed in accordance with the approved landscape plan and inclusive of any conditions of consent.

Reason: To ensure that the landscape treatments are installed to provide landscape amenity.