

Natural Environment Referral Response - Riparian

Application Number:	DA2019/1146
To:	Adam Urbancic
Land to be developed (Address):	Lot 1 DP 1089971 , 65 Campbell Parade MANLY VALE NSW 2093

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application was assessed under
Warringah DCP 2011 C4 – Stormwater
Warringah DCP 2011 C5 – Erosion and Sedimentation
Warringah Council PL 850 Water Management Policy

As the application does not propose to increase the building footprint, water quality controls do not apply. Sediment and erosion controls must still be installed prior to work on the site and maintained until all work is complete, to ensure building materials etc do not migrate to the stormwater system.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.