

Natural Environment Referral Response - Flood

Application Number:	DA2019/1126
To:	Thomas Burns
Land to be developed (Address):	Lot 4 DP 233249 , 43 Pittwater Road MANLY NSW 2095

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed development is a small extension to a room at the rear of the existing dwelling. Subject to conditions, the development is compliant with Council's flood prone land development controls.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Flooding

In order to protect property and occupants from flood risk the following is required:

Building Components and Structural Soundness – C1

All new development shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

Building Components and Structural Soundness – C2

All new development must be designed and constructed to ensure structural integrity up to the Flood Planning Level of 6.33m AHD, taking into account the forces of floodwater, wave action, flowing water with debris, buoyancy and immersion. Structural certification shall be provided confirming the above.

Building Components and Structural Soundness – C3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning

Level. All existing electrical equipment and power points located below the Flood Planning Level of 6.33m AHD must have residual current devices installed cut electricity supply during flood events.

Floor Levels – F2

The underfloor area of the dwelling below the 1% AEP flood level of 5.83m AHD is to be designed and constructed to allow clear passage of floodwaters. The underfloor perimeter of the dwelling is to have a minimum of 50% open area below the 1% level

Fencing – H1

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open for passage of flood waters - All new fencing on the property must be design with a minimum of 50% open area between the 1% flood level of 5.83m AHD and natural ground level, to allow flood waters to pass through.

Recommendations

The development must comply with all recommendations outlined in:

- The Flood Management Report prepared by Pittwater Data Services dated 15 September 2019.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.