



## Landscape Referral Response

<b>Application Number:</b>	DA2019/1001
<b>Date:</b>	25/09/2019
<b>Responsible Officer:</b>	Georgia Quinn
<b>Land to be developed (Address):</b>	Lot 23 DP 15763 , 30 Narrabeen Park Parade WARRIEWOOD NSW 2102

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

### Officer comments

The development application seeks approval for the construction of a secondary dwelling. The proposal in terms of landscape outcome is acceptable subject to the protection of existing trees and vegetation.

Council's Landscape section has assessed the proposal against the following Pittwater 21 DCP Controls:

B4.22 Preservation of Trees and Bushland Vegetation

B4.5 Landscape and Flora and Fauna Enhancement Category 3 Land

C1.1 Landscaping

C1.11 Secondary Dwellings and Rural Worker's Dwellings

D14 Warriewood Locailty

D14.13 Landscaped Area - Environmentally Sensitive Land

### Referral Body Recommendation

Recommended for approval, subject to conditions

### Refusal comments

### Recommended Landscape Conditions:

## CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

### Tree protection

(a) Existing trees which must be retained

i) All trees not indicated for removal on the approved plans, unless exempt under relevant

planning instruments or legislation

ii) Trees located on adjoining land

(b) Tree protection

i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.

ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.

iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.

iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees

v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **Protection of rock and sites of significance**

a) All rock outcrops outside of the area of approved works are to be preserved and protected at all times during demolition excavation and construction works.

b) Should any Aboriginal sites be uncovered during the carrying out of works, those works are to cease and Council, the NSW Office of Environment and Heritage (OEH) and the Metropolitan Local Aboriginal Land Council are to be contacted.

Reason: Preservation of significant environmental features.