

Sent:	7/10/2022 3:49:56 PM
Subject:	NSW RFS Determination - Your Reference - (CNR-41300) DA2019/0409
Attachments:	DA-2019-01634-S4.55-2 - 06-10-2022 11_28_34 - Determination Letter.pdf;



NSW RURAL FIRE SERVICE

Attention: Northern Beaches Council

Your Reference: (CNR-41300) DA2019/0409

Application Details: s100B – SFPP – S4.55

Site Address:

1111 Oxford Falls Road
Frenchs Forest NSW 2086

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Marc Ellwood on 1300 NSW RFS and quote DA-2019-01634-S4.55-2.



Planning and Environment Services

NSW RURAL FIRE SERVICE

Locked Bag 17 Granville NSW 2142

P 1300 NSW RFS **E** records@rfs.nsw.gov.au

www.rfs.nsw.gov.au | www.facebook.com/nswrfs | www.twitter.com/nswrfs

PREPARE. ACT. SURVIVE.



NSW RURAL FIRE SERVICE

Northern Beaches Council
PO Box 882
MONA VALE NSW 1660

Your reference: (CNR-41300) DA2019/0409
Our reference: DA-2019-01634-S4.55-2

ATTENTION: Northern Beaches Council

Date: Friday 7 October 2022

Dear Sir/Madam,

Integrated Development Application

s100B – SFPP – Seniors Housing

1111 Oxford Falls Road Frenchs Forest NSW 2086, 100//DP1284117, 1113//DP752038

I refer to your correspondence dated 21/06/2022 seeking general terms of approval for the above Integrated Development in accordance with s4.55 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the submitted amended information. General Terms of Approval are now re-issued, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions.

Asset Protection Zones

Intent of measures: to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.

1. At the commencement of building works and in perpetuity to ensure ongoing protection from the impact of bush fires, the entire site must be managed as an Inner Protection Area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply, with the exception of the wildlife restoration corridor, the riparian zone and buffer located in the northern part of the site, as shown in Schedule 1 – Bushfire Protection Measures, Issue 1, dated 3/12/2020:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

2. The unformed section of Barnes Road Reserve is to be maintained as an asset protection zone (APZ) for the life of the development, and managed as an outer protection area (OPA) as outlined within Appendices 2 & 5 of *Planning for Bush Fire Protection 2019* and the NSW Rural Fire Service's document 'Standards for asset protection zones'.

Construction Standards

Intent of measures: to provide suitable building design, construction and sufficient space to ensure that radiant heat levels do not exceed critical limits for firefighters and other emergency services personnel undertaking operations, including supporting or evacuating occupants.

3. Proposed construction of Buildings 1 to 9 inclusive, must comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

4. Proposed garden pavilion must be undertaken using non-combustible materials.

Access - Internal Roads

Intent of measures: to provide safe operational access for emergency services personnel in suppressing a bush fire, while residents are accessing or egressing an area.

5. Proposed Internal road must comply with the general requirements of Table 5.3b of *Planning for Bush Fire Protection 2019* and the following:

- minimum 6.5m carriageway width kerb to kerb;
- A turning circle (12m radius) at the termination of this road;
- parking is provided outside of the carriageway width;
- hydrants are located clear of parking areas;
- roads are through roads, and these are linked to the internal road system at an interval of no greater than 500m;
- curves of roads have a minimum inner radius of 6m;
- the road crossfall does not exceed 3 degrees; and
- a minimum vertical clearance of 4m to any overhanging obstructions, including tree branches.

6. The internal road shall be linked into the northern end of Barnes Road to form a secondary access/ egress route.

Water and Utility Services

Intent of measures: to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.

7. The provision of water, electricity and gas must comply with the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419.1:2005;
- hydrants are and not located within any road carriageway;
- reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005;
- all above-ground water service pipes are metal, including and up to any taps;

- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
 - a) lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and
 - b) no part of a tree is closer to a power line than the distance set out in accordance with the specifications in ISSC3 Guideline for Managing Vegetation Near Power Lines.
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - The storage and handling of LP Gas, the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of flammable materials (10m) and shielded on hazard side;
- connections to/ from gas cylinders are metal; not polymer-sheathed flexible gas supply lines; and
- above-ground gas service pipes are metal, including and up to any outlets.

Landscaping Assessment

The intent of measures is for landscaping. To achieve this, the following conditions must apply:

8. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*. In this regard, the following principles are to be incorporated:

- A minimum 1 metre wide area, suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
- Planting is limited in the immediate vicinity, uses low flammability vegetation species and does not provide a continuous canopy to the building;
- Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do not touch or overhang buildings;
- Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
- Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
- Avoid planting of deciduous and climbing species that may increase fuel at surface/ ground level (i.e. leaf litter); and
- Locate combustible materials, structures and flammable fuel stores away from the building.

Emergency and Evacuation Planning Assessment

Intent of measures: to provide suitable emergency and evacuation arrangements for occupants of SFPP developments.

9. A Bush Fire Emergency Management and Evacuation Plan must be prepared and be consistent with the NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan. The Bush Fire Emergency Management and Evacuation Plan should include planning for the early relocation of occupants. In addition a copy of the Bush Fire Emergency Management and Evacuation Plan should be provided to the Local Emergency Management Committee for its information prior to occupation of the development.

This letter is in response to an assessment of the application based on the submitted further information and supersedes our previous general terms of approval dated 05/05/2021.

For any queries regarding this correspondence, please contact Marc Ellwood on 1300 NSW RFS.

Yours sincerely,

Nika Fomin
Manager Planning & Environment Services
Built & Natural Environment



NSW RURAL FIRE SERVICE

BUSH FIRE SAFETY AUTHORITY

SFPP – Seniors Housing

1111 Oxford Falls Road Frenchs Forest NSW 2086, 100//DP1284117, 1113//DP752038

RFS Reference: DA-2019-01634-S4.55-2

Your Reference: (CNR-41300) DA2019/0409

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority supersedes the previous Bush Fire Safety Authority DA-2019-01634-S4.55-1 issued on 05/05/2021 and confirms that, subject to the attached reissued General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

Nika Fomin

**Manager Planning & Environment Services
Built & Natural Environment**

Friday 7 October 2022