



RAFZAN
Consulting Engineers

DATE Tuesday, 18 December 2018
OUR REFERENCE 84483PC
YOUR REFERENCE HAJAKIAN
JOB LOCATION 42 PRINGLE AVENUE BELROSE

STRUCTURAL CERTIFICATE

This is to certify that the masonry walls and steel columns all below the 1 in 100 year ARI plus 0.5m freeboard flood level of RL 163.4m AHD will withstand the forces of flood waters, debris, buoyancy and immersion.

The brickwalls and steel columns are all flood compatible material.

Yours Faithfully

John Rafeletos
B.E. M.I.E. Aust C.P.Eng
NPER3 Structural and Civil