

Environmental Health and Protection Referral Response - commercial use

Application Number:	Mod2013/0141
To:	David Auster
Land to be developed (Address):	Lot 245 DP 1178957 1056 - 1058 Pittwater Road COLLAROY NSW 2097

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments

Was sufficient documentation provided appropriate for referral?	YES
Are the reports undertaken by a suitably qualified consultant?	N/A
Have you considered the following?	YES
• Review Statement of Environmental Effects, consider ongoing use: - Food Premises, use AS 4674 and Food Standards Code and BCA (re ventilation and toilets). Consider location of mechanical ventilation (AS 1668) and grease traps - Backpackers/Boarding House, use Public Health Act and Local Gov Regulations and BCA. - Mortuary, use Local Gov Regulations - Skin penetration acupuncture, tattoo, beauty salon, use Local Gov Regulations - Public pool, use Public Health Act - Childcare, use AS 4674 (kitchen) and BCA toilets • Consider waste disposal. All new food shops should have waste stored in rooms. • Consider impact of noise, hours of operation, outdoor seating, location of equipment, times of deliveries, noise management plans, acoustic reports etc. • Shop top housing must have separate waste storage for residential and commercial. EH&P don't look at residential waste areas or collection.	
General Comments	

This proposal has been reviewed by the Environmental Health & Protection team and in this instance do support the development application with subject to conditions.

Recommendation

APPROVAL - subject to
conditions

Comments completed by: Pankit Shah

Date: 26 August 2013

Recommended Environmental Health and Protection Conditions:

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE**

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from a person who is eligible as a 'Member' of Environmental Health Australia (EHA) that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the kitchen complies with the design requirements. (DACHPFPOC3)

Mechanical Ventilation certification

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from the installer of the mechanical ventilation system that the design, construction and installation of the mechanical ventilation system is compliant with the requirements of AS1668 The use of mechanical ventilation.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the mechanical ventilation system complies with the design requirements. (DACHPFPOC4)