2. DO NOT SCALE FROM THESE DRAWING.

3. ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER BEFORE COMMENCING WITH ASSOCIATED WORK.

STORMWATER NOTES:

AI. ALL WORKS SHALL BE CARRIED OUT IN ACCORDANCE WITH THE AUSTRALIAN STANDARDS (LATEST VERSION) AND THE REQUIREMENTS OF THE LOCAL COUNCIL AND ANY APPLICABLE AUTHORITIES. A2. ALL LEVELS SHOWN ARE TO THE AUSTRALIAN HEIGHT DATUM (AHD) UNLESS NOTED OTHERWISE. A3. THE LOCATION OF ALL DRAINAGE ELEMENTS ARE SHOWN INDICATIVELY BASED ON AVAILABLE SURVEY OR OTHER INFORMATION. ALL DRAINAGE ELEMENTS ARE TO BE INSTALLED WITH CONSIDERATION TO SITE CONSTRAINTS AND THE INTENT OF THE DRAINAGE CONCEPT.

A4. ANY MATERIAL VARIATIONS TO THE DRAINAGE CONCEPT OR DETAILED STORMWATER ELEMENTS MUST BE APPROVED BY NORTHERN BEACHES CONSULTING ENGINEERS PTY LTD PRIOR TO

A5. ANY EXCAVATION OR TRENCHING FOR SERVICES ADJACENT TO A STRUCTURE OR PROPERTY BOUNDARY MUST NOT ENCROACH ON THE 'ZONE OF INFLUENCE', REFER TO THE NCC FOR FURTHER

GENERAL CONSTRUCTION NOTES:

BI. CONTRACTORS TO LOCATE ALL EXISTING SERVICES PRIOR TO EXCAVATION AND NOTIFY ENGINEER OF ANY POTENTIAL CLASHES WITH THE PROPOSED STORMWATER DRAINAGE SYSTEM. B2. ANY ELEMENTS OF THE EXISTING STORMWATER SYSTEM WHICH ARE PROPOSED TO BE RETAINED MUST BE INSPECTED AND APPROVED BY AN ENGINEER PRIOR TO CONSTRUCTION AS BOTH HAVING ADEQUATE CAPACITY TO CATER FOR THE RUNOFF DIRECTED TO IT AND BEING IN ADEQUATE CONDITION

B3. EXISTING STORMWATER SYSTEM ALSO TO BE INSPECTED BY A SUITABLY QUALIFIED PLUMBER PRIOR TO CONSTRUCTION AND UPGRADED AS REQUIRED IN ACCORDANCE WITH AS3500.3.

B4. CARE SHOULD BE TAKEN WHEN UNDERTAKING WORKS IN THE VICINITY OF TREES NOT TO DISTURB THE TREE ROOT SYSTEM. HAND DIGGING OF TRENCHES MAY BE REQUIRED SUBJECT TO THE PROJECT ARBORISTS REQUIREMENTS. REFER TO THE ARBORIST REPORT FOR EXCAVATION REQUIREMENTS SURROUNDING PROTECTED TREE ROOT ZONES.

B5. SWIMMING POOL SURCHARGE OVERFLOW TO BE CONNECTED VIA GRAVITY TO THE SEWER IN ACCORDANCE WITH AS3500. DETAILS AND CERTIFICATION BY OTHERS.

B6. EXTENT, ALIGNMENT, DEPTH AND CONDITION OF ANY COUNCIL STORMWATER PIPELINE WITHIN A DEVELOPMENT SITE MUST BE VERIFIED PRIOR TO CONSTRUCTION AND THE ENGINEER MUST BE NOTIFIED UPON VERIFICATION. ANY NEW CONNECTION TO A COUNCIL STORMWATER PIPELINE WILL BE SUBJECT TO COUNCIL APPROVAL AND MUST BE INSTALLED IN ACCORDANCE WITH THE LOCAL COUNCIL SPECIFICATIONS.

PIPEWORK INSTALLATION:

CI. ALL PIPES TO BE MINIMUM 100mm & UNLESS NOTED OTHERWISE.

C2. ALL PIPES TO BE UPVC SEWER GRADE TO AS 1254 UNLESS NOTED OTHERWISE.

C3. ALL PIPES TO BE LAYED AT 1 % MINIMUM GRADE UNLESS NOTED OTHERWISE.

C4. ALL CONNECTIONS INTO EXISTING PIPES MUST BE MADE IN THE DIRECTION OF FLOW C5. ANY NEW UPVC CONNECTIONS INTO EXISTING R.C. PIPES MUST BE MADE INTO THE TOP HALF OF THE

PIPE USING A FLOWCON CONNECTION FITTING U.N.O.

C6. ALL PIPES SHALL BE LAID ON A 75mm SAND BED, COMPACTED TO 100% S.M.D.D. BELOW PAVEMENTS. (NO COMPACTION REQUIRED BELOW LANDSCAPING) COVER TO SURFACE FROM TOP OF PIPE TO BE 300mm MINIMUM. BACKFILL TO BE ADEQUATELY CONSOLIDATED AROUND PIPES BY METHOD OF RAMMING AND WATERING IN. TRENCHES TO BE FILLED WITH NO-FINES GRANULAR MATERIAL AS

C7. ALL EXISTING EARTHENWARE PIPES TO BE UPGRADED TO UPVC.

C8. MINIMUM PIPE COVER TO ALL IN-GROUND PIPEWORK SHALL BE CARRIED OUT IN ACCORDANCE WITH

C9. ALL SUSPENDED PIPE FIXINGS ARE TO BE CARRIED OUT IN ACCORDANCE WITH AS2032. CIO. ENSURE THAT ALL STORMWATER PITS AND PIPES ARE LOCATED CLEAR FROM TREE ROOT

CII. ALL PIPEWORK MUST BE INSTALLED WITHIN THE SITE BOUNDARY OF THE DEVELOPMENT SITE. ANY NEW OR EXISTING PIPEWORK EXTENDING THROUGH PRIVATE PROPERTY BEYOND THE BOUNDARY OF THE DEVELOPMENT SITE MUST BE CONTAINED SOLELY WITHIN A DRAINAGE EASEMENT. IF NO DRAINAGE EASEMENT EXISTS, A NEW DRAINAGE EASEMENT MUST BE SOUGHT AND REGISTERED PRIOR TO UTILISING OR INSTALLING PIPEWORK THROUGH NEIGHBOURING PROPERTIES. CONTACT THE ENGINEER IF A DRAINAGE EASEMENT CANNOT BE OBTAINED.

ROOF DRAINAGE:

DI. ALL DOWN PIPES TO BE 100mm & UNLESS NOTED OTHERWISE.

D2. DOWN PIPE LOCATIONS ARE INDICATIVE ONLY. LOCATIONS TO BE CONFIRMED WITH ARCHITECT PRIOR TO COMMENCEMENT OF WORK

D3. PROVIDE CLEANING EYES AT ALL DOWNPIPES.

D4. GUTTER GUARDS MUST BE INSTALLED ON ALL GUTTERS UNLESS NOTED OTHERWISE. D5. ALL EAVES GUTTER AND VALLEY GUTTER SYSTEMS MUST BE INSTALLED IN ACCORDANCE WITH

D6. ALL BOX GUTTER SYSTEMS MUST BE INSTALLED STRICTLY IN ACCORDANCE WITH THE DETAILS SHOWN ON THE APPROVED STORMWATER MANAGEMENT PLAN. IF NO DETAILS ARE SHOWN, THE BOX GUTTER SYSTEM MUST BE INSTALLED IN ACCORDANCE WITH AS3500.3. IF ANY CHANGE TO THE BOX GUTTER SYSTEM CONFIGURATION IS PROPOSED, THE ENGINEER MUST BE NOTIFIED FOR A RE-DESIGN. IF THE INSTALLED BOX GUTTER DOES NOT STRICTLY COMPLY WITH THE DESIGN DETAILED ON THE STORMWATER MANAGEMENT PLAN, CERTIFICATION OF THE HYDRAULIC SYSTEM MAY BE REFUSED. D7. ALL GREEN ROOFS, PEBBLED ROOFS AND PLANTERS WITH A CONCRETE BASE MUST BE WATERPROOFED AND HAVE DRAINAGE CELL INSTALLED IN ACCORDANCE WITH THE MANUFACTURERS SPECIFICATION.

EI. ALL STORMWATER PITS MUST BE INSTALLED IN ACCORDANCE WITH AS3500.3.

E2. ALL CONCRETE PITS TO BE CAST INSITU OR, IF PRECAST, APPROVED BY ENGINEER. CAST INSITU PITS TO HAVE 150mm THICK CONCRETE WALLS AND BASE. WALLS TO BE REINFORCED WITH 1 N12 TOP TIE UNLESS NOTED OTHERWISE. CAST INSITU PITS GREATER THAN 900 DEEP TO BE MINIMUM 900x600 AND TO HAVE 150mm THICK CONCRETE WALLS AND BASE. WALLS TO BE REINFORCED WITH NI2 AT 300 EACH WAY UNLESS NOTED OTHERWISE.

E3. MINIMUM INTERNAL DIMENSIONS FOR STORMWATER AND INLET PITS TO BE IN ACCORDANCE WITH TABLE 8.2, AS3500.3.

E4. ALL PITS GREATER THAN 1200mm DEEP SHALL HAVE STEP IRONS INSTALLED. STEP IRON INSTALLATION MUST BE IN ACCORDANCE WITH THE RELEVANT AUSTRALIAN STANDARDS



Consulting Engineers

STRUCTURAL - CIVIL - STORMWATER - REMEDIAL

E5. THE BOUNDARY OR SILT ARRESTOR PIT MUST INCORPORATE A SUMP OF MINIMUM 200mm DEPTH BELOW THE INVERT OF THE OUTLET PIPE AND A MAXI-MESH SCREEN AS PER LOCAL COUNCIL AND THE AUSTRALIAN STANDARD REQUIREMENTS. HOWEVER, UNLESS SPECIFICALLY REQUIRED BY COUNCILS POLICY OR IF THE SITE CONSISTS OF A CLAY OR ROCK SUBGRADE, ALL OTHER DRAINAGE PITS WILL NOT REQUIRE A SUMP.

E6. ALL STORMWATER PITS TO BE LOCATED AT LOW POINTS TO PREVENT PONDED WATER. E7. FOR STORMWATER PITS LOCATED BELOW THE WATER TABLE, CUT INTO ROCK OR IN POORLY DRAINED SOILS, THE PIT SUMP MAY BE FILLED WITH MORTAR AND SCREEDED TOWARDS THE OUTLET AT MINIMUM 1% FALL, SUBJECT TO THE ENGINEERS APPROVAL.

SUBSOIL DRAINAGE: FI. ALL SUBSOIL DRAINAGE TO BE INSTALLED AS REQUIRED IN ACCORDANCE WITH AS3500.3 (SPECIFICALLY SECTION 6, 7 AND APPENDIX M) AND THE NCC.

F2. INSTALLATION OF SUBSOIL DRAINAGE LINES IS GENERALLY REQUIRED WHERE SUBSURFACE WATER MOVEMENT COULD DAMAGE BUILDINGS OR CAUSE LOSS OF AMENITY THROUGH THE BUILD-UP OF EXCESSIVE MOISTURE OR LATERAL WATER PRESSURE. THIS INCLUDES ALONG WALLS THAT IMPEDE THE NATURAL FLOW OF GROUNDWATER, ON THE UPHILL SIDE OF CUT AND FILL SITES, ADJACENT TO DEEP FOOTINGS, BEHIND RETAINING WALLS AND ADJACENT TO BASEMENT WALLS. SUBSOIL DRAINAGE IS GENERALLY ALSO REQUIRED IN SHALLOW LANDSCAPED AREAS OVER ROCK OR POORLY DRAINED SOILS TO PREVENT OVERLY SATURATED LANDSCAPED AREAS.

F3. THE INSTALLATION OF SUBSOIL DRAINAGE MAY REQUIRE TRENCHING THROUGH ROCK.

F4. ALL SUBSOIL LINES ARE TO BE 100mm UPVC SLOTTED PIPE (UNSOCKED), LAID AT (MIN.) 0.5% FALL

F5. THE SUBSOIL LINE IS TO BE SURROUNDED BY SELECT FILTER MATERIAL, GENERALLY 10-20mm DIAMETER AGGREGATE.

F6. THE TRENCH SHALL BE SIZED TO PROVIDE A MINIMUM 50mm BEDDING AND 100mm COVER ALL AROUND THE SUBSOIL LINE, GENERALLY MINIMUM 300mm WIDE X 300mm DEEP. THE TRENCH IS TO BE WRAPPED ALL-ROUND IN NON-WOVEN, GEOTEXTILE FABRIC OF STRENGTH CLASS A, WITH SUFFICIENT OVERLAP (LESSER OF TRENCH WIDTH OR 500mm).

F7. WHERE THE IN-SITU SOILS HAVE A GRAIN SIZE SMALLER THAN THE GEOTEXTILE FABRIC, COURSE WASHED-SAND SHOULD BE USED AS A FILTER TO PREVENT BLOCKAGE OF THE GEOFABRIC. F8. THE BACKFILL LAYER OVER THE TRENCH SHALL BE NO-FINES COURSE WASHED-SAND. WHERE LANDSCAPED AREAS ARE PROPOSED OVER THE TRENCH, THE TOP 300mm OF BACKFILL MAY BE MIXED WITH UP TO 20% ORGANIC MATTER.

F9. ALL SUBSOIL LINES ARE TO DISCHARGE INTO A GRATED PIT, AT A LEVEL MINIMUM 50mm ABOVE THE PIT OUTLET UNO. THE PROJECT BUILDER IS TO IMPLEMENT APPROPRIATE MEASURES TO PREVENT SUBSOIL LINE BLOCKAGE OR INFESTATION OF VERMIN.

FIO. THE HIGH-END OF THE SUBSOIL LINE IS TO BE TURNED UP AT 45° AND TERMINATE AT GROUND LEVEL WITH AN INSPECTION CAP TO ENABLE FUTURE FLUSH OUT AND MAINTENANCE.

FIL 100mm \$\phi x 3000 LONG TAIL OUT SUBSOIL LINE TO BE PROVIDED ON THE UPSTREAM SIDE OF ALL LARGE PITS OR IN AREAS WITH HIGH SEEPAGE FLOWS. SUBSOIL LINE TO BE COVERED WITH GEOTEXTILE FILTER SOCK FOR THE FULL LENGTH AND END COVERED. BACKFILL MUST BE IN NO-FINES COARSE

CHARGED SYSTEM: GI. ALL PIPEWORK IN A CHARGED SYSTEM TO BE 100mm \$\phi\$ UPVC PRESSURE OR SEWER GRADE PIPES

WITH ALL JOINTS PRESSURE SEALED TO A MINIMUM OF 1,000mm (UNLESS NOTED OTHERWISE) ABOVE THE INLET OF THE DISCHARGE POINT. ALL JOINTS TO BE SOLVENT WELDED IN ACCORDANCE WITH THE

G2. ALL CHARGED SYSTEMS MUST HAVE A BLEED OUT LINE AT THE LOW POINT IN THE CHARGED SYSTEM WHICH MUST BE CONNECTED TO A FLUSH OUT PIT VIA GRAVITY. THE BLEED LINE MUST BE MAINTAINED AND REGULARLY FLUSHED OUT.

ON-SITE DETENTION NOTES: HI. ORIFICE PLATE MUST BE INSTALLED PRIOR TO INSTALLATION OF THE ROOF DRAINAGE SYSTEM AND CONNECTION OF THE SITE STORMWATER SYSTEM TO THE ON-SITE DETENTION TANK. H2. THE HEIGHT DIFFERENCE (H*) BETWEEN THE ORIFICE CENTRELINE AND THE TOP WATER LEVEL OF

THE ON-SITE DETENTION TANK MUST BE CONSTRUCTED IN ACCORDANCE WITH THE STORMWATER MANAGEMENT PLAN. IF H* CHANGES DUE TO SITE CONDITIONS, THE ENGINEER MUST BE NOTIFIED FOR AN ORIFICE PLATE SIZE ADJUSTMENT

H3. ANY PIPE FITTINGS FOR BELOW GROUND ON-SITE DETENTION TANKS MUST BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURERS SPECIFICATIONS.

H4. ACCESS HATCHES MUST BE INSTALLED AT BOTH ENDS OF THE ON-SITE DETENTION TANK. IF THE DEPTH OF THE TANK IS GREATER THAN 1200mm, STEPS IRONS MUST BE INSTALLED IN ACCORDANCE WITH THE RELEVANT AUSTRALIAN STANDARDS

H5. ABOVE GROUND ON-SITE DETENTION BASINS MUST NOT EXCEED A PONDING DEPTH OF 300mm, UNLESS NOTED OTHERWISE. THE BUILDER MUST ENSURE THAT THE REQUIRED DETENTION VOLUME IS ACHIEVED DURING CONSTRUCTION. A WORK-AS-EXECUTED PLAN DETAILING THE FINISHED LEVELS AND VOLUME OF THE ON-SITE DETENTION BASIN MUST BE CARRIED OUT AT THE COMPLETION OF WORKS BY A REGISTERED SURVEYOR AND APPROVED BY THE ENGINEER PRIOR TO FINAL CERTIFICATION. SURFACE DRAINAGE:

JI. WHEN LAND FALLS TOWARDS A BUILDING, INCLUDING LAND UPSLOPE OF THE PROPERTY BOUNDARY, GROUND SURFACE LEVELS ADJACENT TO THE BUILDING ARE TO BE REGRADED SUCH THAT THE FIRST METRE HAS MINIMUM 50mm FALL AWAY FROM THE BUILDING, GENERALLY IN ACCORDANCE WITH THE

J2. ANY NEW DEVELOPMENT WORKS MUST NOT CREATE ANY TRAPPED SURFACE AREAS. IN SUCH CASES WHERE TRAPPED AREAS EXIST, SWALE DRAINS OR GRATED PITS WITH PIPED OUTLETS OF ADEQUATE CAPACITY MAY BE REQUIRED TO ROUTE RUNOFF AROUND THE BUILDING TO AN APPROVED DISCHARGE POINT. IF THE TRAPPED AREA IS BELOW THE NATURAL SURFACE LEVEL, A PUMP OUT SYSTEM MAY BE REQUIRED. IN EITHER CASE, THE PROJECT ENGINEER MUST BE CONTACTED FOR DESIGN DETAILS (AS REQUIRED) PRIOR TO CONSTRUCTION.

J3. BUILDER TO PROVIDE A MINIMUM 100mm WIDE x 30mm HIGH OR 50mm DIA OVERFLOW FOR EVERY 6m2 OF EXPOSED AREA THAT IS TRAPPED OR SURROUNDED BY HOBS/BALUSTRADES/WALLS/ETC. THE FULL OVERFLOW DEPTH MUST BE LOCATED BELOW ANY ADJACENT INTERNAL FLOOR LEVELS OR OPENINGS TO PROTECT AGAINST WATER INGRESS DUE TO BLOCKAGE OF THE PRIMARY OUTLET(S).

RAINWATER RE-USE TANKS:

KI: CONSIDERING THE ROOF CATCHMENT AREA, LOCATION OF PROPERTY, INTENDED USE OF RAINWATER AND GARDEN SIZE WE RECOMMEND PROVIDING A RAINWATER TANK FOR USE AS PER BASIX REQUIREMENTS, SYDNEY WATER AND NSW HEALTH REQUIREMENTS FOR NON DRINKING USE ONLY AS FOLLOWS:

a) TO WATER GARDEN AREAS

b) FILLING SWIMMING POOLS, SPAS AND ORNAMENTAL PONDS.

K2: THE TANKS PROVIDED WILL REDUCE PRESSURE ON COUNCIL'S STORMWATER INFRASTRUCTURE. K3: REFERENCES: COOMBES P.J. & KUCZERA G. (2001), "RAINWATER TANK DESIGN FOR WATER SUPPLY & STORMWATER MANAGEMENT." STORMWATER INDUSTRY ASSOCIATION REGIONAL CONFERENCE. PATRICK DUPONT & STEVE SHACKLE, "RAINWATER" AUSTRALIAN GOVERNMENT (2004), "GUIDANCE ON USE OF RAINWATER TANKS".

K4: ALL CONNECTIONS TO PLUMBING AND RAINWATER TANKS TO BE IN ACCORDANCE WITH SYDNEY WATERS' GUIDE "INSTALLING A RAINWATER TANK" AVAILABLE AT www.sydneywater.com.au K5: PROVIDE A DUAL SUPPLY SYSTEM AND BACKFLOW PREVENTION SYSTEM IN ACCORDANCE WITH 'BASIX-DESIGN GUIDE FOR SINGLE DWELLINGS' BY NSW DEPARTMENT OF INFRASTRUCTURE, PLANING AND NATURAL RESOURCES.

K6: IF NOT SPECIFIED ON PLANS, THE FIRST FLUSH SYSTEM IS TO HAVE A MINIMUM SIZE OF 20L PER 100m2 OF ROOF CATCHMENT AREA PRIOR TO ENTERING THE RAINWATER TANK, INDIVIDUAL SITE ANALYSIS IS REQUIRED IN HEAVILY POLLUTED AREAS TO DETERMINE IF LARGER VOLUMES OF FIRST FLUSH RAINWATER ARE TO BE DIVERTED. IF IN DOUBT, CHECK WITH LOCAL HEALTH AUTHORITIES. K7: SCREENED DOWNPIPE RAINWATER HEAD OR OTHER SUITABLE LEAF AND DEBRIS DEVICE TO BE INSTALLED ON EACH DOWNPIPE. SCREEN MESH TO BE 4-6mm AND DESIGNED TO BE SELF-CLEANING. K8: FIRST FLUSH DEVICES, OR APPROVED ALTERNATIVE, TO BE INSTALLED WITH AN AUTOMATED DIVERSION AND DRAINAGE SYSTEM, THAT IS, NO MANUAL DIVERSION AND DRAINAGE VALVES. REFER TYPICAL FLUSH OUT PIT FOR DETAILS.

K9: BEFORE PURCHASING MATERIALS OR PAINT TO BE USED ON ROOF CATCHMENT AREAS, THE MANUFACTURER'S RECOMMENDATIONS ON LABELS AND BROCHURES FOR RAINWATER TANK SUITABILITY TO BE READ AND ADHERED TO.

KIO: PRE-STORAGE PITS FOR UNDERGROUND RAINWATER STORAGE TANKS AND FLUSH OUT PITS MAY ASSIST IN LIMITING SILT, AND PREVENT VERMIN, INSECTS (INCLUDING MOSQUITOES) AND DEBRIS FROM ENTERING THE RAINWATER STORAGE AREA.

KII: BUILDER/PLUMBER TO ENSURE THE INSTALLATION OF THE RAINWATER TANK SYSTEM IS IN ACCORDANCE WITH THE RELEVANT AUSTRALIAN STANDARDS AND THE RAINWATER TANK DESIGN AND INSTALLATION HANDBOOK - HB 230-2008. IF IN DOUBT CONTACT ENGINEER. KI2: RAINWATER TANK TO BE WATER PROOFED IN ACCORDANCE WITH HB 230-200B

STORMWATER RE-USE TANKS:

DRAWING SCHEDULE:

DOI - STORMWATER DRAINAGE GENERAL NOTES

DOS - STORMWATER DRAINAGE DETAILS SHEET

DO2 - BASEMENT LEVEL STORMWATER DRAINAGE PLAN

STI: BASIX RECOMMENDS PROVIDING A STORMWATER TANKS FOR USE AS PER BASIX REQUIREMENTS FOR THE FOLLOWING USES: a) TO WATER GARDEN AREAS

ST2: THE TANKS PROVIDED WILL REDUCE PRESSURE ON COUNCIL'S STORMWATER INFRASTRUCTURE. ST3: IF NOT SPECIFIED ON PLANS, THE FIRST FLUSH SYSTEM IS TO HAVE A MINIMUM SIZE OF 20L PER 100m2 OF ROOF CATCHMENT AREA PRIOR TO ENTERING THE RAINWATER TANK, INDIVIDUAL SITE ANALYSIS IS REQUIRED IN HEAVILY POLLUTED AREAS TO DETERMINE IF LARGER VOLUMES OF FIRST FLUSH RAINWATER ARE TO BE DIVERTED. IF IN DOUBT, CHECK WITH LOCAL HEALTH AUTHORITIES. ST4: SCREENED DOWNPIPE RAINWATER HEAD OR OTHER SUITABLE LEAF AND DEBRIS DEVICE TO BE INSTALLED ON EACH DOWNPIPE. SCREEN MESH TO BE 4-6mm AND DESIGNED TO BE SELF-CLEANING. ST5: FIRST FLUSH DEVICES, OR APPROVED ALTERNATIVES, TO BE INSTALLED WITH AN AUTOMATED DIVERSION AND DRAINAGE SYSTEM, THAT IS, NO MANUAL DIVERSION AND DRAINAGE VALVES. REFER TYPICAL FLUSH OUT PIT FOR DETAILS

ST6: BEFORE PURCHASING MATERIALS OR PAINT TO BE USED ON ROOF CATCHMENT AREAS, THE MANUFACTURER'S RECOMMENDATIONS ON LABELS AND BROCHURES FOR RAINWATER TANK SUITABILITY TO BE READ AND ADHERED TO.

NORTHERN BEACHES COUNCIL (WARRINGAH AREA) ON SITE DETENTION SYSTEM CALCULATION SHEET

ADDRESS: 52 BURCHMORE RD, MANLY VALE SITE STORMWATER DISPOSAL METHOD

STEP 1: CONNECTION TO EXISTING DRAINAGE SYSTEM

SITE DETAILS

 735.7 m^2 (BY D.P.) TOTAL SITE AREA

PRE DEVELOPMENT IMPERVIOUS AREA 322.8 m 2 (44% IMPERVIOUS) 398.6 m 2 (54% IMPERVIOUS) POST DEVELOPMENT IMPERVIOUS AREA

OSD REQUIREMENT

THIS IS AN ALTERATIONS AND ADDITIONS AND THE SITE HAS A DIRECT CONNECTION TO COUNCIL'S

STORMWATER SYSTEM VIA AN EASEMENT, THEREFORE OSD IS NOT REQUIRED

SITE STORAGE REQUIREMENT

OSD VOLUME REQUIRED

RAINWATER 'BASIX' REQUIRED

OUTLET CONTROL

METHODS OF DISCHARGE EXISTING DRAINAGE EASEMENT

DIAL BEFORE YOU DIG NOTE:

NO INVESTIGATION OF UNDERGROUND SERVICES HAS BEEN MADE. ALL RELEVANT AUTHORITIES SHOULD BE NOTIFIED PRIOR TO ANY EXCAVATION ON OR NEAR THE SITE DEVELOPERS \$ EXCAVATORS MAY BE HELD FINANCIALLY RESPONSIBLE BY THE ASSET OWNER SHOULD THEY DAMAGE UNDERGROUND NETWORKS.

CARELESS DIGGING CAN:

- CAUSE DEATH OR SERIOUS INJURY TO WORKERS AND THE
- INCONVENIENCE USERS OF ELECTRICITY, GAS, WATER AND COMMUNICATIONS
- LEAD TO CRIMINAL PROSECUTION AND DAMAGES CLAIMS - CAUSE EXPENSIVE FINANCIAL LOSSES TO BUSINESS
- CUT OFF EMERGENCY SERVICES - DELAY PROJECT COMPLETION TIMES WHILE THE DAMAGE IS
- REPAIRED



1,739 L (2,000 L PROVIDED)

MINIMISE YOUR RISK AND DIAL BEFORE YOU DIG. - TEL. 1100

NOTES:

1. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION IF THE ISSUE DATE PRECEDES THE ISSUE DATE ON THE ARCHITECTURAL DRAWINGS.

ISSUED FOR D.A. SUBMISSION ONLY NOT FOR CONSTRUCTION

IF IN DOUBT ASK

52 Burchmore Road, Manly Vale NSW 2093

Project: ALTERATIONS AND ADDITIONS

2. DO NOT SCALE FROM THIS DRAWING.

ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER BEFORE COMMENCING WITH ASSOCIATED WORK.

FOR GENERAL NOTES REFER

TO DRAWING NUMBER: DOI.

Paul R Bruce July 2021 AMIEAust.

A1				
21.07.2021	А	ISSUED FOR D.A. SUBMISSION ONLY - NOT FOR CONSTRUCTION	P.R.B.	C.F
Date:	Issue:	Description:	Ву:	Revie

DOCUMENT CERTIFICATION Date : 21 Jul '21 Michael Wach jo / B.E.(Civil), MIEAust (Director NB Consulting Engineers)

The copyright of this drawing remains with Northern Beaches

onsulting Engineers Pty Ltd. Trading as NB Consulting Enginee

Consulting Engineers | Architect: STRUCTURAL - CIVIL - STORMWATER - REMEDIAL A.C.N. 076 121 616 A.B.N. 24 076 121 616 **Sydney**: Ph: (02) 9984 7000 Suite 207, 30 Fisher Road Dee Why N.S.W. 2099

Gold Coast: Ph: (07) 5631 4744 Suite 1, 30B Griffith Street, Coolangatta QLD 4225 E: nb@nbconsulting.com.au W: www.nbconsulting.com.au

Morten & Kylie Scheibye

Action Plans

DO4 - FIRST FLOOR LEVEL AND ROOF STORMWATER DRAINAGE PLANS

DO3 - GRANNY FLAT AND GROUND FLOOR LEVELS STORMWATER DRAINAGE PLANS

STORMWATER DRAINAGE GENERAL NOTES

Drawing No:

D01

EXISTING SUBFLOOR DRAINAGE TO BE INSPECTED AND UPGRADED AS REQUIRED TO AS 3500.3. RECOMMENDED 600mm MINIMUM WIDE SPOON DRAIN TO COLLECT SUBFLOOR RUNOFF.

ALL PIPES TO BE 100mm ϕ uPVC UNLESS NOTED OTHERWISE ALL PIPES TO BE LAID AT 1 % MINIMUM FALL UNLESS NOTED OTHERWISE BASEMENT LEVEL STORMWATER DRAINAGE PLAN

DECK PROPOSED FFL 4.230

BLEED LINE FROM-

CHARGED SYSTEM

LIVING PROPOSED

FFL 4.280

PROPOSED

WORKSHOP PROPOSED

REFER TO DRAWING No. DO4 -

300x300 GRATED PIT

600mm MINIMUM WIDE DRAINAGE VOID

WITH MASS CONCRETE SPOON DRAIN

WITH 1 % MINIMUM FALL TO PITS ACCESS TO BE PROVIDED TO

DRAINAGE VOID FOR MAINTAINENCE ACCESS DETAILS BY OTHERS

300x300 GRATED PIT

INV 3.700 OUTLET INV 3.600 PIT

FSL 4.100

INV 3.700 OUTLET

INV 3.600 PIT

FSL 4.100

FOR CONTINUATION

SCALE = 1 : 100

- 450x450 GRATED CHARGED SYSTEM FLUSH OUT PIT

— 150mm φ υPVC

PROPOSED POOL

PROPOSED FFL 3.720

FSL 3.720

INV 3.220 OUTLET INV 3.120 PIT

LEGEND 100mm \$\phi\$ DOWNPIPE TO DISCHARGE TO OSD TANK INSPECTION OPENING NEW STORMWATER PIPE EXISTING STORMWATER PIPE ======== STORMWATER PIPE FLOW DIRECTION GRATED DRAIN GDI - 150 MIN DEPTH x 150 WIDE GRATED DRAIN GD2 - STORMTECH 65AG GRATED DRAIN NOTE: ALL DRAINAGE LINE LOCATIONS ARE INDICATIVE ONLY. LOCATION MAY VARY DUE TO CONSTRAINTS.

-300x300 GRATED PIT

INV 3.400 OUTLET

INV 3.300 PIT

FSL 3.700

ASSUMED LOCATION OF EXISATING -

STORMWATER PIPE DISCHARGING TO EXISTING REAR BOUNDARY PIT

SWIMMING POOL SURCHARGE OVERFLOW TO BE CONNECTED TO SYDNEY WATER SEWER IN ACCORDANCE WITH AS3500.2.2.2003 DETAILS AND CERTIFICATION BY OTHERS.

EXISTING BOUNDARY PIT

NOTES:

- 1. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION IF THE ISSUE DATE PRECEDES THE ISSUE DATE ON THE ARCHITECTURAL DRAWINGS.
- 2. DO NOT SCALE FROM THIS DRAWING. ISSUED FOR D.A. SUBMISSION ONLY
 - 3. ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER BEFORE COMMENCING WITH ASSOCIATED WORK.

IF IN DOUBT ASK				
13	IF	IN	DOUBT	ASK

www.1100.com.au

NOT FOR

CONSTRUCTION

	BT ASK	4.	FOR GENERAL TO DRAWING	
--	--------	----	---------------------------	--


4.	FOR GENERAL NOTES REFER
	TO DRAWING NUMBER: DOI.

L	, w										
ŀ			DOCUMENT CERTIFICATION	Consulting Engineers STRUCTURAL - CIVIL - STORMWATER - REMEDIAL	Architect:		Project: ALTERATIONS AND ADDITIONS	Date:	Design:	Drawn:	
ŀ			Date : 21 Jul '21 / /	STRUCTURAL - CIVIL - STORMWATER - REMEDIAL A.C.N. 076 121 616 A.B.N. 24 076 121 616		Action Plans	52 Burchmore Road, Manly Vale NSW 2093	July 2021	S.R.	Paul R Br AMIEAust.	bruce
			Michael Wachjo	Sydney: Ph: (02) 9984 7000 Suite 207, 30 Fisher Road Dee Why N.S.W. 2099	Client:		Drawing Title: BACEMENT EVE	Job No:		Drawing No:	Issue:
ŀ		. C.F.	B.E.(Civil), MIEAust. (Director NB Consulting Engineers)	Gold Coast: Ph: (07) 5631 4744 Suite 1, 30B Griffith Street, Coolangatta QLD 4225		Morten & Kylie Scheibye	BASEMENT LEVEL STORMWATER DRAINAGE PLAN	2106	,2a	D02	
L	Date: Issue: Description: By:	Review:	The copyright of this drawing remains with Northern Beaches Consulting Engineers Pty Ltd. Trading as NB Consulting Engineers			THE COLL & TOYTHO SCHOOLS	STORTINATER DRAINAGE PLAN	2106	<u>/</u>		<u> </u>

SUBFLOOR EXISTING SECONDARY DWELLING ENTRY EXISTING BATH EXISTING

ALL PIPES TO BE 100mm ϕ uPVC UNLESS NOTED OTHERWISE ALL PIPES TO BE LAID AT 1 % MINIMUM FALL UNLESS NOTED OTHERWISE GRANNY FLAT LEVEL STORMWATER DRAINAGE PLAN

SCALE = 1 : 100



ALL PIPES TO BE 100mm ϕ uPVC UNLESS NOTED OTHERWISE ALL PIPES TO BE LAID AT 1 % MINIMUM FALL UNLESS NOTED OTHERWISE GROUND FLOOR LEVEL STORMWATER DRAINAGE PLAN

SCALE = 1 : 100



LEGEND

FDI 🗏

NOTES:

100mm & DOWNPIPE TO DISCHARGE TO RWT

REFER TO NOTE 'J3' ON DRAWING No. DOI

RAINHEAD WITH 100mm & DOWNPIPE

50mm \$\psi\$ uPVC STORMWATER PIPE BUILT INTO FLOOR STRUCTURE

STORMWATER PIPE FLOW DIRECTION

FLOOR DRAIN, REFER TO DETAILS

NOTE: ALL DRAINAGE LINE LOCATIONS ARE INDICATIVE ONLY.

ISSUED FOR D.A.

SUBMISSION ONLY

NOT FOR

CONSTRUCTION

LOCATION MAY VARY DUE TO CONSTRAINTS.

GDI - 150 MIN DEPTH x 150 WIDE GRATED DRAIN

RAINWATER TANK TO COLLECT ALL DPI DOWNPIPES.

TO BE RE-USED AS PER BASIX REQUIREMENTS

LOCAL COUNCIL \$ SYDNEY WATER REQUIREMENTS

GD2 - STORMTECH 65AG GRATED DRAIN

DISCHARGE TO RWT

IN CHARGED SYSTEMS

STORMWATER PIT

GRATED DRAIN

100mm \$\phi\$ DOWNPIPE TO DISCHARGE TO BOUNDARY PIT

- 1. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION IF THE ISSUE DATE PRECEDES THE ISSUE DATE ON THE ARCHITECTURAL DRAWINGS.
- 2. DO NOT SCALE FROM THIS DRAWING.
- 3. ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER BEFORE COMMENCING WITH ASSOCIATED WORK.


1	ाम	IN	DOUBT	ASK	4.	FOR GENER
	11	11.4	DOODI	ADI	IJ	TO DPAMII

4.	FOR GENERAL	NOTES	REFE
	TO DRAWING	NUMBER	: D01.

		Date : 21 Jul '21	Consulting Engineers STRUCTURAL - CIVIL - STORMWATER - REMEDIAL A.C.N. 076 121 616 A.B.N. 24 076 121 616	Action Plans	Project: ALTERATIONS AND ADDITIONS 52 Burchmore Road, Manly Vale NSW 2093			Drawn: Paul R Bruce AMIEAust.
21.07.2021	A ISSUED FOR BUILT HOT FOR SOMETHING	(Director ND Consulting Engineers)	Sydney: Ph: (02) 9984 7000 Suite 207, 30 Fisher Road Dee Why N.S.W. 2099 Gold Coast: Ph: (07) 5631 4744 Suite 1, 30B Griffith Street, Coolangatta QLD 4225	Client: Morten \$ Kylie Scheibye	Drawing Title: GRANNY FLAT AND GROUND FLOOR LEVELS STORMWATER DRAINAGE PLANS	Job No: 2100	629	Drawing No: Issue:
Date:	Issue: Description: By: Review:	The copyright of this drawing remains with Northern Beaches Consulting Engineers Pty Ltd. Trading as NB Consulting Engineers		Thereen Trythe Serienbye	LEVELS STURINATER DRAINAGE PLANS	Z10k		

BEDROOM 3 MASTER BEDROOM SHADE SAIL CARPORT PROPOSED PROPOSED BUILT INTO FLOOR STRUCTURE


ALL PIPES TO BE 100mm ϕ uPVC UNLESS NOTED OTHERWISE ALL PIPES TO BE LAID AT 1 % MINIMUM FALL UNLESS NOTED OTHERWISE FIRST FLOOR LEVEL STORMWATER DRAINAGE PLAN SCALE = 1 : 100



ALL PIPES TO BE 100mm ϕ uPVC UNLESS NOTED OTHERWISE ALL PIPES TO BE LAID AT 1 % MINIMUM FALL UNLESS NOTED OTHERWISE

ROOF STORMWATER DRAINAGE PLAN

SCALE = 1 : 100



NOTES:

- 1. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION IF THE ISSUE DATE PRECEDES THE ISSUE DATE ON THE ARCHITECTURAL DRAWINGS.
- 2. DO NOT SCALE FROM THIS DRAWING.
- 3. ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER BEFORE COMMENCING WITH ASSOCIATED WORK.

ww.1100.com.au
IAL 1100 FORE YOU DIG


www.1100.com.au	SUBMISSION ONLY NOT FOR CONSTRUCTION
DIAL 1100 BEFORE YOU DIG	IF IN DOUBT ASK


IF	IN	DOUBT	ASK	$\bigg)$

ISSUED FOR D.A.

4.	FOR GENERAL NOTES REFER
	TO DRAWING NUMBER: DOI.


		DOCUMENT CERTIFICATION	Consulting Engineers STRUCTURAL - CIVIL - STORMWATER - REMEDIAL	• • • • • • • • • • • • • • • • • • • •	Project: ALTERATIONS AND ADDITIONS	Date:	Design:	Drawn: Paul R Bruce
		Date: 21 Jul '21 Michael Wachjo B.E.(Civil), MIEAust. (Director NB Consulting Engineers)	A.C.N. 076 121 616 A.B.N. 24 076 121 616 Sydney: Ph: (02) 9984 7000	Action Plans	52 Burchmore Road, Manly Vale NSW 2093	July 2021	S.R.	AMIEAust.
21.07.2021	A ISSUED FOR D.A. SUBMISSION ONLY - NOT FOR CONSTRUCTION P.R.B. C.F.		\ ,	Client:	Drawing Title: FIRST FLOOR LEVEL AND ROOF STORMWATER DRAINAGE PLANS	Job No: 21062		Drawing No: Issue:
Date:	Issue: Description: By: Review:		Suite 1, 30B Griffith Street, Coolangatta OLD 4225	Morten & Kylie Scheibye			<u> </u>	D04 A






PRECAST OR CAST INSITU PIT REFER STORMWATER NOTES 450x450 CHARGED SYSTEM FLUSH OUT PIT DETAIL SCALE = 1 : 20

TYPICAL SECTION RAINWATER RE-USE TANKS WITH CHARGED PIPE SYSTEM NOT TO SCALE



PRECAST OR CAST INSITU PIT REFER STORMWATER NOTES ALTERNATE POLYPROPYLENE PIT BY MANUFACTURER

> 300x300 PIT DETAIL SCALE = 1 : 20



OR PRECAST GRATED DRAIN ALTERNATE POLYPROPYLENE DRAIN BY MANUFACTURER

> TYPE 'GDI' GRATED DRAIN SCALE = 1 : 20

NOTES:

- 1. THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION IF THE ISSUE DATE PRECEDES THE ISSUE DATE ON THE ARCHITECTURAL DRAWINGS.
- 2. DO NOT SCALE FROM THIS DRAWING. ISSUED FOR D.A. SUBMISSION ONLY
 - 3. ALL DIMENSIONS ARE TO BE VERIFIED ON SITE BY THE BUILDER BEFORE COMMENCING WITH ASSOCIATED WORK.
 - FOR GENERAL NOTES REFER

CONSTRUCTION www.1100.com.au DIAL 1100 BEFORE YOU DIG IF IN DOUBT ASK

TO DRAWING NUMBER: DOI.

			Date : 21 Jul '21	Consulting Engineers STRUCTURAL - CIVIL - STORMWATER - REMEDIAL A.C.N. 076 121 616 A.B.N. 24 076 121 616	Architect:	Action Plans	Project: ALTERATIONS AND ADDITIONS 52 Burchmore Road, Manly Vale NSW 2093	July 2021	Design:	Drawn: Paul R E AMIEAust.	
21.07.2021	A ISSUED FOR D.A. SUBMISSION ONLY - NOT FOR CONSTRUCTION P.R.B.).	Michael Wachjo B.E.(Civil), MIEAust. (Dinasten NB Consulting Engineers)	Sydney: Ph: (02) 9984 7000 Suite 207, 30 Fisher Road Dee Why N.S.W. 2099 Gold Coast: Ph: (07) 5631 4744	Client:		Drawing Title: STORMWATER DRAINAGE	Job No:		Drawing No:	Iss
Date:	Issue: Description: By:	Review:	■ The convright of this drawing remains with Northern Beaches ■	Suite 1, 30B Griffith Street, Coolangatta QLD 4225 E: nb@nbconsulting.com.au W: www.nbconsulting.com.au	u	Morten & Kylie Scheibye	DETAILS SHEET 1	2106	24	D05	

NOT FOR