

Building Assessment Referral Response

Application Number:	DA2022/2148
Proposed Development:	Demolition works and construction of a building for use as a specialised retail premises including signage
Date:	29/12/2022
To:	Maxwell Duncan
Land to be developed (Address):	Lot 18 DP 819775 , 202 Condamine Street BALGOWLAH NSW 2093 Lot 17 DP 819775 , 204 Condamine Street BALGOWLAH NSW 2093 Lot 91 DP 607382 , 200 Condamine Street BALGOWLAH NSW 2093

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Building Code of Australia Fire Safety Requirements

The Building Code of Australia fire safety requirements for the building as detailed and recommended in the BCA Assessment Report prepared by BCA Logic, dated 25/10/2022, Ref 115853-BCA-r1, including any required Performance Solutions, is to be considered as part of the assessment for any

Construction Certificate. Details demonstrating compliance are to be provided to the Certifying Authority, prior to the issue of a Construction Certificate..

Reason: To ensure adequate provision is made for Health, Amenity, access and Fire safety for building occupant health and safety.

Access and Facilities for Persons with Disabilities

Access and facilities to and within the building are to be provided for Persons with a Disability in accordance with the Building Code of Australia and AS1428, In this regard the Access Assessment Report prepared by BCA Logic, Ref 115853- Access-r1 dated 25/10/2022 is to be included as part of the Construction Certificate assessment. Details are to be provided to the Certifying Authority prior to the issue of the Construction Certificate and be implemented prior to occupation of the building.

Reason: To ensure adequate provision is made for access to and within the building for Persons with a disability.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and the NSW Fire Brigade.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of an Occupation Certificate.

Each year the Owners must send to the Council and the NSW Fire Brigade an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement of the Environmental Planning and Assessment Regulation 2021.