

# FIRE SAFETY SCHEDULE

**Premises:**

91 North Steyne, Manly

**Development Consent:**

TBA

**Construction Certificate:**

TBA

The following essential fire safety measures are proposed as part of the works to infill two balconies at the above address.

| NO. | ESSENTIAL FIRE AND OTHER SAFETY MEASURES      | STANDARD OF PERFORMANCE  | PROPOSED |
|-----|-----------------------------------------------|--------------------------|----------|
| 1.  | Fire Shutters<br>(Western window apartment 4) | BCA E1.3 & AS2419.1-2005 | Yes      |
| 2.  | Wall Wetting drencher system                  | BCA C3.4 & AS2118.2      | Yes      |