

Natural Environment Referral Response - Flood

Application Number:	Mod2024/0697
Proposed Development:	Modification of Development Consent DA2018/0563 granted for Construction of a new dwelling house with internal lift and garage
Date:	18/02/2025
To:	Stephanie Gelder
Land to be developed (Address):	Lot 27 DP 28669 , 950 Barrenjoey Road PALM BEACH NSW 2108

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This proposal is for the modification of Development Consent DA2018/0563, as modified under MOD2024/0697. The proposal includes the construction of a new lower ground floor level and a reconfiguration of the internal stairway. The proposal is assessed against Section B3.11 of the Pittwater DCP and Clause 5.21 of the Pittwater LEP.

The proposal is located within the Medium and Low Flood risk precincts. The flood characteristics vary across the site due to the topography.

The FFL of the proposed storeroom under the stairs is below the 1% AEP level of that location. An additional flood assessment provided justification for the the floor level at that location.

As such, subject to conditions, the proposal generally complies with Section B3.11 of the Pittwater DCP and Clause 5.21 of the Pittwater LEP.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Flood effects caused by development

There is to be no filling of the land or any other reduction of the available flood storage which results in a net loss of storage below the 1% AEP flood level of 30.04m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Building components and structural soundness

B1 - All new development below the Flood Planning Level of each site shall be designed and constructed from flood compatible materials.

B2 - All new development must be designed to ensure structural integrity up to the Flood Planning Level of each location, taking into account the forces of floodwater, debris load, wave action, buoyancy and immersion.

B3 - All new and existing electrical equipment, power points, wiring and connections must be located above the Flood Planning Level of each site, protected from flood water or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Floor levels

C1 - New floor levels within the development shall be set at or above the Flood Planning Level for each site.

C2 - New floor levels within the development shall be set at or above the Probable Maximum Flood Level.

C3 - The underfloor area of the dwelling below the 1% AEP flood level is to be designed to allow clear passage of floodwaters. At least 50% of the perimeter of the underfloor area must be of an open design from the natural ground level up to the 1% AEP flood level.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Storage of Goods

Storage areas for hazardous or potentially polluting materials shall not be located below the Flood Planning Level of 30.54m AHD unless adequately protected from floodwaters in accordance with industry standards.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Certification of Works as Executed

A suitably qualified engineer and/or registered surveyor is to certify that the completed works have been constructed in accordance with this consent and the approved plans with respect to the following:

1. Floor levels for ground floor, shelter in place refuge and garage are set at or above the required level
2. There has been no filling on the land other than what has been approved
3. Openings are provided under floor areas where required for the free passage of flood waters

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

Building Components and Structural Soundness

B2 - A suitably qualified structural engineer is to certify the structural integrity of the new development up to the Flood Planning Level. The depth, velocity, debris load, wave action, buoyancy and immersion must all be considered.

B3 - A suitably qualified electrician or contractor is to certify that all new and existing electrical equipment, power points, wiring and connections are located above the Flood Planning Level, are protected from flood water or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.