

Natural Environment Referral Response - Coastal

Application Number:	Mod2024/0593
Proposed Development:	Modification of Development Consent N0363/16 granted for demolition of existing dwelling and construction of a new dwelling house, secondary dwelling and inclinor
Date:	05/02/2025
Responsible Officer	Phil Lane
Land to be developed (Address):	Lot A DP 347026 , 132 McCarrs Creek Road CHURCH POINT NSW 2105 Lot LIC 570209 , 132 McCarrs Creek Road CHURCH POINT NSW 2105

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed modifications are minor in nature and do impact the assessment of coastal matters considered for N0363/16

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Stockpiling materials

During construction, all material associated with works is to be contained at source, covered and must be within the construction area. All material is to be removed off site and disposed of according to local regulations. The property is to be kept clean and any building debris removed as frequently as required to ensure no debris enters receiving waters.

Reason: To ensure pollution control measures are effective to protect the aquatic habitats within receiving waters throughout the construction period.