**Sent:** 1/07/2020 8:51:17 AM

Subject: FW: Northern Beaches Local Planning Panel Notice

**Attachments:** NBLPP Plans.pdf;

Hi Carly,

I'd like to represent United Petroleum and address the panel via teleconference with regard to our proposed rectification of light spill into the neighbours property via individual light screens.

As per the attached, United Petroleum are proposing a 250mm aluminium shroud around all car canopy lights as opposed to the Council proposed 500mm skirt to the edge of the canopy structure.

The attached elevation shows this will have a greater impact on reducing light spill to all neighbouring tenancies. To ensure adequate lighting throughout the site and the subsequent safety of our customers, we advise against shrouding to 500mm locally on the two lights requested by Council.

Thanks,

## Matt



## Matt Anderson | Project Manager

S.H.A. Premier Constructions Pty Ltd | 600 Glenferrie Rd, Hawthorn Vic Australia 3122 M: 0416 405 295 | E: matthew.anderson@shapremierconstructions.com.au

This e-mail and the attachments may be confidential and subject to legal professional privilege. If you are not the correct recipient of this e-mail please contact us, delete it immediately and destroy any copies. Please consider the environment before printing email.

