

Natural Environment Referral Response - Coastal

Application Number:	DA2021/2265
Date:	26/11/2021
Responsible Officer	David Auster
Land to be developed (Address):	Lot 2 DP 6238 , 4 Burchmore Road MANLY VALE NSW 2093

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application was assessed in consideration of:

- Supplied plans and reports;
- Coastal Management Act 2016;
- State Environmental Planning Policy (Coastal Management) 2018 (clauses 13 & 15); and
- Relevant LEP and DCP clauses.

The application meets the requirements of the relevant Environmental Planning Instruments and policies.

The application is supported subject to conditions:

- Stormwater Management (prior to construction certificate)
- Pollution control (during works)

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Stormwater Management

Stormwater shall be disposed of in accordance with Council's Policy. The stormwater management plan is to be implemented to ensure that there is no increase in stormwater pollutant loads arising from the approved development. Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from development, ensuring that the proposed works do not negatively impact receiving waters.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Pollution Control

All stockpiles, materials, waste and slurry associated with works (including excavated material) is to be contained at source within the construction area and enclosed in waterproof covering and/or sediment and erosion control while not in use. All waste/debris is to be removed off site and disposed of as frequently as required in accordance to local regulations.

Reason: To protect the surrounding environment, and ensure that pollutants and building associated waste do not leave the construction site.