

## Natural Environment Referral Response - Flood

<b>Application Number:</b>	DA2025/1273
<b>Proposed Development:</b>	Demolition works and construction of a dwelling house including a swimming pool
<b>Date:</b>	24/09/2025
<b>To:</b>	Lachlan Rose
<b>Land to be developed (Address):</b>	Lot 7 DP 6260 , 14 Stewart Avenue CURL CURL NSW 2096

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

This proposal is for the demolition of an existing building, and the construction of a new two-storey dwelling including an in-ground pool.

The proposed dwelling's floor levels are above the FPL for the site, and the proposed swimming pool is outside of the 1% AEP extent.

Subject to the following conditions, the proposal generally complies with Section E11 of the Warringah DCP and Clause 5.21 of the Warringah LEP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Natural Environment Conditions:

#### CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### Building components and structural soundness

B1 - All new development below the Flood Planning Level of 4.19m AHD shall be designed and constructed from flood compatible materials.

B2 - All new development must be designed to ensure structural integrity up to the Flood Planning Level of 4.19m AHD, taking into account the forces of floodwater, debris load, wave action, buoyancy and immersion.

B3 - All new and existing electrical equipment, power points, wiring and connections must be located above

the Flood Planning Level of 4.19m AHD, protected from flood water or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

### **Floor levels**

C1 - New floor levels within the development shall be set at or above the Flood Planning Level of 4.19m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

### **Fencing**

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open to allow for the unimpeded movement of flood waters. It must be designed with a minimum of 50% open area along any straight length, from the natural ground level up to the 1% AEP flood level. Openings shall be a minimum of 75mm x 75mm.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

### **Pools**

All electrical equipment associated with the pool (including pool pumps) is to be waterproofed and/or located at or above the Flood Planning Level of 4.19m AHD.

All chemicals associated with the pool are to be stored at or above the Flood Planning Level of 4.19m AHD.

Pool fencing shall be open to allow for the unimpeded movement of flood waters. It must be designed with a minimum of 50% open area from the natural ground level up to the 1% AEP flood level of 3.69m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Certification of Works as Executed**

A suitably qualified engineer and/or registered surveyor is to certify that the completed works have been constructed in accordance with this consent and the approved plans with respect to the following:

1. Floor levels for ground floor, shelter in place refuge and garage are set at or above the required level

2. Openings are provided in fencing where required for the free passage of flood waters

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

### **Building Components and Structural Soundness**

B2 - A suitably qualified structural engineer is to certify the structural integrity of the new development up to the Flood Planning Level of 4.19m AHD. The depth, velocity, debris load, wave action, buoyancy and immersion must all be considered.

B3 - A suitably qualified electrician or contractor is to certify that all new and existing electrical equipment, power points, wiring and connections are located above the Flood Planning Level of 4.19m AHD, are protected from flood water or have residual current devices installed to cut electricity supply during flood events.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to the issue of the Occupation Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.