

Parks, Reserves and Foreshores Referral Response

Application Number:	DA2022/0971
Date:	20/07/2022
To:	Clare Costanzo
Land to be developed (Address):	Lot 7379 DP 1164856 , 0 Sydney Road MANLY NSW 2095 Lot 2502 DP 1143032 , 0 Sydney Road MANLY NSW 2095

Reasons for referral

This application seeks consent for any application on land or land being adjoining or adjacent to any parks, reserves, beaches, or foreshore
And as such, Council's Parks, Reserves and Foreshores officers are required to consider the likely impacts of the proposal.

Officer comments

The development application is for the demolition of the existing childcare centre located in Ivanhoe Park, and the installation of interpreting paving and landscape works at the Park Ave entrance to the park, as described and illustrated in the Reports and Plans. A Arboricultural Impact Assessment accompanies the application and is assessed as part of this Landscape Referral.

In review of all relevant plans and reports that provide guidance on the open space recreational character to be provided following demolition of the existing childcare centre, no objections are raised by Parks, Reserves and Foreshores Referral.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Parks, Reserves and Foreshores Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Working and Access on Reserves Permit

Works (undertaken by principal contractors working without Council supervision) on land owned or managed by Council require a "Working on Reserves" permit prior to commencement. Applications can be obtained from Council's website or the Parks and Recreation business unit.

Reason: Public safety and the protection of Council infrastructure.

Installation and Maintenance of Sediment and Erosion Control

Prior to commencement of works on site, sediment and erosion controls must be installed along the immediate downslope of the works area in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). The erosion controls shall be maintained in an operational condition until the development activities have been completed and the site fully stabilised. Sediment shall be removed from the sediment controls following each heavy or prolonged rainfall period. Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities

have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Protection of Council's Public Assets

Any damage to Council's public assets shall be made good by the applicant, and/or the contractor, to the satisfaction of Council.

Council's public assets include, but is not limited to, the following: road, kerb and gutters, crossovers, crossings, paths, grass verge, open space and associated elements such as furniture, recreational facilities and the like, within the meaning of the Local Government Act 1993.

Reason: To protect and/or restore any damaged public asset.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Removal of All Temporary Structures/Materials and Construction Rubbish

Once demolition and any construction has been completed all silt and sediment fences, silt, rubbish, building debris, straw bales and temporary fences/bunds are to be removed from the site.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Occupation Certificate.

Reason: To protect reserve amenity and public safety.