




BLACKETT
MAGUIRE+
GOLDSMITH

26 March 2015



The General Manager
Pittwater Council
PO BOX 882
MONA VALE NSW 1660

Dear Sir / Madam,

**REFERENCE: DA NO. N0191/13 (AS AMENDED)
2 DAYDREAM STREET, WARRIEWOOD NSW 2102
STAGE 3 CONSTRUCTION CERTIFICATE (AMENDED)**

As required by Clause 142(2) of the EP&A Regulation 2000 (the Regulation) notice is hereby given that the following application for Construction Certificate has now been approved.

Applicant: Livpac Developments Pty Ltd
Subject Address: 2 Daydream Street, Warriewood NSW 2102
Date Received: 11 March 2015
Date Determined: 4 June 2015

Please find undercover a copy of the Amended Construction Certificate No. CC-15057/A in relation to the subject development.

This Amended Construction Certificate has been issued for Danpalon and Alucobond wall cladding including revised Fire Safety Engineering Report.

We have also enclosed a copy of the following for Councils record:

- + Application form;
- + Fire Safety Schedule; and
- + Approved documentation and other documentation relied upon as indicated on the Construction Certificate.

Pursuant to Clause 263(2) Environmental Planning and Assessment Regulation 2000, please find enclosed a cheque to the sum of \$36.00 for the submission of this Part 4A Certificate and request that a receipt for which is forwarded to our office.

If we have provided the approved documentation to you electronically on a USB storage device, we would like to advise you that this device is for transmittal purposes only and is not designed for long term storage, please transfer all documentation to a purpose designed form of storage media.

Please contact the undersigned should you have any further enquiries on 02 9211 7777.

Yours Sincerely,

Tony Heaslip
Director
Blackett Maguire + Goldsmith Pty Ltd

\$36

REC: 372315

9/6/15

Address | Suite 2.01,
22-36 Mountain St
Ultimo NSW 2007

Postal | PO Box 167
Broadway NSW 2007
ABN | 18 408 985 851

Contact | Ph: 02 9211 7777
Fax: 02 9211 7774
Email: admin@brmplusg.com.au

CONSTRUCTION CERTIFICATE (AMENDED)

Pursuant to Part 4A of the Environmental Planning & Assessment Act 1979

CERTIFICATE No.:	CC-15057
TYPE:	☒ Building Work
DETERMINATION:	Approved
DATE OF DETERMINATION:	26 March 2015
DATE OF AMENDMENT A:	04 June 2015
SUBJECT LAND:	
Lot & DP	Lot 100 DP 1174851
Address	2 Daydream Street, WARRIEWOOD NSW 2102
LOCAL GOVERNMENT AREA:	Pittwater Council
APPLICANT:	
Name	Mark Livingstone
Company	Livpac Developments Pty Ltd
Address	PO BOX R215 , ROYAL EXCHANGE NSW 1225
Phone / Fax / Email	Phone: 02 8274 0400 Fax: 02 8274 0444 Email: mlivingstone@livgroup.com.au
OWNER:	
Name	Livpac Developments Pty Ltd
Address	PO BOX R215, ROYAL EXCHANGE NSW 1225
Phone / Fax / Email	Phone: 02 8274 0400 Fax: 02 8274 0444 Email: mlivingstone@livgroup.com.au
DESCRIPTION OF DEVELOPMENT:	CC3: Remaining building works (excluding Danpalon and Alucobond wall cladding). <i>Note: This Construction Certificate excludes any external ancillary services, structures or civil works required by relevant authorities.</i>
DESCRIPTION OF AMENDMENT A:	Remaining building works associated with the Stage two development of an industrial and commercial complex including Danpalon and Alucobond wall cladding and associated revised Fire Safety Engineering Report.
BCA CLASSIFICATION:	Class 5, 7a, 7b & 9b
DEVELOPMENT CONSENT:	
Development Application No.	N0191/13 dated 8 October 2013 amended by
Date of Determination	N0191/13/S96/1 dated 15 January 2015
APPROVED PLANS:	As listed in Schedule 1
STATUTORY CERTIFICATION:	
Work completed in accordance with documentation accompanying the application for the certificate (with such modifications verified by the certifying authority as may be shown on that documentation) will comply with the requirements of the Environmental Planning & Assessment Regulation 2000 as are referred to in section 81(A)5 of the Environmental Planning & Assessment Act 1979.	
CONDITIONS:	Refer to Schedule 3
CERTIFYING AUTHORITY DETAILS:	
Certifying Authority	Blackett Maguire + Goldsmith Pty Ltd
Accreditation No.	ABC 4
SIGNATURE:	
SIGNED ON BEHALF OF BM+G:	Tony Heaslip Date: 04/06/2015 Accreditation No. BPB0178



SCHEDULE 1

SCHEDULE OF DOCUMENTATION

+ Architectural Plans prepared by SBA Architects:

DRAWING NUMBER	REV	DATE	DRAWING NUMBER	REV	DATE
GA-100	A	8 August 2014	GA-101	G	20 March 2015
GA-102	M	18 February 2015	GA-110	C	17 March 2015
GA-210	M	18 March 2015	GA-211	Y	20 March 2015
GA-212	S	5 March 2015	GA-213	U	20 March 2015
GA-214	K	6 February 2015	GA-301	B	25 August 2014
GA-305	J	17 March 2015	GA-306	E	12 January 2015
GA-307	D	26 February 2015			

In conjunction with the above plans and specifications the following documentation was relied upon in issuing the Construction Certificate:

+ Other documents relied upon:

ITEM	DOCUMENTATION	PREPARED BY	DATE
1.	CC Application Form	Livpac Developments Pty Ltd	18 July 2014
2.	Staged CC Letter	Livpac Developments Pty Ltd	11 March 2015
3.	Design Compliance Statement	SBA Architects Pty Ltd	11 February 2015
4.	Letter regarding the Water Management Report	Worley Parson Consulting	10 March 2015
5.	Water Management Report - No. 301015-03566 Rev. 2	Worley Parson Consulting	10 March 2015
6.	Certification - Access	ILC Access	6 March 2015
7.	Access Audit Report	ILC Access	6 March 2015
8.	Energy Efficiency Evaluation Report No. 14085145	Partners Energy	26 August 2014
9.	Letter regarding landscaping	FDC Construction & Fitout Pty Ltd	18 March 2015
10.	Email correspondence regarding mezzanine	Appianway	23 March 2015
11.	Water Management Report submission	FDC Construction & Fitout Pty Ltd	11 March 2015
12.	FER Request for Initial Fire Safety Report	Fire & Rescue NSW	Undated
13.	Fire Engineering Report - Report No. 26664700-RPT01-7	Exova Warringtonfire Aus Pty Ltd	19 March 2015
14.	Receipt of lodgement of Notice of Design Change	Fire & Rescue NSW	26 March 2015
Amendment A			
15.	CC Modification Application Form	Livpac Developments Pty Ltd	4 June 2015
16.	Fire Engineering Report - Report No. 26664700-RPT01-8	Exova Warringtonfire Aus Pty Ltd	8 April 2015
17.	Clause 144 Notice of Design Change submission	BM+G	29 May 2015
18.	Clause 144 Notice of Design Change acknowledgement	FRNSW	29 May 2015



SCHEDULE 2

FIRE SAFETY SCHEDULE

Issued under Clause 168 of the Environmental Planning & Assessment Regulation 2000

ADDRESS:	2 Daydream Street, Warriewood
OWNER:	Livpac Developments Pty Ltd
DEVELOPMENT APPLICATION No.:	N0191/13 (as amended)
CONSTRUCTION CERTIFICATE No.:	CC-15057

The following essential fire safety measures shall be implemented in the whole of the building premises and each of the fire safety measures must satisfy the standard of performance listed in the schedule, which, for the purposes of Clause 168 of the Environmental Planning and Assessment Regulation 2000, is deemed to be the current fire safety schedule for the building.

SCHEDULE

Measure	Standard	Compliance	Compliance
Alarm Signalling Equipment	AS1670.3 - 2004	✓	✓
Automatic Fire Detection & Alarm System <i>Tenancy 1 (Amber Technology) & Level 2 of Stage 2 Development</i>	Clause 5 of BCA Specification E2.2a Fire Engineering Report prepared by Exova Warringtonfire, Report No. 2567602- RPT01-2, Revision 2 dated 22/12/2011 Fire Engineering Report prepared by Exova Warringtonfire, Report No. 26664700-RPT01-8, Revision 8 dated 8/04/2015.	✓	✓
Automatic Fire Suppression Systems <i>(Excluding Swim school tenancy)</i>	BCA Spec. E1.5 & AS 2118.1-1999 Fire Engineering Report prepared by Exova Warringtonfire, Report No. 26664700-RPT01-8, Revision 8 dated 8/04/2015.	✓	✓
Building Occupant Warning System activated by the Sprinkler System	Clause 8 of BCA Spec E1.5 & Clause 3.22 of AS 1670.1 - 2004	✓	✓
Emergency Lighting	BCA Clause E4.4 & AS 2293.1 - 2005	✓	✓
Exit Signs	BCA Clauses E4.5, E4.6 & E4.8 and AS 2293.1 - 2005	✓	✓
Fire Blankets	AS 3504 - 1995 & AS 2444 - 2001	✓	✓
Fire Dampers	BCA Clause C3.15, AS 1668.1 - 1998 & AS 1682.1 & 2 - 1990	✓	✓
Fire Doors	BCA Clause C2.12, C2.13, C3.2, C3.4, C3.5, C3.6, C3.7 & C3.8 and AS 1905.1 - 2005	✓	✓
Fire Hose Reels	BCA Clause E1.4 & AS 2441 - 2005	✓	✓
Fire Hydrant Systems	Clause E1.3 & AS 2419.1 - 2005	✓	✓
Fire Seals	BCA Clause C3.15, AS 1530.4 & AS4072.1 - 2005	✓	✓
Lightweight Construction	BCA Clause C1.8 & AS 1530.3 - 1999	✓	✓
Mechanical Air Handling Systems	BCA Clause E2.2, AS/NZS 1668.1 - 1998 & AS 1668.2 - 1991	✓	✓
Paths of Travel	EP & A Regulation Clause 186 and Fire Engineering Report prepared by Exova Warringtonfire, Report No. 26664700- RPT01-8, Revision 8 dated 8/04/2015.	✓	✓
Portable Fire Extinguishers	BCA Clause E1.6 & AS 2444 - 2001	✓	✓
Required Exit Doors (power operated)	BCA Clause D2.19(b)	✓	✓
Warning & Operational signs	Section 183 of the EP&A Regulations 2000, AS 1905.1 - 2005, BCA Clause C3.6, D2.23, E3.3	✓	✓



Fire Engineered Alternative Solution relating to fire resisting construction (allowing reduced FRL's from 4hrs to 2hrs)	BCA Performance Requirements CP1 & CP2 Stage 1: Fire Engineering Report prepared by Exova Warringtonfire, Report No. 2567600-RPT02-3, Revision 3 dated 6/10/2011. Stage 2: Fire Engineering Report prepared by Exova Warringtonfire, Report No. 26664700-RPT01-8, Revision 8 dated 8/04/2015.	✓	✓
Fire Engineered Alternative Solution relating to distances between alternative exits in Tenancy 1 (Amber Technology) comprising 75m in Lieu of 60m – <i>Stage 1 development</i>	Fire Engineering Report prepared by Exova Warringtonfire, Report No. 26664700-RPT01-8, Revision 8 dated 8/04/2015.	✓	
Fire Engineered Alternative Solutions for the Stage 2 Development relating to: - To allow the provision of a 120/120/120 FRL fire walls, floors and columns in lieu of 240/240/240 FRL to the warehouse areas. - To allow drencher protected glazing in lieu of 120/120/120 FRL to the Ground Floor entry lobby of the swim school and Stair 2. - Fire isolation of Fire Stair 2, and separation of rising and descending stairs in fire isolated exits. - Travel distance of up to 65m to an exit within the basement carpark in lieu of 40m. - Travel distance of up to 120m between alternative exits within the car parking basement levels in lieu of 60m. - Travel distance up to 25m to the single exit in lieu of 20m within the warehouse mezzanine. - Travel distance of up to 30m to the single exit in lieu of 20m within the Level 2 office. - Travel distance up to 70m between alternative exits within Tenancy G.3 in lieu of 60m. - Travel distance within the childcare centre on Level 2 of up to 70m between alternative exits in lieu of 60m. - To allow the travel path egress width within the swim school between columns and the pools is 820mm wide, in lieu of 1m. - The non-provision of a sprinkler system to the swim school tenancy. - The use of jet-fans in lieu of a conventional exhaust air system in the basement carpark where the jet-fans do not comply with the requirements and recommendations in clause 5.5 of AS/NZS 1668.1. <i>The provision of Danpalon and Alucobond Plus, which are not considered "non-combustible", to form part of the external walls at various locations.</i>	BCA Performance Requirements CP1, CP2, DP4, DP5, EP1.4 & EP2.2 Fire Engineering Report prepared by Exova Warringtonfire, Report No. 26664700-RPT01-8, Revision 8 dated 8/04/2015.		✓



SCHEDULE 3

CONDITIONS OF CONSTRUCTION CERTIFICATE

There are no conditions pursuant to clause/s 144, 187 & 188 of the Environmental Planning & Assessment Regulation 2000 at the date of issue of this Construction Certificate.

CONSTRUCTION
CERTIFICATE (MODIFICATION)
APPLICATION



BLACKETT
MAGUIRE+
GOLDSMITH

Information for the Applicant

- A construction certificate has no effect if it is issued after the building work or subdivision work to which it relates is physically commenced on the land to which the relevant development consent applies.

APPLICANT

Note - This must be the person having the Benefit of the Development Consent. Cannot be the builder unless the builder is the owner of the property.

Company

ABN (if applicable)

Livpac Developments Pty Ltd

65 122 395 091

Applicant Name

Mark Livingstone

Applicant Postal Address

Level 8, 151 Macquarie Street, Sydney

Phone

Fax

Mobile

8274 0400

8274 0444

Email

Signature

x

Date:

4 JUNE 2015

SUBJECT LAND

Location and title details of the land where the building work or subdivision work is to be carried out.

Unit / Street No

Street Name

2

Daydream Street

Suburb / Town

State

Postcode

Warrimood

NSW

2102

Lot No.

DP / SP No.

100

DP 1174851

PROPOSED DEVELOPMENT

Briefly describe the development including modifications to original CC.

Modified Description

Addition of revised fire engineering report to cover of the use of Alucobond and Danpalon cladding to the building

CC to be Modified

Existing BCA Classification

Proposed BCA Classification

CC-15057

5, 7a, 7b & 9b

5, 7a, 7b & 9b

Estimated Cost of Works including modifications (incl GST)

\$13.7million

The estimated cost of works is the contract price, or if there is no contract a genuine and accurate estimate, for all labour and material costs associated with all demolition and construction required for the development, including the cost of construction of any building and the preparation of the building for the purpose for which it is to be used (such as the costs of installing plant, fittings, fixtures and equipment). GST is also to be included.

OFFICE USE - RECEIPT OF APPLICATION

This Modification to Construction Certificate Application was received by Blackett Maguire + Goldsmith on:

(Please stamp 'Received' stamp or write date received in the space provided).

Date Received:

Received

04-Jun-15

Blackett Maguire + Goldsmith

Address

Suite 2.01,
22-36 Mountain St
Ultimo NSW 2007

Postal

PO Box 167
Broadway NSW 2007
ABN 18 408 985 861

Contact

Ph: 02 9211 7777
Fax: 02 9211 7774
Email: admin@amplusg.com.au



DEVELOPMENT CONSENT

Development Consent No.

N0191/13/S95/1

Date of Determination

15/01/15

Consent Authority

Pittwater council

DA Applicant Name

Mark Livingstone

Has a Section 82a review of determination been submitted to Council?

☐ Yes

☒ No

Does the development relate to building work or subdivision?

☒ Building Work

☐ Subdivision

Does the application relate to a residential flat development which was required, under Clause 50(1A) of the EP&A Regulation, to be accompanied by a design verification from a qualified designer?

☐ Yes

☒ No

If yes, please provide a statement from a qualified designer which verifies that the plans and specifications achieve or improve the design quality of the development for which development consent was granted, having regard to the design quality principles set out in Part 2 of State Environmental Planning Policy No.65: Design Quality of Residential Flat Development (SEPP 65).

CONSENT OF OWNERS - Authority to enter and inspect Land

A certificate of consent to enter and inspect land is required for development that involves the construction of a building or the carrying out of works on land that is subject to a development consent. The certificate must be obtained from the owner of the land or the person in possession of the land.

OWNERS DETAILS

Company / Full Name **Livpac Developments Pty Ltd**

ABN (if applicable) **65 122 395 091**

Postal Address **PO Box R215, Royal Exchange NSW 1225**

Phone **8274 0400**

Fax **8274 0444**

Mobile

Email

DELIVERY OF THE APPLICATION

Applications for construction certificates must be delivered to the principal office of Blackett Maguire + Goldsmith by one of the following methods:

- + By hand;
- + By post; or
- + Transmitted electronically.

Applications MAY NOT be sent by fax.

REQUIRED DOCUMENTATION

Please refer to the CC Requirements list issued separately for all documentation required to be forwarded to our office to support this application and facilitate the approval of the Construction Certificate.



FIRE ENGINEERING REPORT

Perthula Business Estate - Stage 2
2 Daydream Street
Wentworth NSW 2102

Report Number: 2044770-20770-8
Date: 6th April, 2015

Client:
PDC Construction and Fibrot Pty Ltd
22-24 Junction Street
Forest Lodge NSW 2007

Testing, Advising, Assuring.

AUTHORISATION

No.	Comment / Reason for Issue	Issue Date	Prepared By	Reviewed By
8	Reviewed report based on additional alternative solution relating to the provision of Alucobond and Dargapon at various locations of the external walls.	8/4/2015		

REVISION HISTORY

No.	Comment / Reason for Issue	Issue Date	Prepared By	Reviewed By
1	Initial Issue	28/06/2014	Vinh Dang	James Dominguez
2	Reviewed report based on stakeholder comments.	22/09/2014	Vinh Dang	James Dominguez
3	Reviewed report based on minor comments.	28/09/2014	Vinh Dang	James Dominguez
4	Reviewed report based on additional alternative solutions relating to fire separation of openings in external walls and system used to satisfy the smoke management provisions, arising from the provision of sprinklers to the swim school.	21/12/2014	Vinh Dang	James Dominguez
5	Reviewed report based on additional alternative solutions relating to the provision of jet fans within Basement	20/02/2015	Vinh Dang	Simon Kathleen
6	Reviewed report based on additional alternative solutions relating to exit widths within the swim school and provision of demarcator protected glazing to Stair 1.	18/03/2015	Vinh Dang	Simon Kathleen
7	Reviewed report reflecting updated floor plans and based on comments provided by stakeholders.	19/03/2015	Vinh Dang	Simon Kathleen

For and on behalf of Exova Warringtonfire Aus Pty Ltd.



Report No. 2044770-20770-8
Page 8 of 170

CONDITIONS OF USE

© Copyright Exova Warringtonfire Aus Pty Ltd 2015

The report addressee may only reproduce this report in full for use with respect to the project specified in the report. No organisations or individuals are permitted to reproduce this report or any part thereof for any other purposes without the prior written consent of a Director of Exova Warringtonfire Aus Pty Ltd.

The copyright and intellectual property rights of Exova Warringtonfire Aus Pty Ltd extend to the data, ideas, methodologies, calculation procedures, and conclusions presented in the report and must not be used without authorisation in writing from Exova Warringtonfire Aus Pty Ltd. The report is subject to change and no liability will be accepted in relation to any loss resulting from use of the report pending approval from the authority having jurisdiction.

CONTACT INFORMATION

Exova Warringtonfire Aus Pty Ltd
Victoria
Unit 2, 409-411 Hamstead Road
Dandenong VIC3175
Australia
T: +61 (0)3 9767 1000
F: +61 (0)3 9767 1001

New South Wales
Suite 202A, Level 20, 44 Market Street
Sydney NSW 2000
Australia
T: +61 (0)2 8270 7800
F: +61 (0)2 8289 6076

Queensland
Northport, Unit 12, Level 5
231 North Quay
Brisbane QLD 4000
Australia
W: info@exova.com.au
E: info@exova.com.au
T: +61 (0)7 3228 1700
F: +61 (0)7 3221 4633

Report No. 2044770-20770-8
Page 8 of 170

OVERVIEW

Exova Warringtonfire Aus Pty Ltd has been engaged by PDC Construction and Fibrot Pty Ltd for professional fire engineering services to formulate a fire safety design solution against stakeholder-agreed fire safety objectives defined in the Fire Engineering Brief process. This is in relation to the following matters involving the Perthula Business Estate - Stage 2 development at 2 Daydream Street, Wentworth NSW 2102:

- verification to fire resistance levels of the warehouse areas
- verification to fire resisting construction to entry lobby of swim school and Stair 2 on Ground Floor and verification to openings in fire isolated stairways for Stair 1 on Ground Floor, Level 1 and Level 2.
- The provision of Dargapon and Alucobond Fira, which are not considered "non-combustible", to form part of the external walls
- non-provision of fire-isolated stairways and separate rising and descending stair flights
- exit travel distances to carpark
- distances between alternative exits within carpark
- exit travel distances to warehouse mezzanine
- exit travel distances to Level 2 office
- distances between alternative exits within warehouse
- distances between alternative exits within child-care centre
- Travel path egress width within swim school
- verification to fire resisting construction to the roof, vertical separation of openings in external walls and system used to satisfy the smoke management provisions, arising from the non-provision of sprinklers to the swim school.

- provision of jet fans to the basement carpark in lieu of an air exhaust system.
- A Fire Engineering Brief (FEB) was prepared and agreed upon by the relevant stakeholders and Authorities Having Jurisdiction. This was conducted generally as described in the International Fire Engineering Guidelines 2005 and documented in Fire Engineering Brief FEB0 Wentworth Stage 2 1 dated 7/06/2014. Comments and recommendations arising from this Brief have been incorporated into this Fire Engineering Report.
- The Fire Engineering Brief process involved the collaborative development and agreement of an appropriate methodology, structure and trial design concept(s) by all the relevant stakeholders and formed the basis for the detailed safety analyses and design presented in this Fire Engineering Report.
- It is the responsibility of the client to verify that the fire safety design strategy in this report is implemented as part of the design documentation and construction stages for this project.
- The recommendations of this fire engineering report are presented in section 6 "Fire Safety Design" and section 7.4 "Standards of Construction, Commissioning, Management and Maintenance".

This report is not a compliance certificate in accordance with clause 14.4A of the Environmental Planning & Assessment Regulation 2000.



CONTENTS

1	Introduction.....	9
1.1	Project.....	9
1.2	Client.....	9
1.3	Project Address.....	9
1.4	Description of Work.....	9
1.5	Scope and Limits of Report.....	9
1.6	Regulatory Framework.....	9
1.7	Information Considered for Fire Engineering Report.....	10
1.8	Legislative Requirements.....	10
1.9	Fire Engineering Brief Stakeholders.....	11
PART A – FIRE ENGINEERING BRIEF		12
2	Principal Building Characteristics.....	13
2.1	Location.....	13
2.2	Building Size and Shape.....	14
2.3	Function or Use of the Building.....	14
2.4	BCA Deemed-to-Satisfy Provision Reference Criteria.....	14
2.5	Structure.....	15
3	Dominant Occupant Characteristics.....	16
3.1	Occupant Groups.....	16
3.2	Distribution.....	16
3.3	State.....	16
3.4	Physical Attributes.....	16
3.5	Mental Attributes.....	17
3.6	Group Roles.....	17
3.7	Emergency Response Training & Roles During an Emergency Incident.....	17
3.8	Familiarity with Building.....	17
3.9	Level of Assistance Required & Available.....	17
4	Fire Safety Design Objectives.....	18
4.1	Client Objectives.....	18
4.2	Loss Control Objectives.....	18
4.3	Regulatory Objectives.....	18
4.4	Fire Brigade Objectives.....	18
5	BCA Analysis Information.....	20
6	Hazards.....	25
6.1	General Building Layout.....	25
6.2	Activities.....	25
6.3	Ignition Sources.....	26
6.4	Fuel Sources.....	27
6.5	Interactions Between Ignition and Fuel Sources.....	28
6.6	Unusual Features.....	28
6.7	Hazards Summary.....	28
6.8	Preventative and Protective Measures.....	29
7	Threat Concept Fire Safety Strategy.....	32
7.1	Construction, Fire Resistance & Compartmentation.....	32
7.2	Egress.....	36
7.3	Fire Services & Equipment.....	36

8	7.4 Standards of Construction, Commissioning, Management and Maintenance.....	39
8.1	Proposed Approach and Method of Analysis.....	42
8.2	General.....	42
8.3	Analysis Strategy.....	42
8.4	Sensitivity Studies.....	50
9	Acceptance Criteria.....	51
9.1	Judgement of Acceptance Criteria.....	52
9.2	Acceptance Criteria for the Analysis.....	52
9.3	Environmental and Loss Control Acceptance Criteria.....	54
10	Fire Scenarios, Occupant Egress Scenarios and Analysis Scenarios.....	56
10.1	General Overview of Fire.....	56
10.2	Sprinkler Reliability and Performance.....	56
10.3	Proposed Fire Scenarios.....	60
10.4	Discounted Fire Scenarios.....	60
10.5	Aven.....	60
PART B – FIRE ENGINEERING ANALYSIS		62
11	Alternative Solution 1 – Fire resisting construction to Warehouse Areas.....	63
11.1	Assessment Criteria.....	63
11.2	Fire Engineering Assessment.....	64
11.3	Summary.....	68
12	Alternative Solution 2 – Drencher-Protected Glazed Wall Assemblies and Openings in Fire Isolated Exits.....	69
12.1	Assessment Criteria.....	69
12.2	Fire Engineering Assessment.....	70
12.3	Summary.....	75
13	Alternative Solution 3 – External Wall Lining.....	76
13.1	Assessment Criteria.....	76
13.2	Fire Engineering Assessment.....	77
13.3	Summary.....	80
14	Alternative Solution 4 – Non-Provision of Fire-Isolated Stairways and Separate Risling and Descending Stair Flights.....	81
14.1	Assessment Criteria.....	81
14.2	Fire Engineering Assessment.....	82
14.3	Summary.....	85
15	Alternative Solution 5 – Exit Travel Distances and distance between Alternative Exits (Carpark).....	86
15.1	Assessment Criteria.....	86
15.2	Fire Engineering Assessment.....	87
15.3	Summary.....	92
16	Alternative Solution 6 – Exit Travel Distances to a Single Exit (Tenancy G3 Mezzanine).....	93
16.1	Assessment Criteria.....	93
16.2	Fire Engineering Assessment.....	94
16.3	Summary.....	97
17	Alternative Solution 7 – Exit Travel Distances to a Single Exit (Level 2 Office).....	98
17.1	Assessment Criteria.....	98
17.2	Fire Engineering Assessment.....	99
17.3	Summary.....	103

18	Alternative Solution 8 – Travel Distances Between Alternative Exits (Tenancy G3).....	104
18.1	Assessment Criteria.....	104
18.2	Fire Engineering Assessment.....	105
18.3	Summary.....	107
19	Alternative Solution 9 – Distances Between Alternative Exits (Child Care Centre).....	108
19.1	Assessment Criteria.....	108
19.2	Fire Engineering Assessment.....	109
19.3	Summary.....	112
20	Alternative Solution 10 – Exit width within Swiss School.....	113
20.1	Assessment Criteria.....	113
20.2	Fire Engineering Assessment.....	113
20.3	Summary.....	116
21	Alternative Solution 11 – Fire Resistance Level to Roof, Spandrel Separation and Smoke Hazard Management.....	118
21.1	Assessment Criteria.....	118
21.2	Fire Engineering Assessment.....	119
21.3	Summary.....	124
22	Alternative Solution 12 – Provision of Jet-Fire within Basement Carpark Level.....	126
22.1	Assessment Criteria.....	126
22.2	Fire Safety Assessment.....	127
22.3	Summary.....	131
23	Analysis Against BCA Performance Requirements.....	132
23.1	Methodology.....	132
23.2	Structural Stability.....	132
23.3	Fire Spread.....	133
23.4	Number, Dimensions and Distribution of Exits.....	134
23.5	Fire-Isolation of Exits.....	134
23.6	Fire Suppression System.....	135
23.7	Smoke Hazard Management.....	135
24	Conclusion.....	137
24.1	General.....	137
24.2	Recommended Fire Safety Design Strategy.....	137
24.3	Construction & Commissioning Requirements.....	137
24.4	Engineering Judgement.....	137
24.5	Expert Judgement.....	137
25	Validity / Decision.....	138
APPENDIX A	EVACUATION CALCULATIONS.....	139
APPENDIX B	WAREHOUSE TENANCY FIRE MODELLING.....	149
APPENDIX C	FIRE BRIGADE INTERVENTION MODEL.....	162
APPENDIX D	CFD MODELLING FOR JETTAN ALTERNATIVE SOLUTION.....	168
APPENDIX E	BASMENT CARPARK SPRINKLER ACTIVATION SLICE FILES.....	164
APPENDIX F	JET FAN SPECIFICATION.....	167
APPENDIX G	ALUCOBOND CERTIFICATE OF CONFORMITY.....	168

APPENDIX H	ALUCOBOND TEST REPORT EXCERPT.....	169
-------------------	---	------------

1 INTRODUCTION

1.1 Product

The proposed development relates to the Stage 2 extension to the Parkville Business Estate.

1.2 Client

FDC Construction and Fitout Pty Ltd, 22-24 Junction Street, Forest Lodge NSW 2037.

1.3 Product Address

2 Drydenham Street, Wentwood NSW 2102.

1.4 Description of Work

Exova Warringtonfire Aus Pty Ltd (Exova) has been engaged to facilitate a performance-based design approach in formulating a fire safety strategy that satisfies stakeholder objectives as they relate to the Parkville Business Estate - Stage 2 works.

This report presents the formulation of a fire safety design solution and includes analysis of the fire safety design against stakeholder-agreed fire safety objectives, as developed in the Fire Engineering Brief process.

1.5 Scope and Limits of Report

Tony Heslop, of Blackett Maguire + Goddard Pty Ltd, is the Authority Having Jurisdiction for the purposes of considering an application for a construction certificate relating to building and construction work in the State of New South Wales. The relevant authority may also be identified during the application, the matters described in the Fire Engineering Brief were identified during the Fire Engineering Brief process as varying from deemed-to-safety provisions of the Building Code of Australia.

The client has requested that these issues be addressed in accordance with appropriate methodologies and procedures agreed upon during the Fire Engineering Brief process. This Fire Engineering Report includes an opinion of the fire safety design against regulatory objectives set out in the Fire Engineering Brief that the relevant authority may also take into consideration in their approval of the construction certificate for the subject building and construction work in accordance with the relevant statutory provisions.

The analysis does not specifically consider arson (other than as a source of initial ignition), multiple simultaneous ignition sources, acts of terrorism, protection of property (other than adjoining property), business interruption or losses, or personal or moral obligations of the owner/occupier.

Exova has developed a fire safety strategy for this building taking note of our duty as designers of workplaces under the relevant workplace safety legislation. Other provisions documenting these designs may also have a duty under such legislation which they must discharge in preparing their designs.

The report is limited to the fire safety provisions of the Building Code of Australia (Sections C, D and E) and does not consider seismic or non-fire health issues in the building.

This report is not a compliance certificate in accordance with clause 144A of the Environmental Planning & Assessment (EPA) Regulation 2000.

It should be noted that it is not possible to totally eradicate the risk from fire in, or from, a building.

Regulatory Framework

The following legislation has been considered in the formulation of this fire engineering report:

1. NSW Environmental Planning and Assessment Act, 1979;
2. NSW Environmental Planning and Assessment Regulation, 2000;
3. Building Code of Australia 2014, Australian Building Codes Board, 2014.



1.7 INFORMATION CONSIDERED FOR FIRE ENGINEERING REPORT

The following information has been considered in the formulation of this fire engineering report:

1. Email received from Blackett Maguire + Goddard Pty Ltd, describing the extent of BCA non-compliance relating to the provision of the external wall integrity, dated 20th March 2015;
2. Email received from FDC Construction & Fitout Pty Ltd requesting an additional alternative solution relating to the provision of enclosure-protected glass doors in lieu of fire doors to the fire-activated Stair 1, dated 10th March 2015;
3. Email received from FDC Construction & Fitout Pty Ltd requesting an additional alternative solution relating to the variation to exit width to the swim school, 10th March 2015;
4. Email received from FDC requesting Alternative Solution relating to the provision of liftwells to Basement Carpark, dated 10 November 2014;
5. Revised BCA Reference Report, prepared by Blackett Maguire + Goddard Pty Ltd, dated 20 October 2014;
6. N.B. BCA Report incorporates additional matters to be subject to fire engineering advice from the non-provision of liftwells to the swim school;
7. Fire Engineering Brief Questionnaire document, prepared by Exova Warringtonfire (Aus) Pty Ltd FEBO Wentwood Stage 2, dated 7/6/2014;
8. BCA Reference Report, prepared by Blackett Maguire + Goddard Pty Ltd, dated 7 July 2014. N.B. It has been advised that an Alternative Solution for the roof area passing through enclosure protected doors is not required.

Architectural drawings prepared by SBA Architects Pty Ltd (Project Number 14174), as listed in Table 1.1:

Reference	Title	Revision	Date
GA-107	Site Plan - Overall	D	18 February 2014
GA-108	Site Plan - Stage 2 works	B	18 February 2015
GA-110	Fire Constraints Stages 1 & 2	C	17 March 2015
GA-110	Basement Plan	M	18 March 2015
GA-111	Ground Floor Plan	X	18 March 2015
GA-112	Level 1 Floor Plan	C	June 2014
GA-113	Level 2 Floor Plan	F	17 March 2015
GA-114	Roof Plan - Layout	C	June 2014
20356-M101	Basement Layout - Mechanical Services	B	November 2014
20356-M102	Duct and Equipment Layout - 1 of 2	B	November 2014
GA-240	Pen Level 2 Office/Come Centre	E	16 March 2015

1.8

Limitative Requirements

For the proposed development works, compliance with the BCA is mandated by the Environmental Planning & Assessment Regulation 2000. As noted within the referenced BCA assessment report, the relevant BCA edition for this project is 2014.

Pursuant to BCA clause A0.4, a building solution will comply with the BCA if it satisfies the performance requirements, which can only be achieved through one of the methods listed in clause A0.5, being as follows:

- (a) complying with the Deemed-to-Safety Provisions; or
- (b) formulating an Alternative Solution which—
 - (i) complies with the Performance Requirements; or
 - (ii) is shown to be at least equivalent to the Deemed-to-Safety Provisions; or
 - (c) a combination of (a) and (b).

The proposed method of BCA compliance for the subject development is A0.5(c), compiling a combination of prescriptive-based and performance-based design. For the performance-based



PART A – FIRE ENGINEERING BRIEF

component of the design the subject of this report, the proposed methods of compliance to be used for each alternative solution are listed in Table 5.1.

For the assessment of alternative solutions, BCA clause A0.9 stipulates that assessment must be undertaken in accordance with one or more of the methods outlined in clause A0.9. With BCA compliance only being achieved where the assessment methods have been satisfied. The various assessment methods listed in clause A0.9 are:

- (a) Evidence to support that the use of a material, form of construction or design meets a Performance Requirement or a Deemed-to-Safety Provision as described in A0.2;
- (b) Evidence to support that the use of a material, form of construction or design meets a Performance Requirement or a Deemed-to-Safety Provision as described in A0.2;
- (c) The Verification Methods in the BCA; or
- (d) such other Verification Methods as the appropriate authority accepts for determining compliance with the Performance Requirements;
- (e) Expert Judgement;
- (f) Expert Judgement.

The proposed assessment methods to be used for each alternative solution are listed in Table 5.1.

1.9

Fire Engineering Brief Stakeholders

The persons listed in Table 1.2 were involved in the development and agreement of the Fire Engineering Brief.

Table 1.2 – Project stakeholders

Name	Organisation	Role
Joel Andropoulos	FDC Construction and Fitout Pty Ltd Blackett Maguire + Goddard Pty Ltd	Client / project manager / developer representative
Tony Heslop	Ltd	Authority having jurisdiction
Team leader of alternative solutions	Fire and Rescue NSW	Statutory review agency
Vin Diang	Exova Warringtonfire Aus Pty Ltd	Fire safety engineer
James Dominguez		
Simon Kristman		



2 PRINCIPAL BUILDING CHARACTERISTICS

2.1 LOCATION

2.1.1 General Site Description

The subject development is located at Warriewood, approximately 26 km north of Sydney's central business district.

As shown in Table 2.1, this project relates to the proposed Stage 2 extension of a three-storey commercial/industrial building at Warriewood. The subject building will be bounded by roadways to the north and east. Neighbouring property is located to the south and undeveloped land to the west. Pedestrian access will be provided via Daydream Street on the east side of the complex. Vehicular access will be provided via Daydream Street described above.




Figure 2.1 – Indicative site location¹

2.1.2 Proximity to Boundaries and Buildings

The subject development is bounded by Mona Vale Road to the north, Daydream Street to the east, a neighbouring property to the south and undeveloped land to the west.

2.1.3 Proximity to Hazards

There are no significant hazards known near the subject building such as electrical, dangerous goods storage or hazardous structures etc.

2.1.4 Proximity to Buildings of High Importance

The subject building is not situated next to any buildings that are of high importance such as disaster recovery facilities (i.e. emergency and health-care facilities).

2.1.5 Fire Brigade Access and Locations

Fire brigade access into the building is available from the bounding roadway on the eastern side of the building.

The proximity of fire stations available to provide a response to the site are given in Table 1. This is the nearest fire station (Warriewood Fire Station) located approximately 1.5 km from the site. The site is also within the fire service area of the Warriewood Fire Station (Warriewood Fire Station) and the location of the two closest fire stations to the development².

1. Map data courtesy of Google Maps (www.maps.google.com), dated 13/06/14

2. Fire and Rescue NSW, FIRENSIS Abridged Alarm Response Protocol, Sydney, NSW, Fire and Rescue NSW, 2012.

3. Fire and Rescue NSW, Contact Details, website link.

Table 2.1 – Location of responding fire stations near subject development

Fire station	Location (road distance)	Staffing
Mona Vale Fire Station	Mona Vale, NSW, is a travel distance of approximately 2.3 km from the building.	Permanent
Narrabeen Fire Station	Narrabeen, NSW, is a travel distance of approximately 6.6 km from the building.	Permanent

These stations are manned by full time crews.

2.2 BUILDING SIZE AND SHAPE

The proposed building consists of basement carparking, a swim school and a single-storey warehouse containing a mezzanine to Ground Floor, office to Level 1 and offices and a child care centre to Level 2. The building contains largely a rectangular footprint.

Stage 2 comprises a total floor area of 13,570 m² and a height of less than 12 metres.

The extension features pedestrian access to two lobby areas and serviced by three lift cores.

2.3 FUNCTION ON USE OF THE BUILDING

The building features a mixture of uses including Class 5 (office), class 7a (carpark) and Class 7b (warehouse) and Class 8a (swim school and childcare centre). Level 1 will be used for office accommodation, whilst the ground floor will be utilised as warehouse, office and undercroft carpark areas. The ground floor will feature the main pedestrian access to the different parts of the building.

2.4 BCA CLASSIFICATION

Table 2.2 below outlines key classification criteria in accordance with the Building Code of Australia 2014 in relation to the building, as advised by Blackett Maguire + Goldsmith Pty Ltd.

Table 2.2 - BCA deemed-to-satisfy provision reference criteria

BCA clause	Description of requirement
A1.1 Effective height	Less than 12 m The building has the following classification: • Class 5 (office) • Class 7a (carpark) • Class 7b (warehouse) • Class 8a (swim school / childcare centre)
A3.2 Occupancy classification	Class 5 (office) Class 7a (carpark) Class 7b (warehouse) Class 8a (swim school / childcare centre)
G1.1 Minimum type of construction	Type A construction is applicable.
G1.2 Risk in stories	The building has a risk in stories of three.
G2.2 Fire compartment floor area and volume	The limitations of Table G2.2 for Class 5 and Class 8a occupancies are 6,000 m ² and 48,000 m ³ for Type A construction. The limitations of Table G2.2 for Class 7a and Class 7b occupancies are 5,000 m ² and 30,000 m ³ for Type A construction. The fire compartment area and volumes have not been exceeded.
G2.3 Large isolated building	Not applicable.

2.5 STRUCTURE

2.5.1 Structural Characteristics

The proposed extension will feature the following structural characteristics:

- Floors: Reinforced concrete floor slabs.
- Vertical structure: load-bearing structure comprising masonry construction; and internal office walls consisting of steel stud-framed construction with plasterboard.
- Roof: Metal roof sheeting.

2.5.2 Coverings and Linings

All building materials and linings will comply with the fire hazard property provisions of Part G1 of the BCA and are expected to consist of a range of materials, such as painted plasterboard, architectural/terrazzo, ceramic/porcelain tiling, carpet, timber flooring and other potentially combustible linings.

2.5.3 Openings, Shafts and Voids

This development does not feature any unusual shafts or voids within the building design. The warehouse tenancy is full height.

2.5.4 Ventilation and Air Movement

The building will be provided with ventilation and air movement in accordance with BCA Deemed-to-Satisfy provisions, including car park areas being provided with mechanical ventilation.

3 DOMINANT OCCUPANT CHARACTERISTICS

3.1 Occupant Groups

Occupant characteristics and their interaction with their environment are of equal importance as the characteristics of the building.

Occupants within the development generally comprise the following distinct groups:

- Staff members
- Maintenance / cleaning staff
- Visitors

Measures to manage any evacuation procedures and training will be considered as part of the fire engineering analysis.

3.2 Demographic

Considering the proposed use being for storage, and office accommodation, the occupants are expected to be located within these areas of the facility the majority of the time and only occasionally within the car park. They will be reasonably well-distributed across the building.

The occupant number to be considered in the fire engineering assessment is based on the floor areas within the building and Clause D1.13 of the BCA, as shown in Table 3.1 below.

Section of Building	Population provided by Blackett Maguire + Goldsmith	Population based on BCA Clause D1.13
Basement	-	-100 people
Tenancy G2 (swim school)	-	-20 people
Tenancy G3 (warehouse)	-	-20 people
Tenancy G3 (warehouse)	-	-20 people
Office	-	-122 people
Tenancy G3 (warehouse mezzanine)	-	-10 people
Tenancy 1 (office)	-	-48 people
Tenancy 2 (office)	-	-48 people
Childcare centre	-	-100 people

3.3 Staff

Staff members are expected to be awake and conscious of their surroundings, be generally familiar with building layout and, for selected staff members, have emergency response training and the ability to provide assistance to children and visitors during an emergency evacuation.

Children may be preoccupied with activities at the time of an incident. They are expected to be less responsive to indirect detection cues associated with fire and may rely to some degree on trained staff members for initiation of an orderly evacuation.

With the exception of the swim school, it is expected that visitors would be low in number and are awake, conscious of their surroundings and be generally familiar with building layout.

3.4 Physical Attributes

Occupants within the warehouse area are more likely to be able-bodied, based on the physical nature of activities associated with industrial-based work.

Members of staff are expected to be mobile and have normal hearing and visual abilities and are generally expected to be capable of hearing emergency evacuation warning alarms and evacuating without assistance (and being capable of assisting children as part of a managed evacuation process in the warehouse where nominated).

Infants and children will not have the same physical ability and mobility as adults and, therefore, may require physical guidance and assistance during an emergency evacuation.

Cleaners and maintenance personnel are expected to be mobile and have normal hearing and visual abilities, as would be expected for those working in such a capacity.

MENTAL ATTRIBUTES

Staff are expected to have an understanding of the need to respond in an organised manner in the event of an emergency in the building, based on ongoing evacuation training procedures. Infants and young children are not expected to understand how to respond appropriately, in the case to make the required decisions and will therefore rely heavily on any adults present for guidance.

Visitors are not expected to be familiar with the building layout nor the locations of the exits.

For occupants located within close proximity of a fire, fire detection is expected to initially occur as a result of receipt of a clear visual cue, where occupants are prompted to evacuate prior to the activation of the detection system. Conversely, for a fire occurring at a more remote point, where occupants may not be made aware of the fire for some time, the detection is expected to initially occur as a result of receipt of an automatic cue from the occupant warning system, initiated by the smoke detection system.

Group Risks

Staff and children within the child care area and staff from the other tenancies will have particular group risks with each other. Visitors may not be trained. It is likely that such occupants will attempt to support others during the evacuation process (although this is a more likely action to be taken by tenants, with males more likely to attempt first-aid fire-fighting) by alerting them to the threat of a fire and assisting them where it is felt safe to do so.

Emergency Response Team as Focus Group as an Emergency Incident

Although members of the public are not expected to have any emergency response training, selected staff members are expected to be suitably trained in emergency management procedures, in accordance with the principles of AS 3745-2010. It is therefore considered that trained staff will have an understanding of the processes involved, will be aware of emergency procedures specific to the alarm or hazard and will be relatively familiar with the building layout. Furthermore, due to their age, familiarity with the building may not be a significant contributing factor in their ability to evacuate without assistance. Visitors may not be aware of the exit locations nor have a comprehensive understanding of the building layout.

Facilities with Bunkers

For staff members, medium to long-term occupation is generally anticipated. They are expected to be familiar with their surroundings and the building layout in general, including the exit pathways from each floor.

Children may be familiar with parts of the building they are situated in or areas they frequent. However, they may not be aware of the exit locations nor have a comprehensive understanding of the building layout. Furthermore, due to their age, familiarity with the building may not be a significant contributing factor in their ability to evacuate without assistance.

Visitors may not be aware of the exit locations nor have a comprehensive understanding of the building layout.

Letters, or Assessment Procedures & Alarms

The lifts within the building are not intended to be used in addition to the required exits to assist occupants to evacuate the building safely.

Escape for people with disabilities within the building should be addressed via the implementation of an emergency evacuation plan for all occupants, including people with disabilities, in accordance with AS 3745-2010. This may include specific evacuation strategies for people with disabilities including assistance, use of evacuation means of communication, emergency information and warnings to people with disabilities, and the subsequent timing of staff.

Other brigade responsibilities that may be contained within their statutory act or other objectives are beyond the scope of this report.

General fire brigade objectives are addressed in the relevant performance clauses under fire brigade intervention. Other Brigades responsibilities that may be contained within their Statutory Act or other objectives are beyond the scope of this report.

FIRE SAFETY DESIGN OBJECTIVES

Client Objectives

The Client has not indicated any additional fire safety objectives to that required by the relevant statutory requirements, as described in the BCA. Therefore, asset protection and community impact of the fire excluded from the analysis outcome.

Loss Control Objectives

Consideration of specific issues such as property and asset protection, business interruption, and the impact of fire on the community, as described in the BCA, is not included in the analysis outcome, and are therefore beyond the scope of this report, as identified in Section 1.5. While, as soon as a single point of ignition may be considered in the analysis, simultaneously multiple fire events are not considered, although the production systems or inventory are not included as part of the report scope. It should, however, be noted that due to the client's request to develop alternative solutions for the project, fire and smoke damage may vary when compared to a building design that complies with the BCA DTS provisions. The building has not been identified during the Fire Engineering Brief process as a likely target for terrorism.

It is recommended that the building owner/operator liaise with its relevant insurers on this matter.

Regulatory Objectives

To meet the regulatory requirements, the design is to be in accordance with the Building Code of Australia 2014. Compliance with the fire safety objectives in the BCA is achieved by satisfying the relevant BCA performance requirements, as determined by the authorities having jurisdiction. The general objectives for the fire safety assessment outlined herein are consistent with those set out within Sections C and D Part E1 and Part E2 of the Building Code of Australia, of which the analysis specifically relates to, being as follows:

Section C objectives C01:

The Objective of this Section is to:

- (a) safeguard occupants from fires or injury due to a fire in the building; and
- (b) facilitate the activities of emergency services personnel; and
- (c) avoid the spread of fire between buildings; and
- (d) protect other property from physical damage caused by structural failure of a building as a result of fire.

Section D objectives D01:

The Objective of this Section is to:

- (a) ...N/A (locus-related)
- (b) safeguard occupants from fires or injury while evacuating in an emergency.

Part E1 objectives E01:

The Objective of this Part is to:

- (a) safeguard occupants from fires or injury while evacuating during a fire; and
- (b) provide facilities for occupants and the fire brigade to undertake the fighting operations; and
- (c) prevent the spread of fire between buildings.

Part E2 objectives E02

The Objective of this Part is to:

- (a) safeguard occupants from fires by warning them of a fire so that they may safely evacuate; and
- (b) safeguard occupants from fires or injury while evacuating during a fire.

Fire Evacuation Objectives

General fire brigade objectives are addressed in the relevant performance clauses under fire brigade intervention. The fire brigade objective throughout Australia is to protect human life and property.

BCA ANALYSIS INFORMATION

The variations from the DTS provisions of the BCA, as advised by Blackett Maguire + Goldsmith Pty Ltd, are to form the basis of the fire engineering analysis and are the subject of the proposed alternative solutions. The proposed alternative solutions are described in Table 5.1 below, along with details of the relevant BCA performance requirements and BCA assessment methods. The relevant performance requirements have been identified in conjunction with Blackett Maguire + Goldsmith Pty Ltd and in accordance with BCA clause A0.10. The latter requiring consideration of any relevant performance requirement from parts of the BCA other than those where the DTS variation is to be found.

All other items of fire and life safety are to be provided in compliance with the DTS provisions of the BCA.

Table 5.1 – Summary of BCA DTS provision departures and proposed alternative solutions		
BCA Specification	Proposed alternative solution	
BCA Specification C1.1 stipulates that building elements are to have fire resistance ratings as set out in accordance with Table 5.1 of Specification C1.1, being, for the subject development, 240/240/240 FRL to the warehouse areas, 120/120/120 FRL to the office areas and 120/120/120 FRL to the sprinkler-protected car parking areas.	Alternative solution 1 The proposed alternative solution is based on: (i) The provision of a 120/120/120 FRL fire wall, floors and columns in lieu of 240/240/240 FRL to the warehouse areas; (ii) The presence of an automatic sprinkler system within the building, except for the swim school; (iii) The low-rise design of the building; and (iv) The significant distance from neighbouring buildings	
BCA Clause C1.1 and Spec C1.1.		
Relevant performance requirement(s)	CP1 and CP2.	
Assessment Method(s)	AS3091(1) Other	
Assessment Method	Method 1.	

Proposed alternative solution	
BCA DSB provision Clause C1.1 nominates compliance with Specification C1.1, which, for Type A construction, stipulates an FRL of 120/120/120 FRL, fire resisting lift and stair shafts. Clause C2.7(b)(i) stipulates that any openings in a fire wall must not reduce the FRL required by Specification C1.1 for the fire wall, except where permitted by the Fire Retardant-to-Safety Provisions of Part C3. Clause C2.8 of the BCA stipulates that a fire wall must not have a different classification located alongside one another in the same storey, each building element must have a higher FRL prescribed in Spec. C1.1. Clause C3.8 of the BCA stipulates that doorways which open into fire-protected exits must be protected by fire-resisting doors or fire-resisting doors or fire-resisting doors or fire-resisting doors in accordance with C3.8(a). Relevant performance requirement(s) Clause C3.8. Assessment method CP2. Assessment method A0.9(b)(ii) "other Verification Methods". Clause C1.1 of the BCA stipulates that external walls must be non-combustible. Clause 2.4(e) of BCA Spec. C1.1 & Clause C1.10 stipulates that fire-hazard properties of external walls are required to comply with the fire hazard properties of external walls of Class 1.1. BCA Clause Spec. C1.1. Relevant performance requirement(s) CP2. Assessment method A0.9(b)(ii) "other Verification Methods".	Alternative solution 2 The proposed alternative solution is based on: (i) The provision of a fire-protected glazed entry lobby in lieu of 120/120/120 FRL to the ground floor entry lobby of the swim school and Stair 2; (ii) The provision of fire-protected glazed doors to Stair 1 in lieu of fire doors; and (iii) The presence of an automatic sprinkler system within the building, except for the swim school. Alternative solution 3 The proposed alternative solution is based on: (i) The provision of Dampson and Alucobond Plus as cladding to various parts of the external walls, which have not been tested as "non-combustible" in accordance with AS 1530.1; and (ii) The presence of an automatic sprinkler system within the building, except for the swim school.

BCA DSB provision Clause D1.3 of the BCA stipulates that every stairway serving as an exit must be fire-isolated and, unless it connects, passes through or passes by not more than three consecutive storeys if the building has a sprinkler system. Clause D2.4 of the BCA stipulates that if a stairway serving as an exit is not fire-isolated, there must be no direct connection between a flight rising from the storey below the lowest level of access to a road or open space and a flight descending from a storey below that level. BCA Clause D1.3 and D2.4. Relevant performance requirement(s) DPS and EP2.2. Assessment method A0.9(c) "Comparison with the Deemed-to-Satisfy Provisions".	Alternative solution 4 The proposed alternative solution is based on: (i) Stair 1 which is fire-isolated and does not feature separation via rising and descending stair flights; (ii) Stair 2 which is not fire-isolated and does not feature separation via rising and descending stair flights; (iii) The presence of an automatic sprinkler system within the building, except for the swim school; (iv) The 2 hour fire separation provide between the stairways and basement carpark level; and (v) Occupants travelling a maximum of two levels to egress.
BCA Clause D1.4. Relevant performance requirement(s) DP4 and EP2.2. Assessment method A0.9(c) "Comparison with the Deemed-to-Satisfy Provisions". Assessment method A0.9(b)(ii) "other Verification Methods".	Alternative solution 5 The proposed alternative solution is based on: (i) Travel distance of up to 65 metres to an exit within the basement carpark, in lieu of 40 metres; (ii) Travel distance of up to 120 metres between alternative exits within the carparking basement levels, in lieu of 60 metres; (iii) A sprinkler system with listed test-response heads (activation temperature of 68°C and RTI 50 m²/m³) and maximum coverage of 12 m² per sprinkler for ordinary hazard throughout the basement car park level, in accordance with BCA Specification E1.5, which includes compliance with the relevant parts of AS2118-1999; and (iv) A building occupant warning system featuring an automatic voice-messaging function.
BCA Clause D1.4 of the BCA stipulates that no point on a floor must be more than 20 m from an exit, or a point from which travel in different directions to two exits is available.	Alternative solution 6 The proposed alternative solution is based on: (i) Travel distance of up to 25 metres to the single exit in lieu of 20 m within the warehouse mezzanine;

BCA DSB provision Clause C1.1 nominates compliance with Specification C1.1, which, for Type A construction, stipulates an FRL of 120/120/120 FRL, fire resisting lift and stair shafts. Clause C2.7(b)(i) stipulates that any openings in a fire wall must not reduce the FRL required by Specification C1.1 for the fire wall, except where permitted by the Fire Retardant-to-Safety Provisions of Part C3. Clause C2.8 of the BCA stipulates that a fire wall must not have a different classification located alongside one another in the same storey, each building element must have a higher FRL prescribed in Spec. C1.1. Clause C3.8 of the BCA stipulates that doorways which open into fire-protected exits must be protected by fire-resisting doors or fire-resisting doors or fire-resisting doors or fire-resisting doors in accordance with C3.8(a). Relevant performance requirement(s) Clause C3.8. Assessment method CP2. Assessment method A0.9(b)(ii) "other Verification Methods". Clause C1.1 of the BCA stipulates that external walls must be non-combustible. Clause 2.4(e) of BCA Spec. C1.1 & Clause C1.10 stipulates that fire-hazard properties of external walls are required to comply with the fire hazard properties of external walls of Class 1.1. BCA Clause Spec. C1.1. Relevant performance requirement(s) CP2. Assessment method A0.9(b)(ii) "other Verification Methods".	Alternative solution 7 The proposed alternative solution is based on: (i) Travel distance of up to 30 metres to the single exit in lieu of 20 m within the Level 2 office. (ii) Provision of a smoke detection system in accordance with AS 1670.1-2004; and (iii) A building occupant warning system featuring an automatic voice messaging function. Alternative solution 8 The proposed alternative solution is based on: (i) Travel distance of up to 60 metres between alternative exits within Treasury C3, in lieu of 60 metres; (ii) Sprinkler system in accordance with BCA Specification E1.5, which includes compliance with the relevant parts of AS2118-1999; (iii) A building occupant warning system featuring an automatic voice messaging function; and (iv) The significant reservoir size for the smoke to fill. Alternative solution 9 The proposed alternative solution is based on: (i) Travel distance of up to 70 metres between alternative exits within the child care centre on Level 2, in lieu of 60 metres; (ii) Provision of a 30 m² refuge area to Level 2 adjacent to the lift lobby and fire stair with the bounding walls being lined with the existing plasterboard to achieve a 120/120 FRL and extending to the underside of the roof covering or a 120/120 FRL ceiling; (iii) The distance between exits and refuge area not exceeding 60 metres. Alternative solution 10 The proposed Alternative Solution is based on the travel path egress width within the swim school between columns and the pool is 820mm wide, in lieu of 1 m.
---	--

BCA DSB provision Clause C1.1 nominates compliance with Specification C1.1, which, for Type A construction, stipulates an FRL of 120/120/120 FRL, fire resisting lift and stair shafts. Clause C2.7(b)(i) stipulates that any openings in a fire wall must not reduce the FRL required by Specification C1.1 for the fire wall, except where permitted by the Fire Retardant-to-Safety Provisions of Part C3. Clause C2.8 of the BCA stipulates that a fire wall must not have a different classification located alongside one another in the same storey, each building element must have a higher FRL prescribed in Spec. C1.1. Clause C3.8 of the BCA stipulates that doorways which open into fire-protected exits must be protected by fire-resisting doors or fire-resisting doors or fire-resisting doors or fire-resisting doors in accordance with C3.8(a). Relevant performance requirement(s) Clause C3.8. Assessment method CP2. Assessment method A0.9(b)(ii) "other Verification Methods". Clause C1.1 of the BCA stipulates that external walls must be non-combustible. Clause 2.4(e) of BCA Spec. C1.1 & Clause C1.10 stipulates that fire-hazard properties of external walls are required to comply with the fire hazard properties of external walls of Class 1.1. BCA Clause Spec. C1.1. Relevant performance requirement(s) CP2. Assessment method A0.9(b)(ii) "other Verification Methods".	Alternative solution 11 The proposed alternative solution is based on: (i) The non-provision of a sprinkler system to the swim school; (ii) The swim school being a separate fire compartment from the remainder of the building; (iii) The non-provision of a roof over the building having an FRL of 120/60/20; (iv) The non-provision of separation between vertical openings in external walls; (v) The provision of a sprinkler system throughout the building with the exception of the swim school; and (vi) The provision of a beam type automatic fire detection system to the swim school. Alternative solution 12 The proposed Alternative Solution is based on: (i) The use of jet-fans in lieu of a conventional exhaust air system in the basement carpark where the jet-fans do not comply with the requirements and recommendations in clause 5.5 of AS/NZS 1686.1; (ii) The provision of an automatic sprinkler system with test response heads of a standard sprinkler system in the basement carpark; (iii) The provision of manual controls by the fire fan control and indication panel (FFCP) at the fire indicator panel which override the automatic operation of the jet-fans; and (iv) An additional detector(s) being located on the downstream side of each jet fan for auto shutdown; and (v) The jet fans located above driveways and access ways.
---	---

8 HAZARDS

A review of fire hazards is to be carried out as part of the fire safety assessment. This review can assist in providing an insight into the inherent fire risks associated with the subject building that may need to be considered in the assessment.

The potential sources of ignition are not critical to the assessment, as it is to be deterministic in nature (based on ignition occurring, followed by the nominated fire scenario). Thus, a detailed review of ignition sources is not considered necessary in the context of the assessment.

8.1 General Building Layout

Hazards to occupants relating to the building layout may arise in association with:

- Exit travel distances within the office areas;
- Exit travel distances within the car park;
- Exit travel distances within warehouse areas.

Although there are variations to the travel distances, adequate number and distribution of exits are provided in accordance to DSS provisions of the BCA, given occupant numbers and size of the building.

The above issues are to be considered in detail as part of the fire engineering assessment.

8.2 Activities

Car Park Areas

The primary activity being undertaken within the car park is the movement/parking of motor vehicles. Associated hazards that could result in initiation of a fire are as follows:

- Vehicle accidents (about slow-speed accidents);
- Mechanical or electrical failure of vehicle parts.

Storage/Collection Areas

Given the area being used comprises mostly activity rooms, this area will be used predominantly by staff and is not intended for storage or collection of goods. As such, no unusual high fire safety hazards are present in comparison to the ignition and evacuation issues associated within the facility.

Manufacturing Areas

Potential hazards associated with activities within the storage areas relate to the presence and use of electrical and communication equipment throughout most areas (milling, coating activities and other manufacturing activities). The equipment used in these areas is not considered to be a significant source of ignition, as the equipment is not intended for storage or collection of goods. As such, no unusual high fire safety hazards are present in comparison to the ignition and evacuation issues associated within the facility.

Office Areas

Potential hazards associated with activities within the office areas relate to the presence and use of electrical and communication equipment throughout most areas (milling, coating activities and other manufacturing activities). The equipment used in these areas is not considered to be a significant source of ignition, as the equipment is not intended for storage or collection of goods. As such, no unusual high fire safety hazards are present in comparison to the ignition and evacuation issues associated within the facility.

Mayrall, H. W., Fire: A Century of Automatic Sprinkler Protection in Australia and New Zealand 1980-1990, 1990.



6.3 Ignition Sources

Car Park Areas

A number of potential ignition sources and fire hazards have been identified for the building, based on a literature review of similar compounds (Patterson, Mayrall, BHP, FRCO and Thomas¹³). The potential ignition sources and fire hazards in the car park areas include vehicles, electrical equipment and arson.

A review of fire statistics in car parks¹⁴ by BHP Melbourne Research Laboratories (BHL) has reported the following:

- There have been no death or serious injuries recorded for fires in car parks in Australia.
- The American Iron and Steel Institute (AISI) survey of US and Canadian car parks has indicated that the fire safety risks within car parks are not significant, as there has been no recorded loss of life or property in car parks over a survey period of 60 years. Car parks are generally not a source of death or personal injury.
- The National Fire Protection Association analysed the loss from US and Canadian car parks from 1982 to 1989 and concluded that there is an extremely low fire safety hazard in car parks.

The referenced AISI report concluded with the following statement: "It is clear from the available fire record that fires in car parks represent little risk to life or injury, and very low monetary losses, possibly less than 1% of the losses in this type of building. Accordingly, the requirements for fire protection should not be excessive."

Storage/Collection Areas

The fire incident statistics in assembly buildings in Australia and the United Kingdom could identify significant trends and provide an insight of the inherent fire risk of education buildings, such as the building under investigation. However, it should be noted that the statistical evaluation is based on a review of fire incidents in assembly buildings, not specifically in storage or collection areas. It may be applicable to the subject development and not as the sole basis of a fire safety strategy, due to the potential variations in building conditions, age, fire safety measures installed, etc.

Australian Fire Incident Statistics, prepared by CSIRO¹⁵, provides an overview of fire stats across the entire spectrum of fixed property use in the period of 1980-1994. The most common sources of ignition for educational buildings, according to Australian Fire Incident Statistics, are electrical equipment (about circuits etc), smoking materials (cigarettes, matches, lighters etc) and cooking equipment. At approximately 20 per cent, arson contributes to a relatively large percentage of fire in educational properties, although it should be noted that arson is a common contributing factor in the majority of fires in educational buildings. The most common source of ignition for education buildings is electrical equipment (17 per cent), followed by assembly areas (15 per cent), circulation spaces (kitchen/cooking areas) (9 per cent each) and external surfaces, such as walls, roofs and balconies (9 per cent).

Statistics provided by NSW Fire Brigades (NSWFB) in its annual report for 2004/2007¹⁶ also indicate that the most common source of ignition for educational buildings is electrical equipment (17 per cent), followed by assembly areas (15 per cent), circulation spaces (kitchen/cooking areas) (9 per cent each) and external surfaces, such as walls, roofs and balconies (9 per cent). According to statistics provided by Mayrall¹⁷, the most common contributing factors to the stats in school buildings in Australia are electrical equipment and smoking materials.

1. Patterson, J. and MacDonald-Gibson, O. (1989) Documentation of Ignition Frequency of Fires in Different Premises in Victoria.
2. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
3. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
4. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
5. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
6. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
7. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
8. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
9. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
10. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
11. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
12. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
13. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
14. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
15. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
16. NSW Fire Brigades, New South Wales Fire Brigades Annual Statistical Report 2006/2007, Sydney, 2007.
17. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.



eliminate/control the source of heat, ignition and fuel, as shown by the concepts tree in Figure 2. The concept is considered applicable for the type of development.

Fire Prevention




Figure 2 - Fire safety concepts from NFPA 550

To mitigate these events, site-specific policies can be developed and implemented to address for the purposes of minimising the risk of fire initiation, based on maintenance, planning, housekeeping and training, as discussed in detail the document.

6.5 Interactions Between Ignition and Fuel Sources

The fire safety concepts tree NFPA 550¹⁸ considers the interaction of individual elements as part of an overall fire safety system. It recommends that one of the means of mitigating the fire risk is to eliminate/control the source of heat, ignition and fuel, as shown by the concepts tree in Figure 6.1. The concept is considered applicable for the type of development.

Fire Prevention



Figure 6.1 - Fire safety concepts from NFPA 550

To mitigate these events, site-specific policies can be developed and implemented to address for the purposes of minimising the risk of fire initiation, based on maintenance, planning, housekeeping and training, as discussed in detail in Section 6.5.

6.6 Unusual Features

The Fire Engineering Brief process has not identified specific issues relating to BCA deemed-to-satisfy provisions E.1.10 and E2.3.

Any dangerous goods to be stored in the property are to be addressed by way of endorsement with the relevant codes and standards, noting that the client has not advised that any are expected.

6.7 Hazards Summary

As the above statistical evaluation is based on a large range of buildings types, the results should only be used to derive typical trends that may be applicable to the subject development and not as the sole basis of a fire safety strategy, due to the potential variations in building conditions, age, fire safety measures installed etc.

NFPA 550, Guide to the Fire Safety Concepts Tree, 2002.



1. U.S. Fire Administration, Technical Paper: Research Series, Volume 2, Issue 5, October 2001, Issued March 2002.
2. The Fire Protection Association, O. (1989) Documentation of Ignition Frequency of Fires in Different Premises in Victoria.
3. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
4. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
5. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
6. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
7. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
8. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
9. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
10. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
11. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
12. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
13. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
14. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
15. Thomas, J. R. (1988) Fire Safety in Shopping Centres, Final Research Report - Project 6, The Code Reform Centre Ltd, Sydney.
16. BHP (1980) Design of School Steel Buildings for The Safety, BHP Integrated Steel, June 1980.
17. Mayrall, H. W. (1990), Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1980-1990, FPAU, Australia.
18. NFPA 550, Guide to the Fire Safety Concepts Tree, 2002.

(i) Fires in assembly buildings accounted for a relatively large proportion of the fire incidents that occurred in all building types. As such, the large number of fire alerts for these buildings supports the need for a fire safety assessment of the potential for fire spread, based on the specific circumstances involved.

- (iii) The main causes of ignition in commercial office buildings appeared to be electrical equipment and electrical system faults, cigarettes, combustible fuels, arson and trades activities, such as welding and painting.
- (iv) Arson (fire of suspicious nature) has been identified as a common ignition factor for the building, as is the case for most occupancy types. This can be minimized by the implementation of suitable building security measures.

PREVENTATIVE AND PROTECTIVE MEASURES

PREVENTATIVE AND PROTECTIVE MEASURES

- **Sub-system A – Fire Initiation and Development and Control**

- Sub-system E – Occupant Evacuation and Control
- Sub-system F – Fire Services Intervention

ensuing threat to occupant safety.

Sub-system	Preventative and protective measures
Sub-system F - Fire Systems Intervention	Applicable safety measures are as follows:
	• A fire-fighting system will be provided for use by fire-fighters undertaking fire-fighting or search and rescue activities. • An automatic fire sprinkler system will be provided throughout the building, with the exception of the swim school, with fast response heads to the capsize, which will assist in reducing the size and severity of a fire thus minimising the risk of exposure for attending fire-fighters. • The presence of fire compartmentation between classifications will limit the spread of fire and smoke, which will assist in reducing the size and severity of a fire thus minimising the risk of exposure for attending fire-fighters. • The building is provided with appropriate access points suitable for fire brigade access. • A fire alarm system will be provided, which will assist in reducing the size and severity of a fire thus minimising the risk of exposure for attending fire-fighters. • Suitable fire-fighting equipment will be available in response to fire incidents in the Sub-systems/operation being

Table 6.1 – Preventative and protective measures

SUE-system	Applicable mitigating measures are as follows: <u>Preventing and protective measures</u>
------------	--

- Appropriate policies and procedures will be implemented the control of smoke during the early stages of a fire's growth.

- The presence of fire compartmentation will limit the spread of smoke in the early stages of a fire when occupants will be evacuating.

- The building materials and linings will comply with the fire hazard property provisions of the BCA to reduce the incidence of rapid fire spread and significant smoke production during the early stages of a fire.

- and a fire hose reel system will be provided for use by occupants in alternating first-aid fire-fighting prior to arrival of fire-fighters.

- order to reduce the risk of obstruction during evacuation.**

7 TRIAL CONCEPT FIRE SAFETY STRATEGY

7.1 CONSTRUCTION, FIRE RESISTANCE & COMPARTMENTATION

Table 7.1 – Proposed construction measures

Item No.	Messure	Description of construction measure
1.	Compliance with BCU DS provisions	With the exception of the proposed alternative solutions described within this document, the proposed deventher system is to comply with the DS provisions of Section 7.5.1 of BS EN 16359-1:2014. Provisions of Section 7.5.1 of BS EN 16359-1:2014 are to be complied with the 2 hour fire resisting construction on the basement carpark level, as shown in Figure 7.1.
2.	Fire separation	The glazing shown in Figure 7.1 below, which is to be protected by a well-sealing deventher system in accordance with the deventher system provisions described in below, is to comply with the following: (f) glazed door leaves are to be full height (i.e. extend to the top of the deventher-protection glazing) and self-closing or fire-resistant and self-closing-protection glazing) and self-closing or fire-resistant and self-closing barriers or other measures, such as storage provided adjacent to the glazed construction, stating: "No storage adjacent to glazing or fitting of frame to glazing for fire safety purposes" not less than 20 mm high in a colour contrasting with the background and permanent construction are to be provided to prevent the placement of either storage or furnishings adjacent to the glazing that may obstruct the operation of the barrier or other measures; (g) as well as the above requirements, the glazing is to comply with (j) or (k) below, depending upon whether it is to be protected by Tyco Model WS deventhers or an alternative system: (i) any glazing protected by the Tyco Model WS deventher system is to comply with the glazing requirements outlined within the Tyco Model WS deventher specification noting that although the inclusion of (self-closing) doors as part of the deventher protection system construction is considered acceptable as part of the Alternative Solution; or (ii) any glazing not protected by the Tyco Model WS deventher system is to comply with the following: a) horizontal mullions are not to be incorporated in the glazing on the sides of the glazing where the deventhers are to be provided, as the flow of water may be obstructed; b) deventher-protected glazing construction is to feature reinforced glazing construction, with a minimum thickness of 6 mm and glazing is to be supported by aluminium, timber or steel framing elements, which provide allowance for the expansion of the glass by the use of suitable seals; c) fixed glazing is to be supported by aluminium, timber or steel framing elements, which provide allowance for the expansion of the glass by the use of suitable seals; As part of the child care centre fitout works, a 30 m ² refuge area, shown in Figure 7.5 is to be provided to Level 2 adjacent to the lift lobby and fire exit. The bounding walls are to be lined with fire resisting plasterboard to achieve a 120/120 FRL and extend to the underside of the roof ceiling over a 120/120/120 FRL ceiling. The doors are to be 120/30 FRL, self-closing or automatic-closing doors with smoke
3.	Drencher-protected glazed construction	
4.	Refuge area	

Item No.	Measure	Description of construction measure
5.	Smoke seals	Medium-temperature smoke seals are to be provided to the doors to the refuge area described above. The smoke seals shall be selected such that when fitted to a fire door and tested in accordance with AS 1530.7-2007, they achieve a maximum total leakage rate of 25 m³/h, corrected to STP, at a pressure differential of 25 Pa after more than 30 minutes exposure to 200 °C (as per AS 8905-2007).
6.	Fire compartmentation	Fire resisting walls and floors are to be provided in accordance with drawing GA-110, as shown in Figure 7.4 below (prepared by SBA Architects), to separate the fire compartments within Stage 2 and to separate Stage 2 from Stage 1. Note: The swim school on Ground Floor is to form a separate fire compartment.




Figure 7.1 – Location of proposed drencher protected glazing and fire separation on Ground Floor




Figure 7.2 – Proposed Drencher-protected glazing on Level 1




Figure 7.3 – Proposed Drencher-protected glazing on Level 2




Figure 7.4 – Proposed fire compartmentation to Stage 2




Figure 7.5 – Proposed refuge area to Level 2 child care centre

7.2

Egness

Table 7.2 below summarises the egress measures that are to be implemented as part of the proposed fire safety strategy.

Table 7.2 – Proposed agreed measures

Table 7.2 – Proposed egress measures		
Item no.	Measure	Description of egress measure
1.	Compliance with BCA DIS provisions	With the exception of the proposed alternative solutions described within Table 5.1, the proposed development is to comply with the DIS provisions of Section D of the BCA.
2.	Travel path egress width	The travel path egress width within the swim school between columns and the north is 820 gress width. In line of 1 m.

73

FIRE SERVICES & EQUIPMENT

Table 7.3 below summarises the fire protection systems that are to be provided as part of the proposed fire safety strategy for the development.

Figure 7.6 indicates the various infrastructure locations for the fire protection systems.

Table 7.9 – Proposed fire protection systems

Item no.	Measure	Description of fire protection system
1.	Compliance with BCA DTS provisions	With the exception of the proposed Alternative Solutions described within this document, the proposed development is to comply with the DTS provisions of Section E of the BCA.

Item No.	Measure	Description of the protection system
2.	Automatic fire smoke detection system	An automatic fire detection system is to be provided to the Level 2 office floor in accordance with the provisions of the Fire Protection Code of BCA Specification E2.2a and AS 1670.1-2004. With the exception of the swim clinic fire compartment, an automatic fire detection system is to be provided throughout the building in accordance with clause E1.5 of the BCA and AS 2118.1-1999. In addition, fast-response heat (activation temperature of 68°C and RTI 50 m²s^{1/2}), is to be provided throughout the car park levels, and maximum coverage of 12 m² per sprinkler for ordinary hazard, in accordance with BS EN 12868-1:2003, car park level, in accordance with BS EN 12868-1:2003, clause E1.5, which includes compliance with the relevant parts of AS2118-1999. Class A or B monitoring devices are to be fitted to the main stop valves, as detailed under Clause 3.4.2 of AS 2118.1.
3.	Automatic fire suppression system	Automatic fire suppression is to be provided to the carpark side of the glazed installations on Ground Floor, to the office side on Level 1 and to the swimming pool area on Level 2, in accordance with the provisions of the Fire Protection Code of BCA Specification E2.3 incorporating the following: (i) fire extinguishers are to be provided in accordance with Figure 7.1, Figure 7.2 and Figure 7.3 incorporating the following: (i) fire extinguishers are to be fitted from the fire hydrant system, using a monitored isolation valve that is clearly labelled as the valve itself, on the hydrant floor plan, and is accessible without the need for a fire order; (ii) fire extinguishers are to be used that is capable of fully wetting the glazing, as well as the fire extinguisher, and is capable of being used on the glazing, including any self-closing / automatic-closing doors when in the closed position, with no dry spots or a proprietary system, unless an alternative system can be shown as being appropriate for the application. Note that in the case of adoption of the Tyco Model WS fire extinguisher, the use of a monitored isolation valve to isolate the fire extinguisher-provided installations is inconsistent with the product specification, such doors are considered acceptable as part of this alternative solution; and (iii) the design is to be capable of supplying the required flow and pressure for the simultaneous operation of the fire extinguishers to one side of one of the glazed installations.
4.	Automatic wall-wetting fire extinguishers	
5.	Building occupant warning system	A building occupant warning system is to be provided throughout the building in accordance with the following: (i) Clause 6 of Specification E2.2a, which includes compliance with the relevant parts of AS 1670.1-2004. (ii) Clause 4.3.5 of AS 1670.4-2004, relating to the use of an automatic fire alarm system.


Page 40 of 120
Report No. 2006-01

Figure 7.6 – Fire services infrastructure layout

STANDARDS OF CONSTRUCTION, COMMISSIONING, MANAGEMENT AND MAINTENANCE

Construction

Building works associated with the installation of the proposed fire safety measures and construction elements are to be undertaken by appropriately qualified persons. Coordination of such works is to be undertaken by a project manager and / or construction manager nominated for the project.

Commissioning

Fire safety measures are to be the subject of any testing and commissioning requirements specified within the relevant Australian design and installation standards, which include the following:

- (i) wet-wetting drencher system – section 5 of AS 2118.2
 - (ii) fire hydrant system – section 10 of AS 2419.1
 - (iii) fire hose reel system – section 12 of AS 2441
 - (iv) fire doors – Appendix E of AS 1905.1
 - (v) fire sprinkler system – AS 2118.10
 - (vi) portable fire extinguishers – schedule of installed equipment (type, capacity, rating and locations)
 - (vii) automatic fire detection system – AS 1670.1 (section 7 and Appendixes E and F) as well as as a record of an interface test
 - (viii) fire stopping (schedule of locations, types and details)
 - (ix) illuminated exit signs and emergency lighting – AS 2293.2 (name as per monthly test, except for 120 minutes instead of 90 minutes)
- The following inspections of the completed building works are to form part of the commissioning phase of the building:
1. Inspections by the project stakeholders, where necessary, to facilitate certification of the fire safety system and to ensure that the system complies with the fire safety strategy presented as the basis of the fire engineering report.
 2. An inspection by Fire and Rescue NSW to facilitate a final fire safety report, pursuant to the Fire and Rescue Act 2002, which will be submitted to the relevant authority for approval. The authority will also be satisfied that the building complies with the category 2 fire safety provisions of the EPRA.

Item no.	Measure	Description of the protection system
		With the exception of the proposed Alternative Solutions regarding the use of jet-fan system discussed in section 5 of this report the system is to comply with Table E2.2a of BCA Clause E2.2a.
		(i) Dedicated detectors are to be located within 2.3 metres of each jet-fan on the downstream side of the fan and in the supply risers of each jet-fan. The detectors are to be located within 1.5 metres of each jet-fan prior to the operation of the sprinkler system. Detector types are to be selected by the fire services engineer to maximise sensing and performance whilst considering the environment associated with the carpark and the risk of false alarms occurring.
6.	Carpark air exhaust system	(ii) Any sprinkler head in the air-stream of a jet-fan in the downstream direction is to be located a minimum of 2.5 metres from the jet-fan.
		(iii) The jet-fans are to be located along the driveways and orientated such that the jet-fans are directed away from the carpark.
		(iv) Jet-fans are to be monitored and controlled by the main jet-fan controller, which is to be fitted to the fire indication panel.
		(v) Fire resisting cable recommended for the fire trip to the jet-fan panel from the Fire Indicating Panel (FIP) unless it has a fail-safe switch which switches it off should the connection be severed by a fire.
		(vi) Manual operation of the jet-fans from the main controller of the fire alarm panel is proposed.
		(vii) This problem is to be shown in Appendix F.
7.	Fire hydrant system	A fire hydrant system is to serve the building in accordance with BCA clause E1.3, which includes compliance with AS2419-2005.
8.	Fire hose reel system	A fire hose reel system is to be provided in accordance with BCA clause E1.4 and AS 2441-2005.
9.	Portable fire extinguishers	Portable fire extinguishers are to be provided in accordance with BCA clause E1.6 to cover Class A risks within the building in accordance with AS 2444-2001.
10.	Emergency lighting	Emergency lighting is to be provided in compliance with AS2293.1-2005 to the parts of the building covered by Table E2.2a.
11.	Exit signage	Exit signage is to be provided in compliance with AS2293.1-2005 to the locations nominated by BCA Part EA.

Regulation: specifying that the fire hydrants in the fire hydrant system will be accessible for use by Fire and Rescue NSW; and specifying that the couplings in the fire hydrant system will be compatible with those of the fire appliances and equipment used by Fire and Rescue NSW.

- Final design and installation certificates, together with the fire safety schedule and final fire safety certificate that incorporate the details of the fire engineering report
- Visual inspection of fire-resisting elements of construction, including any fire-protected glazing and fire doors (tagged with self-closers or automatic-closers)
- Visual inspection of fire hose reels, portable fire extinguishers, emergency lighting and exit signs
- Validation of sprinkler system flow switch activation, visual inspection of remote test valves, visual inspection of water supply infrastructure (alarm vessels / main stop valves in secure enclosure, fire pumps, water storage tanks, fire brigade booster assembly and back pumps), visual inspection of spare sprinkler heads and visual inspection of sprinkler heads
- Visual inspection of automatic fire doors
- Visual inspection of fire hydrant system signage and water supply infrastructure (fire pumps, water storage tanks, fire brigade booster assembly and back pumps) and visual inspection of fire hose reels
- Visual inspection of the detection and operation of the fire detection and alarm system (if relevant) by activating a smoke detector and witnessing the operation of the occupant warning system (including verbal messaging) and the shutdown of jetties in the berthing compartment
- Witnessing of power failure for operation of emergency lighting
- Visual check of accessibility of exits

Details of the fire engineering report are to be included within the building's final fire safety certificate to assist future essential services maintenance and auditing of the building.

segment-end Use

Following management procedures and policies are to be implemented on an on-going basis to the basis of the fire safety design analysis to be satisfied:

- A house-keeping policy is to be implemented, based on avoiding the accumulation of rubbish or debris within the common areas, including the exits and the paths of travel to the exits, so that the exit routes remain free from obstructions.
- Non-smoking policy is to be implemented, supported by signage placed in appropriate locations.
- An emergency management policy, including staff training and regular evacuation drills, is to be implemented in accordance with the principles of AS 3745/2010.
- Hot works permit policy is to be adopted to address the undertaking of hot works within the building, which can present as a potential ignition source. A permit is to be submitted to building management for any hot works process involving cutting, welding, heating, angle grinding or any other related processes and returned to the authorising person upon completion of the associated works, addressing:
- a) risks associated with exposure of adjacent combustibles;
 - b) working within confined spaces;
 - c) fire watch procedures;
 - d) fire testing requirements; and
 - e) gas testing requirements.

8 PROPOSED APPROACH AND METHOD OF ANALYSIS

8.1 General.

- The International Fire Engineering Guidelines¹⁴ (IFEG) identifies a number of approaches to understanding the fire engineering analysis and assessment as follows:

The International Fire Engineering Guidelines²⁴ (IFEG) identifies a number of approaches to undertaking the fire engineering analysis and assessment as follows:

- Absolute or comparative
 - Qualitative or quantitative
 - Deterministic or probabilistic
- These approaches are not mutually exclusive and a combination of approaches may be adopted.
- As discussed in the IFEQ:

- a "comparative" assessment involves utilization of the same assumptions, models, calculations and input data to both the benchmark design and the alternative solution; and
- an "absolute" assessment involves the assessment of the alternative solution directly against the relevant performance requirements, using the agreed acceptance criteria. With respect to the concept of an "absolute" assessment, the FEED states that "the related performance requirements of the PCA set out to provide a benchmark with respect to the risk of fatality, injury and loss of efficient structures through fire."

A comparative approach satisfies A0.9(c), while an absolute approach may satisfy either A0.9(b) or (d), subject to agreement by the nominated design and review stakeholders.

Analysis of the proposed trial concept design against the relevant fire safety design objectives will be achieved by deterministic engineering analysis either against the relevant ECA performance objectives or on a comparative basis against a BCA deemed-to-satisfy design approach, as outlined in Table 8.1 below (i.e. both 'absolute' and comparative methods will be utilized, as appropriate for each assessment). The 'normalized assessment method' for the establishment of assessment is A0.8(b)(ii) (other verification methods', which comprises the method of analysis utilized below for each alternative solution.

Engineering judgement will be used as the basis for expert judgment and will be typically used to determine or define parameters associated with quantitative and qualitative assessment.

ANALYSIS STRATEGY

For the alternative solutions under consideration, as identified in Table 5.1, the analysis strategy in Table 6.1 is proposed.

Report No. 2686700-R7TD1-6

Method of analysis	Advantages	Disadvantages
1 Edgewise wall fringe	• Absolute • Deterministic • Quantitative	• Comparative • Probabilistic • Qualitative
2 Droplet- protected enclosures and openings in fire- isolated cells	Based on direct assessment against the performance requirements, the methods of analysis to be undertaken will be qualitative and quantitative in nature and will comprise: (i) a determination of the extent of the spread beyond areas separated by the droplet-protected glazing, based on review of the relevant standards and the use of computer simulation systems during exposure to elevated temperatures commensurate with the assumed ignition scenarios and calculation of potential radiant heat flux values in relation to radiant heat transmission through glazed barrier systems, considering the protection of the glazing by an automatic fire-resisting system; and (ii) a review of the automatic operable elements (i.e. doors) in the glazed installations.	• Comparative • Probabilistic • Qualitative
3 Edgewise wall fringe	• Absolute • Deterministic • Quantitative	• Comparative • Probabilistic • Qualitative

No.	Alternative solution	Method of analysis			
		Absolute	X	Comparative Probabilistic	Qualitative
4	Non-provision of fire-isolated stairways and separate rising and descending stair flights	X	X	X	X
		X	X	X	X
		Relevant IFEG sub-systems are:			
		• Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention			
		Based on a comparative assessment, the methods of analysis to be undertaken will comprise:			
		(i) Determination for the potential for fire and smoke spread via the stairway between storeys and between rising and descending stair flights, based on the fire compartmentation provided from the basement carpark level.			
		(ii) Determination of the potential exposure of occupants to fire during evacuation via the stairway, based on occupants travelling a maximum of two storeys to evacuate.			
		(iii) Comparison with a BCA DIS design comprising a three-storey, sprinklered building complying with D1.3(b)(ii)(A) and inter-connection of three storeys by internal non-fire-isolated stairways.			
		(iv) Review of the ability for occupants to evacuate out of the stairway during a fire in proximity to the stairway, based on visual wayfinding associated with the transparent (glazed) stairway construction.			

No.	Alternative solution	Method of analysis			
		Absolute	Deterministic	Quantitative	Comparative Probabilistic Qualitative
5	Exit travel distances between alternative exits (car park)	X	X	X	X
		X	X	X	X
		Relevant FEG sub-systems are:			
		• Sub-system A - Fire Initiation and Development and Control • Sub-system B - Smoke Development and Spread and Control • Sub-system C - Fire Spread and Impact and Control • Sub-system D - Fire Detection, Warning and Suppression • Sub-system E - Occupant Evacuation and Control • Sub-system F - Fire Services Intervention			
		Based on a comparative assessment, the method of analysis will comprise a quantitative review of the evacuation time of occupants from SQU between the proposed Alternative Solution and a similar BCA DIS compliant design, consisting of:			
		(i) Detection time (i.e. based on activation of automatic fire suppression system).			
		(ii) Pre-movement time (i.e. based on pre-movement time from PD 7974-6:2004 ¹⁰).			
		(iii) Movement time (i.e. based on methodologies and recommendations of Gwynne and Rosenbaum ¹¹).			
		(iv) Comparison of the evacuation time for the proposed design with that of the DIS-compliant design which do not comprise fast response sprinkler heads.			

31 British Standards, PD 7974-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, 2004, p. 149.

32 British Standards, PD 7974-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, 2004, p. 149.

33 Gwynne, S. M. V. and Rosenbaum, E. R., Employing the Hydraulic Model in Assessing Emergency Movement, Section 3: Chapter 14, The SPPE Handbook of Fire Protection Engineering, 4th edition, National Fire Protection Association, Quincy, Massachusetts, 2000, pp. 3-377-3-386.

No.	Alternative solution	Method of analysis			
		Absolute	Deterministic	Quantitative	Comparative
6	Exit travel distances between alternative exits (Tenancy G.3, Mezzanine)	X	X	X	X
		X	X	X	X
		Relevant IFEG sub-systems are:			
		- Sub-system A – Fire Initiation and Development and Control - Sub-system B – Smoke Development and Spread and Control - Sub-system C – Fire Spread and Impact and Control - Sub-system D – Fire Detection, Warning and Suppression - Sub-system E – Occupant Evacuation and Control - Sub-system F – Fire Services Intervention			
		Based on a comparative assessment, the method of analysis will comprise a qualitative review of the evacuation time of occupants from Level 2 office between the proposed Alternative Solution and a similar BCA DIS compliant design, consisting of:			
		(i) Detection time (based on activation of automatic fire suppression system).			
		(ii) Pre-movement time (i.e. based on pre-movement time from PD 7974-6:2004 ¹⁰).			
		(iii) Movement time (i.e. based on methodologies and recommendations of Gwynne and Rosenbaum ¹¹).			
		(iv) Comparison of the evacuation time for the proposed design with that of the DIS-compliant design which does not incorporate a voice messaging system.			

33 British Standards, PD 7974-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, 2004, p. 149.

34 British Standards, PD 7974-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, 2004, p. 149.

35 Gwynne, S. M. V. and Rosenbaum, E. R., Employing the Hydraulic Model in Assessing Emergency Movement, Section 3: Chapter 14, The SPPE Handbook of Fire Protection Engineering, 4th edition, National Fire Protection Association, Quincy, Massachusetts, 2000, pp. 3-377-3-386.

No.	Alternative solution	Method of analysis			
		X / Absolute	X / Deterministic	X / Quantitative	Comparative / Probabilistic / Qualitative
7	Exit travel distances between alternative exits (Level 2 office)	X	X	X	X
		X	X	X	X
		Relevant FEG sub-systems are:			
		- Sub-system A – Fire Initiation and Development and Control - Sub-system B – Smoke Development and Spread and Control - Sub-system C – Fire Spread and Impact and Control - Sub-system D – Fire Detection, Warning and Suppression - Sub-system E – Occupant Evacuation and Control - Sub-system F – Fire Services Intervention			
		Based on a comparative assessment, the method of analysis will comprise a quantitative review of the evacuation time of occupants from Level 2 office between the proposed Alternative Solution and a similar BCA DIS compliant design, consisting of:			
		(i) Detection time (i.e. based on activation of automatic fire detection system).			
		(ii) Pre-movement time (i.e. based on pre-movement time from PD 7974-6:2004 ¹⁰).			
		(iii) Movement time (i.e. based on methodologies and recommendations of Gwynne and Rosenbaum ¹¹).			
		(iv) Comparison of the evacuation time for the proposed design with that of the DIS-compliant design incorporating extended spaced detectors.			
8	Distances between alternative exits (Tenancy G.3.)	X	X	X	X
		X	X	X	X
		Relevant FEG sub-systems are:			
		- Sub-system A – Fire Initiation and Development and Control - Sub-system B – Smoke Development and Spread and Control - Sub-system C – Fire Spread and Impact and Control - Sub-system D – Fire Detection, Warning and Suppression - Sub-system E – Occupant Evacuation and Control - Sub-system F – Fire Services Intervention			
		Based on a comparative assessment approach, the methods of analysis to be undertaken will comprise:			
		(i) Calculation of the available safe egress time (ASET) for the proposed alternative solution based on zone modelling.			
		(ii) Calculation of the ASET for a BCA DIS-compliant benchmark design which could have a ceiling height of 2.4 metres, and travel distances of 20 / 40 / 80 m.			
		(iii) Comparison of the ASET for both the alternative solution and the BCA DIS-compliant benchmark design.			
		(iv) Determination of the impact of the additional travel time that could be incurred by occupants during the evacuation period.			

35 British Standards, PD 7974-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, 2004, p. 149.

36 British Standards, PD 7974-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, 2004, p. 149.

37 Gwynne, S. M. V. and Rosenbaum, E. R., Employing the Hydraulic Model in Assessing Emergency Movement, Section 3: Chapter 14, The SPPE Handbook of Fire Protection Engineering, 4th edition, National Fire Protection Association, Quincy, Massachusetts, 2000, pp. 3-377-3-386.

No.	Alternative solution	Method of analysis			
		X	Absolute Quantitative	Comparative	Probabilistic Quantitative
9	Distances between alternative exits (child care)	X	X	X	X
		X	Quantitative	X	Qualitative
10	Swarm school egress within	X	X	X	X
		X	Quantitative	X	Qualitative

Based on a comparative assessment approach, the method of analysis to be undertaken will comprise an anthropometric assessment to determine the potential for the exit to the safe, utilising anthropometric data from "Littell" and "Phares". The comparative assessment will consider for both the proposed design and the BCA DIS-compliant design:

- the number of occupants served; and
- the occupant movement time.

27 Littell, D. "Metric Handbook: Planning and Design Data, 9th edition, Architectural Press, Oxford, UK, 2008.
28 Phares, G. "Biometrics - Anthropometry, Ergonomics and the Design of Work, Third Edition, Taylor & Francis Group, 2006.

Report No. 2008/030-07/11-4
Page 51 of 170

6.4

Redundancy Strategy

The design strategy includes evaluation of sub-system failure and the bridge intervention, where appropriate. If a sub-system operation is shown to be essential for the proposed fire safety design solution, the system will be assessed for adequate reliability and performance.

Fire protection systems such as fire hydrants, fire hose reels and fire extinguishers will facilitate fire brigades and occupant intervention in the development of a fire and facilitate redundancy in a qualitative manner when considering that the fire safety assessment does not rely directly on these systems.

However, it should be noted that for the alternative solutions that are to be reviewed on the basis of a comparative assessment, redundancy involving the safety measures is not applicable, as this will not be the case for the proposed design. The design strategy includes evaluation of the system for DIS-compliant design, as they will feature similar passive and active elements of design. Redundancy of direct path of travel will be considered given that occupants can manoeuvre around within the escape strategy layout and select an alternative path to reach the 2nd exit.

The safety margins used throughout the analysis will also form part of the redundancy considerations.

No.	Alternative solution	Method of analysis			
		X	Absolute Quantitative	Comparative	Probabilistic Quantitative
11	Variation to roof height, spanning area, structural and smoke hazard management	X	X	X	X
		X	Quantitative	X	Qualitative
12	Mechanical ventilation system	X	X	X	X
		X	Quantitative	X	Qualitative

Based on a comparative assessment approach, the methods of analysis to be undertaken will comprise:

- Review and determination for the potential for the spread from the subject building to the adjacent building.
- Review and determination for the potential for the spread from the subject building to the adjacent building.
- Review and determination for the potential for the spread between the building and the adjacent building.
- Review of the proposed smoke hazard management system for the building which comprises a combination of an automatic sprinkler system and smoke detection system.

6.5

Sensitivity Strategy

When a particular fire safety measure or input parameter for the fire safety assessment is found to play a critical role in the outcome of the analysis, a sensitivity study will be conducted to assess the impact of a variation in performance of such system or parameter on the design.

For the Level 2 exit travel distance assessment, a 'fast fire' will be considered in addition to the standard medium 'fire'.

Report No. 2008/030-07/11-4
Page 53 of 170

6.6

Acceptance Criteria

Assessment or Acceptance Criteria

A deterministic analysis will be undertaken generally as described in the International Fire Engineering Guidelines. The analysis will comprise a comparison with the fire standard to evaluate the interaction between sub-systems, and include system reliability and effectiveness.

The fire engineering analysis will detail and show how the relevant fire-safety objectives have been demonstrated to the degree necessary.

Acceptance Criteria from the Analysis

Consideration of the individual parameters identified for each relevant BCA performance requirement will be addressed by qualitative analysis to establish compliance with the fire standard for buildings possessing similar construction and occupancy characteristics.

Acceptable design margins will be incorporated however, a generally conservative analysis coupled with redundancy in the design. It is intended to provide an initial level of safety prior to the application, if necessary, of a numerical design margin.

For the case of an acceptance criteria based on a comparative assessment approach (based on comparison with the BCA, deemed-to-satisfy provisions as a benchmark for the safety), the International Fire Engineering Guidelines states that:

A should not be necessary to include explicit listing of safety because the same methods and assumptions for the analysis would be used for both the deemed-to-satisfy or prescriptive design and the proposed design.

For the case of an acceptance criteria based on an "absolute" assessment approach, it should be noted that the FREG states that:

It is not intended that the benchmark should be "absolute safety" or "zero risk" because these concepts are not realistic. The benchmark should be "adequate safety" to allow occupants with the community aspects and the cost to the community, which may be determined by a cost benefit analysis.

The nominated acceptance criteria for each of the proposed alternative solutions are detailed within Table 6.1 below.

Table 6.1 – Acceptance Criteria


No.	Alternative solution	Acceptance criteria
1	Fire resisting construction of warehouse areas	Acceptance acceptance criteria are to be adopted, being that structural failure and the spread of fire to the non-fire affected sides of the compartment barrier and collapse onto adjacent buildings is mitigated by the performance of the fire system, the fire-resisting wall construction with the fire bridge possible structural failure time.
2	Direction protected roof structure and openings in fire isolated exits	Acceptance acceptance criteria are to be adopted, being that structural failure and the spread of fire to the non-fire affected sides of the compartment barrier and collapse onto adjacent buildings is mitigated by the performance of the fire system, the fire-resisting wall construction with the fire bridge possible structural failure time.
3	External wall fixings	Acceptance acceptance criteria are to be adopted, being that structural failure and the spread of fire to the non-fire affected sides of the compartment barrier and collapse onto adjacent buildings is mitigated by the performance of the fire system, the fire-resisting wall construction with the fire bridge possible structural failure time.



No.	Alternative solution	Acceptance criteria
4	Non-provision of fire-isolated stairways and separate rising and descending stair flights	(a) A comparative acceptance criterion is to be adopted, whereby the proposed alternative solution is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DS-compliant design, based on: (i) The potential for fire and smoke spread via the stairway between floors and the rising and descending stair flights and the potential for fire and smoke spread via the fire separation provided at the basement level. (ii) The potential exposure of occupants to fire as they evacuate via the stairway will be mitigated, based on the need to travel only two levels to evacuate.
5	Exit travel distances and travel distances between alternative exits (park park)	(a) A comparative acceptance criterion is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DS-compliant design. (b) A comparative acceptance criterion is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution from the subject Level 2 office is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DS-compliant design.
6	Exit travel distances (Level 2 office, G.F., Mezzanine)	(a) A comparative acceptance criterion is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution from the subject Level 2 office is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DS-compliant design.
7	Exit travel distances (Level 2 office)	(a) A comparative acceptance criterion is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution from the subject Level 2 office is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DS-compliant design.
8	Distances between alternative exits (Fireway G.S.)	(a) A comparative acceptance criterion is to be adopted, being that the potential for occupants to be exposed to the products of combustion for the proposed design is at least equivalent to (i.e. not greater than) that associated with the BCA DS-compliant design. (b) A comparative acceptance criterion is to be adopted, being that the potential for occupants to be exposed to the products of combustion for the proposed design is at least equivalent to (i.e. not greater than) that associated with the BCA DS-compliant design (being the result of the larger RSET for smoke filling) compensating for the reduced RSET (being a result of the longer travel distances).
9	Distances between alternative exits (Child care centre)	(a) A comparative acceptance criterion is to be adopted whereby the occupant evacuation time will be at least equivalent to (i.e. not greater than) that of the benchmark, BCA DS-compliant design, based on the need to travel only two levels to evacuate between places of relative safety not exceeding 60 m.
10	Swim school egress width	(a) Comparative acceptance criteria are to be adopted, whereby: (i) The ability for the proposed exit and pathway widths forming the basis of the Alternative Solution to facilitate the single-file passage of a 95th-percentile person is at least equivalent to that associated with the nominated, BCA DS-compliant benchmark design. (ii) The occupant movement time from the swim school is at least equivalent to that associated with the nominated, BCA DS-compliant benchmark design.

9.3

ENVIRONMENTAL AND LOSS CONTROL ACCEPTANCE CRITERIA
The building owner or any other stakeholders have not identified any specific environmental or loss control acceptance criteria.



10 FIRE SCENARIOS, OCCUPANT EGRESS SCENARIOS AND ANALYSIS SCENARIOS

This section presents the fire scenarios and occupant egress scenarios proposed for assessment of the alternative solutions against the relevant BCA performance requirements.

10.1 General Overview of Books

The types of fire scenarios for consideration can be categorised into three groups:

- (i) Smouldering fires
- (ii) Flaming fires
- (iii) Fully-developed fires

Each of these fire scenarios can generally be described as follows.

10.1.1 Smouldering fire

The IFEG⁴⁰ defines a smouldering fire as 'the solid phase combustion of a material without flames but with smoke and heat production'. When considering general building contents anticipated within the building, the context of smouldering combustion would generally occur prior to flaming combustion and represent a slower development (i.e. heat release rate) and generally less significant fire than a flaming fire. For this reason, a flaming fire scenario with a higher heat release rate and exclusion of incipient stage development is considered to be more onerous than a smouldering fire.

10.1.2 *Flamingo Alley*

A flaming fire is a fire that has developed beyond the smouldering phase to involve a non-flashover burning regime. Fully-developed conditions are unlikely to occur due to either occupant intervention or the operation of sprinklers, which are designed to suppress or control a fire to the area or room where ignition first occurs. Smoke spread within the compartment of fire origin is possible and will be considered in the analysis, with the extent of spread depending upon the location and size of the fire.

10.1.3 Fully-Developed Fire

A fully developed fire scenario involves fire growth without timely intervention by occupants, fire fighters or automatic sprinklers. This type of fire is usually controlled by the available ventilation or fuel within the compartment. Based on studies, the onset of a flashover condition is approximated when the ceiling temperatures of 600°C¹ or having a floor irradiance of 20 kW/m².

10.2 SPRINKLER RELIABILITY AND PERFORMANCE

As the assessment to be undertaken will place some reliance on the performance of the proposed automatic sprinkler system, review needs to be made of the expected reliability of such a system to demonstrate that a sprinkler-controlled fire scenario is a reasonable expectation.

A fire scenario coincident with sprinkler failure is considered to be rare event, as reported in literature for correctly designed, commissioned and maintained sprinkler systems.

England and Young¹⁰ estimated the reliability of automatic sprinkler systems to be approximately 95 per cent, based on Australian fire incident statistics collected by the Australasian Fire Authorities Council (AFAC) for the period 1989/90–1993/94. The same document also reported that the fire size was too small to operate the sprinkler needs in 77 per cent of the cases.

NSW data collected by FRNSW⁴⁴ in its Annual Statistical Report 2001/2002 indicates that for incidents where sprinklers were present and operated, the fire was extinguished in 70 per cent of cases and was prevented from spreading in a further 28 per cent of cases – for storage premises, all incidents involved extinguishment or control of the fire.



Antibiotics

within an office area, typically occurring as a result of electrical equipment overheating, electrical system faults, arson or smoking....

Based on a well-distributed fuel load within each level (office furnishings comprising desks, chairs, electrical equipment and various cabinets), the fire is assumed to be a fully developed fire, with smoke being generated by the fire. The fire is assumed to occur throughout the floor of origin. Sufficient smoke generation is expected to result in activation of the fire detection system for initiation of the building occupant warning system, with smoke spread throughout various parts of the floor of fire origin being possible.

The rate of growth of the fire's heat release can be approximated using a standard $(\dot{Q})^2$ rate of growth of the heat release rate ($\dot{Q}$ = escaped time, X = constant), typically selecting the early growth stages of fires involving a wide range of fuels. The rate of growth of the fire is approximated by the following growth rate ($t_c = 300$) is considered to be appropriate for a fire initiating within an office. Use of this design fire is based on research findings by Sandqvist¹⁰ and NIST¹¹ for the growth rates for typical office furnishings, where a number of fires involving typical office furnishings, such as workstations and the like, approximated a medium¹² growth rate.

The development would be governed primarily by the arrangement of fuels and the fire's growth rate. The fire is assumed to be fully developed and once the fire reaches its size adequate to limit further fire growth and minimize the probability for a fully-developed fire.

The initiation of the fire detection system would result in activation of the emergency warning system throughout the building.

The likelihood of fully-developed conditions occurring is low based on the presence of an automatic sprinkler system.

Marriott, L. W. (1986). Fire: A Century of Automatic Fire Protection in Australia and New Zealand 1860-1980. FPA, Australia.

NIST Fire Brigades, New South Wales Fire Brigades Annual Statistical Report 2012/2013, Sydney, 2013.

Sturgeson, S., Initial Fire Risk, Smoke Production and CO Generation from Single Items and Room Fire Tests, Lond, 1993.

National Institute of Standards and Technology (NIST), Fire on the Web, The Experimentals Results, web page <http://www.nist.gov/fire/news/initial.html>, accessed 19/06/04.

Exova
Measuring the world

Report No. ZMS-6700-P07701-8
Date: 6/24/77

Fire Location	Fire Scenario and Design Parameters
External fire scenario	External fire Fire development within the child care centre would be governed by the arrangement of fuels and the ability for either occupants or the fireguards to intervene to control the fire and limit further fire spread, which could occur through the fire door. The fire would be assumed to develop from a small fire (approximately 600 °C throughout the structure, which is also relevant on sufficient ventilation being available to the enclosure, is a phenomenon where all the combustibles within the room of origin are involved in the fire) and fully-developed conditions, within the same time period as the fully-developed conditions, based on the spread statistics presented previously. A flaming fire would be inferred to the area local to the seat of the fire and the item that ignited, either due to the scattered nature of the flames involved or by occupants or the fireguards, which would result in both the enclosure or the combustibles of the conditions, within the enclosure, and fully-developed conditions. Smoke spread could occur throughout various parts of the floor of fire origin.
Child care centre fire scenario	Fully-developed fire A fire initiating within the child care centre could become fully developed in a short period of time without intervention by occupants or fire fighters, with hazardous conditions being possible within the enclosure of the origin, given the nature of the fuels and the arrangement of the fuels. The fire would be assumed to develop from a small fire (approximately 600 °C throughout the structure, which is also relevant on sufficient ventilation being available to the enclosure, is a phenomenon where all the combustibles within the room of origin are involved in the fire) and fully-developed conditions, within the same time period as the fully-developed conditions, based on the spread statistics presented previously. A flaming fire would be inferred to the area local to the seat of the fire and the item that ignited, either due to the scattered nature of the flames involved or by occupants or the fireguards, which would result in both the enclosure or the combustibles of the conditions, within the enclosure, and fully-developed conditions. Smoke spread could occur throughout various parts of the floor of fire origin.
Neighbouring building fire scenario	External fire Fire development within the child care centre would be governed by the arrangement of fuels and the ability for either occupants or the fireguards to intervene to control the fire and limit further fire spread, which could occur through the fire door. The fire would be assumed to develop from a small fire (approximately 600 °C throughout the structure, which is also relevant on sufficient ventilation being available to the enclosure, is a phenomenon where all the combustibles within the room of origin are involved in the fire) and fully-developed conditions, within the same time period as the fully-developed conditions, based on the spread statistics presented previously. A flaming fire would be inferred to the area local to the seat of the fire and the item that ignited, either due to the scattered nature of the flames involved or by occupants or the fireguards, which would result in both the enclosure or the combustibles of the conditions, within the enclosure, and fully-developed conditions. Smoke spread could occur throughout various parts of the floor of fire origin.

- 65 Beltrushka, V., *Temperatures in Flames and Fires*, Fire Science and Technology Inc., Issaquah, WA, 1997, p. 292.
- 66 Drysdale, D., *An Introduction to Fire Dynamics*, Second Edition, p. 282, John Wiley & Sons, West Sussex, England, 1998.
- 67 Beltrushka, V., *Temperatures in Flames and Fires*, Fire Science and Technology Inc., Issaquah, WA, 1997.



Exova
Marketing

10.4 **Discontinuing Fire Scenario**
A propagating fire scenario is not considered, based on the low hazard posed. It is considered that an email fire that generates a moderate or small quantity of smoke over an extended period of time is not a hazard that would readily facilitate fire spread to the extent that the more severe design fire could.

10.5 **Assumptions**

- 65 Beltrushka, V., *Temperatures in Flames and Fires*, Fire Science and Technology Inc., Issaquah, WA, 1997, p. 292.
- 66 Drysdale, D., *An Introduction to Fire Dynamics*, Second Edition, p. 282, John Wiley & Sons, West Sussex, England, 1998.
- 67 Beltrushka, V., *Temperatures in Flames and Fires*, Fire Science and Technology Inc., Issaquah, WA, 1997.

are considered in this report in accordance with the Engineers Australia Society of Fire Safety Code of Practice.

The above mentioned fire scenarios are considered to be representative of an arson fire from a single ignition source in terms of fire severity. Major incidents of arson, involving accelerants and/or multiple ignition sources, are beyond the scope of this analysis, and are excluded from this report.

PART B – FIRE ENGINEERING ANALYSIS

11 **ALTERNATIVE SOLUTION 1 – FIRE RESISTING CONSTRUCTION TO WAREHOUSE AREAS**

Assessment Criteria

Table 11.1 provides a summary of the criteria for consideration as the basis of this Alternative Solution.

Table 11.1 – Assessment criteria

Issue Identification	Cause Analysis
Applicable BCA DIS provisions	BCA Specification G1.1 stipulates that building elements are to have fire resistance levels (FRLs) in accordance with Table s of Specification C1.1, being, for the subject development, 240/240/240 FRLs to the warehouse areas, 120/120/120 FRLs to the office areas, 90/60/60 FRLs to the sprinkler-protected car parking areas.
Proposed Alternative Solution	The proposed alternative solution is based on: (i) the provision of a 120/120/120 FRL fire walls; (ii) 240/240/240 FRL to the warehouse areas; (iii) the presence of an automatic sprinkler system within the building, except for the swim school; (iv) The low-rise design of the building; and (v) The significant distance from neighbouring buildings. Qualitative assessment based on BCA A0.5(3) "omitting an Alternative Solution which complies with the Performance Requirements" and A0.9(b)(iii) "such other Verification Methods as the appropriate authority accepts" for determining compliance with the Performance Requirements". Based on a direct assessment against the performance requirements, the methods of analysis to be undertaken will comprise: (i) Determination of the potential time to failure for the occupants of the affected office and mezzanine areas as follows: - detection time – based on either the occurrence of a visual cue upon formation of a layer of smoke across the enclosure that is at least 5 per cent of the height of the enclosure or activation of the sprinkler system. - pre-movement time – based on the recommendations of Frenchin for open plan buildings for open areas or Sims for compartmented movement time – based on the methodologies and recommendations of Nelson & Mowrer, Peule and Sims. For a person with an average mobility, an unobstructed evacuation speed of 1.19 m/s has been reported by Nelson & Mowrer ⁸⁷ , whilst for people with disabilities such as a walking frame, an evacuation speed of 0.57 m/s was reported by Frenchin ⁸⁸ . In a medium speed of 0.5 m/s down a stair as reported by Probst ⁸⁹ , these unobstructed distances will be less than 0.54 persons/m ² *, however, as the building may contain some occupants with disabilities, an evacuation speed of 0.3 m/s will be used. (ii) Determination of the potential time at which the proposed structural failure would occur, taking account of the following: (a) Completion of the potential time of structural failure with the occupant evacuation time. (iv) Consideration of approximation of the likely fire brigade intervention time to completion of water. Absolute acceptance criteria are to be adopted, being that structural failure and the spread of fire to the non-fire-affected sides of the compartment barrier and collapse onto adjacent buildings is mitigated by the performance of the sprinkler system, the fire-fighting works conducted with the fire brigade intervention time and the resulting works order to achieve the required level of safety.
Methods of analysis	Acceptance criteria

ALTERNATIVE SOLUTION 2 - DRENCHER-PROTECTED GLAZED WALL ASSEMBLIES AND OPENINGS IN FIRE ISOLATED EXITS

12.1 Assessment Criteria

Table 11.1 provides a summary of the criteria for consideration as the basis of this Alternative Solution.

Table 12.1 – Assessment criteria

BSI 1251 - Assessment Criteria	Criterion
	Clause C1.1 nominates compliance with Specification C1.1, which for a Class 1 fire door requires the door to be constructed in accordance with BS 476: Part 3, and to be tested to BS 476: Part 8. The specification stipulates an FRL of 120/120/120 FRL fire resisting fire and structural. Clause C2.7(b)(ii) stipulates that any openings in a fire wall must not reduce the fire resistance of the wall. Clause C1.1 stipulates that the door must be permitted by the Deemed-to-Satisfy provisions of Part C3. Clause C3.9 of the BCA stipulates that if a building has parts of different classifications located alongside one another in the same story, each building element must have a higher FRL profile than the other. Clause C3.8 of the BCA stipulates that doorways which open into fire-rated areas must be protected by 70/30 fire doors that are self-closing or automatic-closing in accordance with C3.8(c).
Applicable BCA DTS provisions	The proposed alternative solution is based on: - The provision of a drencher-protected glazing in lieu of 120/120/120 FRL to the ground floor entry lobby of the swim school and Star 2; - The provision of drencher-protected glazed doors to Star 1 in lieu of fire doors; and - The presence of an automatic sprinkler system within the building, accepted for the purposes of the proposed alternative solution.
BCA assessment method	Qualitative assessment based on BCA A0.50(1) "formulating an Alternative Solution which complies with the Performance Requirements" and A0.9(b)(ii) "such other Verification Methods as the appropriate authority accepts for determining compliance with the Performance Requirements". Based on a direct assessment against the performance requirements, the methods of analysis to be undertaken will be qualitative and quantitative in nature and will comprise of: - A review of the extent of fire spread between zones separated via drencher protected glazing, based on review of test data for barrier systems in relation to the integrity of glazing systems during exposure to elevated temperatures commensurate with the nominated fire scenarios and calculation of potential radiant heat flux value in relation to radiant heat flux values for the proposed barrier systems; considering the protection of the glazing by the automatic sprinkler system; - A review of the adequacy of operable elements (i.e. doors) in the glazed installations.
Methods of analysis	Absolute acceptance criteria are to be adopted, being as follows: - For the glazing barrier construction, the radiant heat flux received on the non-fire-affected side of the barrier where combustibles may be located does not exceed 20 kW/m²; - For the glazed barrier, the radiant heat flux received on the non-fire-affected side of the barrier where combustibles may be located does not exceed 20 kW/m²; - For the glazed barrier, the radiant heat flux received on the non-fire-affected side of the barrier where combustibles may be located does not exceed 20 kW/m²;
Acceptance criteria	(i) The radiant heat flux received on the non-fire-affected side of the barrier where combustibles may be located does not exceed 20 kW/m²; (ii) The radiant heat flux received on the non-fire-affected side of the barrier where combustibles may be located does not exceed 20 kW/m²; (iii) The radiant heat flux received on the non-fire-affected side of the barrier where combustibles may be located does not exceed 20 kW/m²;

Consideration	Other relevant sub-systems from the International Fire Engineering Guidelines are considered: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread, Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Relevant performance requirements	CP2.

122 First Engineering Assessment

12.2.1 Intent of the D19 Provisions for Fire Resistance Levels

In relation to fire resistance levels for various elements of construction, the BCA DIs provisions match specific fire resistance levels with each occupancy class, with those that are considered to feature higher fire loads, such as retail and industrial use, given higher FRLs (2-3 hours) and those that are considered to feature lower fire loads, such as residential, health care and office use, given lower FRLs (1-2 hours).

This recognises the need to address life safety, fire brigade intervention and adjacent property, as outlined by Objective C01 of the BCA, as follows:

- (e) safeguard people from illness or injury due to a fire in a building; and
- (f) safeguard occupants from illness or injury while evacuating a building during a fire; and
- (g) facilitate the activities of emergency services personnel; and
- (h) avoid the spread of fire between buildings; and
- (i) protect other property from physical damage caused by structural failure of a building as a result of fire.

The intent of FRLs for Type A construction has been discussed in Fire Code Reform Centre's Project 3, Part 1⁷⁶ as enabling the building or compartment of fire origin to "survive burnout and (the) occupants (to) escape to a place of safety". As such, the intent of BCA Specification C1.1 with respect to FRLs and the associated FRLs assigned to elements separating different classifications is considered to be to allow the building to adequately resist the effects of a fire, thereby limiting the potential for extensive fire spread and structural collapse.

12.2.2 Intent of the BCA DYS Provisions for Fine-Isolated Entities

The Guide to the BCA⁵⁰ states that the intent of Clause C3.8 is:

To maintain the integrity of a fire-isolated exit and to protect people using fire-isolated exits by providing adequately protected door and window openings.

12.2.3 Proposed Alternative Solutions

The proposed alternative solution is based on the provision of a drencher-protected glazing in lieu of 120°/120°/120° FRL to the ground floor entry lobby of the swim school, Stair 1 and Stair 2.

78 Australian Building Codes Board, ABCB, International Fire Engineering Guidelines Edition 2005, Australian Building Codes

70 Board, Australia, 2005.
 Elm Code Reform Centre (ECRC). Protect 3 Elm Resistance and Non-Combustibility Part 1: Objectives & Performance | au

for Fire Resistance, FCRC, October, 1996.

80 Australian Building Codes Board (ABCB), BCA 2014 Class 2 to 9 Buildings, Australian Building Codes Board, Canberra
Australia


Report No. 2005-1700-RPT01-6
Page 71 of 120

Figure 12.1 – Proposed Drinker-protected clearing on Ground Floor

Report No. 2800-1700-REPORT-18
Date: 7/9 of 1700




Figure 12.3 – Proposed Drencher-protected glazing on Level 2

1224

The risk of fire spread the ground floor entry lobby of the swim school via the carpark area and to Sair 1 and Sair 2 via the adjacent areas (office area and cloakroom centre) is to be assessed for the glazed, clasher-protected portion. The wall separating the ground floor entry lobby of the swim school, Sair 1 and Sair 2 comprises a combination of fire resisting construction and glazed construction components providing a complete physical barrier to the ground floor entry lobby of the swim school, Sair 1 and Sair 2.



The risk of furnishings and other combustibles being situated in proximity to the drencher-protected, glazed bounding construction and compromising the flow of water down the face of the glazing will be mitigated as the adjacent spaces comprise an undercroft carpark and lobby areas where furniture would be neither processed nor suitable for the area.

The drenchers will be located on the carpark side and lobby side of the glazing, designed to cover the entire glazed areas with water at a design density sufficient to prevent the breakage of the glass and the passage of fire through the barrier.

The effectiveness of the drencher system will be dependent upon the design of the glazing, including the support structure of the walls. Standard float plate glass is prone to failure at temperatures as low as approximately 120°C¹, which will generally be inconsistent with the performance capability of an automatic drencher system with respect to minimum drencher head activation temperatures. As a result, glass that is not susceptible to failure at such low temperatures is to be provided, with toughened glass satisfying this requirement.

The support structure for the glazing is required to be considered for reasons of expansion under elevated temperatures. The elevated temperatures that could be experienced during a fire within the building could result in the heating and expanding of the glazing and its framing system, despite the action of the dampers in cooling the surface. As the glazing is to be provided with flexible seals between the head/bottom of the glass panels and the frame, adequate levels of expansion are expected to be catered for under the elevated temperatures associated.³¹

Consideration needs to be made in the alternative solution of the potential for the spread of fire from one side of the glass to the other by way of radiation, which is transmitted through the glazing and received at locations on the adjacent area where combustible linings or furnishings may be found. Research has demonstrated a reduction in transmitted radiant heat through non-drencher-protected glazing of 35-45 per cent and a reduction through drencher-protected glazing of at least 90 per cent exposed to the drencher for thirty and thirty-two minutes respectively.



only. As the levels of incident flux at which timber and cotton fabric will ignite by non-petioled flames are 20 kW/m² and 25 kW/m² respectively, the level of incident flux is not expected to be necessary to cause spontaneous ignition of combustible furnishings that may be located within the balcony.

For the most probable design fire involving a single-compartment fire from the carpark, the exposure at the glazing will be minimal. Referring to the calculation presented in Figure 12.4, utilising the Radiation sub-routine within FireCalc[®], radiant heat flux will be mitigated as a result of the low temperatures and radiant heat flux commensurate with such conditions. That is, a temperature of up to 200°C would result in a radiant heat flux of less than 3 kW/m² at the source, which does not exceed the ignition criteria of 20 kW/m². This exposure will be further reduced by the operation of the fire-fighting system if sufficient heat were to result in activation of the detector heads.




Figure 12.4 – Radiant Heat Flux received at Detector Protected Glazing

Further consideration is given to severe scenarios as part of a sensitivity analysis. A fire of winter conditions is considered, with a fire of 600°C (or ~ 32 kW/m²) based on a severe scenario where the radiation source consists of a black body, would result in a transmitted radiant heat flux within the adjoining areas of approximately 3 kW/m², where the glazing acts to reduce transmission through the glass by up to 90 per cent, as discussed above. It is therefore unlikely that the level of transmitted radiant heat flux could result in spontaneous ignition occurring within the adjoining areas noting that there is also in the way of combustibles in this location.

Based on the maximum radiation flow of 2.3 kW/m² (2.28 W/m²), a tolerance time of at least 5 seconds is provided, based on the data provided by The SPRE Handbook of Fire Protection Engineering⁶², as shown in Figure 12.5 below. However, occupants are expected to be exposed to

62. Hudson, A.V. and Graham, S., *Water Cisterns to Shield Glass from Radiant Heat from Building Fire*, Technical Report 422, Experimental Building Station, Department of Housing and Construction, New South Wales, 1975.
63. Kouskoumaki, J.K., A. Choudhury, L. The Tests on Window Assemblies Protected by Automatic Sprinklers, National Research Council Canada, 1997.
64. Dymally, D., *An Introduction to Fire Dynamics*, Second Edition, University of Edinburgh, UK, 1999.
65. Standards Australia, AS 1530.4-1997 Methods for the tests on building materials, components and structures Part 4: Fire resistance tests, 1997.
66. CSIRO, FIRECALC, Version 2.2, CSIRO Division of Building Construction and Engineering, 1993.
67. SPRE Handbook of Fire Protection Engineering, Third Edition, Society of Fire Protection Engineers and National Fire Protection Association, 2002.

12.2.5 Fire Spread between buildings

Consideration is given to the impact of a 'severe', fully-developed fire within the subject building, which could result in enclosure temperatures of up to approximately 850°C. The potential for fire spread to a neighbouring building will be reliant on a number of outcomes, being:

- Failure of the internal structural elements in the subject building;
 - Instability and failure of the structural roof elements, leading to displacement of the roof decking; and
 - Exposure of the neighbouring building to the compartment fire of the subject building.
- Such a severe fire would involve the generation of a number of cases, such that occupants within the subject and neighbouring buildings could be expected to be aware of the configuration prior to the fire spreading to the neighbouring building. The fire would be expected to be contained within the subject building to such a fire would be limited by the warning time available.
- Further to this, the southern portion of the building and the closest southern neighbouring building is separated by a fire-resisting wall. The fire would be expected to be contained within the subject building to such a fire would be limited by the warning time available.

12.2.6 Occupant evacuation

The design of the building with respect to mitigation of fire spread between the main school and the carpark, Stair 2 and the carpark, Stair 1 and the carpark, Stair 1 and the Level 1 office and Stair 1 and the children's facility is required to be assessed in terms of its impact on occupant fire safety in the event of a fire.

It has been demonstrated above that the provision of the detector-glazing system, will enable the spread of fire between the subject areas to be mitigated. As such, the period of time available for evacuation and, therefore, the fire hazard imposed on the occupants, will not be affected by the proposed alternative solution.

12.2.7 Fire Brigade intervention

Assessment of the effects on fire brigade intervention of the proposed alternative solution has been made to ascertain that the design does not adversely affect fire-fighting activities.

The assessment undertaken above has determined that the uncontrolled spread of fire in most cases is mitigated by the proposed fire safety strategy, as a result of the detector-protected glazing and automatic sprinkler system provided throughout the building. The reliability of sprinkler systems in the event of a fire is well established, and the system is designed to provide the means to only activate occupant evacuation and fire-fighting during occurrence of small, controlled fires.

It is only in the rare case of a severe, uncontrolled fire, where the occupants have not been able to evacuate the building, that the fire-fighting system would be required to activate. In such a case, the fire-fighting system would be required to activate to evacuate occupants that may have been exposed to the effects of the fire, however, the reliability of the sprinkler system has been discussed previously as being in excess of 95%.

Due to the mitigation of fire spread, as discussed, fire brigade intervention activities will therefore not be adversely affected by the proposed alternative solution, involving the subject variations in FRLs to the stair and lobby fire compartmentation.

12.3 Summary

The assessment undertaken above demonstrates that the proposed glazed barrier construction to the ground floor entry lobby of the swim school and Stair 2 and the provision of an automatic sprinkler system to the building is considered to facilitate an acceptable level of fire and life safety in minimising the risk of fire spread between the ground floor entry lobby of the swim school and Stair 2 resulting from the proposed construction complying detector-protected glazing.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for the assessment in section 8.

the opening for not more than a few seconds as they evacuate past the opening. It is therefore considered that the design of the building is not expected to be adversely affected by the radiant heat to evacuating occupants and allowing sufficient time before occupants are affected by the fire.



Figure 12.5 – Exposure data from SPRE Handbook of Fire Protection Engineering

The provision of an appropriately-designed glazing system, protected with detectors as discussed, is therefore expected to be capable of maintaining the spread of fire by modes of either conduction / convection (physical failure of the barrier) or radiative heat flux.

In the case of use of the Tyco Model WSTN detector system, it is noted that the design of the detector-glazing system is not expected to be adversely affected by the radiant heat to evacuating occupants and allowing sufficient time before occupants are affected by the fire.

In addition, within the exception of the swim school, the building is to be provided with an automatic sprinkler system as discussed above. A high level of performance can be associated with the sprinkler system. Sprinkler activation and control will generally serve to prevent flashback occurring and restrict the potential for the rapid fire spread throughout an enclosed area or to an adjacent area, such as to an open plan space or to adjacent areas.

Now that the building will have a fire in storey of only three, being well under 25 metres in effective height such that it is not considered to fall within the definition of a high-rise structure, the fire-fighting system is not expected to be adversely affected by the radiant heat to evacuating occupants and allowing sufficient time before occupants are affected by the fire.

It is also noted that the glazed barrier construction is non-rated bearing. Failure of the construction will not directly affect the performance of any of the building structural elements.

68. Tyco Fire Protection, installation brochure 'Tyco Model WSTN – 5.8 K-Hazard Specific, Application Window Sprinklers, Horizontal and Pendant Version Schem', Tyco Fire Protection, Pennsylvania, 2005.

13 ALTERNATIVE SOLUTION 3 - EXTERNAL WALL LINING

13.1 Assessment Criteria

Table 13.1 provides a summary of the criteria for consideration as the basis of the Alternative Solution.

Table 13.1 – Assessment criteria	
Consideration	Criterion
Applicable BCA	Clause C1.1 of the BCA refers to Clause 3.1(b) of Spec. C1.1 which stipulates that the external wall of a building shall be constructed in accordance with the provisions of AS 1530.4-1997.
Dis Provisions	The proposed alternative solution is based on: (i) The provision of Dupon, and Alabond Plus as cladding to various parts of the external walls, which have not been listed as 'non-combustible' in accordance with AS 1530.1; and (ii) The presence of an automatic sprinkler system within the building, except for the swim school.
Proposed Alternative Solution	Qualitative and quantitative assessment, based on BCA A0.50(9) 'terminating an alternative solution which complies with the Performance Requirements and AS 1530.4-1997'.
BCA assessment method	Based on qualitative assessment, the method of analysis to be undertaken will comprise a qualitative review and determination of the extent of fire spread between buildings and vertical fire spread between storeys via the facade, based on the presence of a sprinkler system throughout the building (except for the swim school), the location of the wall linings and the proximity of the wall linings to other combustibles and occupants.
Methods of analysis	Qualitative assessment criteria are to be assessed, namely: (i) The extent of fire spread between buildings via the external walls; and (ii) The potential for the spread between storeys will be mitigated by way of the design and location of the design and location of the proposed linings.
Acceptance criteria	The relevant sub-system from the International Fire Engineering Guidelines ⁶⁹ are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression
Fire Engineering Guidelines	
Relevant Performance Requirement	CR2.

13.2 Fire Evacuation Assessment

13.2.1 Intent of the BCA DSS Provisions for Fire Hazard Properties

Specification C1.1 of the BCA includes provisions to limit the combustibility of a number of elements of construction for buildings of Type A construction.

The requirement relating to the non-combustibility of external walls can be placed to the potential for wall-to-wall spread between storeys in the same building and the potential for fire spread between buildings.

As such, the performance of the design to be assessed (researcher is that relating to the ability of the combustible external wall to avoid the spread of fire between storeys and from the neighbouring storeys).

13.2.2 Proposed Alternative Solution

The proposed alternative solution is based on the provision of Dampson and Alabond Plus to form part of the external wall, which have not been tested as 'non-combustible' in accordance with AS 1530.1.

It is noted that the Cockburn certification for the product states that when used in buildings of Type A construction, the building must be sprinkler protected throughout, as shown in Appendix G. The subject development is sprinkler protected throughout with the exception of the swim school tenancy.




Figure 13.1 - Location of proposed Dampson wall lining




Figure 13.2 - Location of proposed Alabond Plus wall lining

13.2.3 Vertical Fire Spread

Fire At Subject Development Initiating Hazard

Fire severity within the building will primarily be influenced by the performance of the proposed automatic fire sprinkler system, which, based on the statistics discussed previously, is expected to




Figure 13.3 - Proximity of Subject Building to Neighbouring Buildings

Direct flame impingement is therefore extremely unlikely to occur, based on the closest buildings being the warehouse and the childcare centre. The proximity of the warehouse and the childcare centre, which further reduce the potential for ignition of the building when exposed to a fire in another building.

The potential for the spread of fire by way of radiation is dependent upon the locations where combustible linings or furnishings may be found. The proximity for fire spread from a neighbouring building via radiant heat is therefore unaffected by the inclusion of the proposed Alabond Plus and Dampson wall lining, based on the potential for exposure of combustibles at the building located being mitigated via asbestos on the neighbouring property and the wall linings being clad onto concrete construction. Further to this, the lack of any situation on site of external openings in the form of windows or doors, which could allow fire to spread from the neighbouring building to the subject building, is also noted. The resulting propagation of the fire within the building is also noted. This is supported by the following research findings of Fire Code Research Centre's Project 2 B-205, which indicate that a fire in the subject building is likely to result in a greater exposure severity than a fire in another building:

"Exposure of combustible cladding to a fire source feature (e.g. exposure due to fire in an adjacent building) is also unlikely to be a governing consideration for vertical fire spread as the expected received heat fluxes on the cladding due to a fire source feature are likely to be less than that produced by a external window fire plume in the region of fire state. This addressing the potential for fire spread from a neighbouring building to the subject development to include the proposed Alabond Plus and Dampson wall lining, based on the potential for exposure of combustibles at the building located being mitigated via asbestos on the neighbouring property and the wall linings being clad onto concrete construction."

As a result, the combustibility of the proposed wall linings is not considered to have an impact on the potential for fire spread from a neighbouring building to the subject development to include the proposed Alabond Plus and Dampson wall lining, based on the potential for exposure of combustibles at the building located being mitigated via asbestos on the neighbouring property and the wall linings being clad onto concrete construction.

Notes that in relation to the impact of fire suppression systems, the building's fire load and the fire compartmentation status do not affect the potential for the fire spread from the neighbouring building, only to the neighbouring buildings, which it is to be considered below.

Fire Spread to Neighbouring Buildings

For the unlikely case involving a fully-developed fire, the contribution of the combustible external cladding to the spread to a neighbouring building will be mitigated based on the wall lining being clad to concrete construction.



control the outbreak and spread of fire for at least 95 per cent of incidents where the fire is of a size that is sufficient to activate the sprinklers.

A non-activated fire, being one that is either insufficient in severity to operate the sprinkler system or cannot be able to be controlled by the sprinkler system, would result in relatively low exposure temperatures within the building.

For the Alabond Plus, comparable asbestos panel lining, the non-combustible (unfurnished) cladding material is also noted to be a contributing factor to the potential for fire spread from the building. The Alabond Plus is also checked onto concrete, mitigating the risk of the spread into the building.

It is also considered that the building of a fully-developed fire occurring is being mitigated by the presence of trained staff as a measure that could undertake either fire self investigation or raise an alarm during the early stages of a fire.

Fire severity within the swim school will primarily be influenced by the proposed fire load levels. The classification of the building is severely limited (i.e. typically dry, moist, solid, and additional training), which results in a relatively low fire load. However, the use of the subject building primarily relative to a swim school, with bobby areas and change rooms having minimal combustibles and fuel load. Fuel loads within the swim school may comprise fixed furniture, the reception desk, chairs and benches. Furnishings typically associated with the majority of class 95 assembly buildings, comprising items such as tables, chairs and kitchen equipment will therefore be limited.

Fire At Subject Development Initiating Hazard

The likelihood and potential development of an external fire that involves the wall linings of the subject building will be influenced by the following features:

- The area immediately around the building to the southern facade is dedicated to circulation and access space, restricting the ability for storage or accumulation of rubbish within immediate proximity of the facade.
- The area immediately around the building to the northern facade comprises landscaping and is generally non-accessible to occupants.
- The eastern facade where the Alabond Plus is proposed is only over a single level on the subject tenancy. The spread between levels is therefore mitigated based on the fire dissipating across the roof.

It should also be noted that the risk of a fire originating on an external wall of the building is relatively low, based on the fire load of the building. The fire load of the building is relatively low, based on the fire load of the building. The fire load of the building is relatively low, based on the fire load of the building.

13.2.4 Fire Spread Between Buildings

The risk of fire spread occurring between properties is largely dependent upon the following factors:

- (i) the layout and severity of a fire, which, in turn, is influenced by the compartment size, fuel load and fire suppression systems
- (ii) proximity to neighbouring properties
- (iii) the extent of openings in the external envelope of the building

These factors are reviewed hereunder.

Fire Spread from Neighbouring Buildings

As discussed within Fire Code Research Centre Project 3¹¹, the original intent of control of external wall combustibility was not intended to address direct flame impingement from adjoining buildings but to address radiant heat exposure only.

There is minimal exposure to adjoining properties for facilitation of fire spread, as the proposed development includes:

- a public roadway to the north
- the Stage 1 development to the east



13.2.5 Fire Hazard Properties of the Proposed Alabond Plus

It is noted that the Alabond Plus is a group 1 material, as defined in Specification C1.10 of the BCA. The material is classified as a group 1 material, as defined in Specification C1.10 of the BCA. The material is classified as a group 1 material, as defined in Specification C1.10 of the BCA.

Other mitigating factors include the presence of an automatic sprinkler system throughout the building (except for the swim school, the low fuel loads exposed within the swim school and the concrete wall between the proposed wall linings which contribute to the unlikelihood of impact to adjacent tenancies).

Furthermore, in the unlikely event where either the Dampson or Alabond Plus claddings are exposed to a fire, the fire load of the building is relatively low, based on the fire load of the building.

Fire Mitigation Intervention

The assessment undertaken above has determined that the spread of smoke of the wall lining is mitigated by the proposed fire safety strategy, as a result of the presence of an automatic sprinkler system throughout the building, with the exception of the swim school, the low fuel loads to the swim school and the location of the proposed wall linings which do not result in the spread of smoke between levels as part of the proposed alternative solution.

It is only in the rare case of a severe, uncontrolled fire, where the Dampson and Alabond Plus is exposed to a fire which results in smoke development and spread from the subject wall lining. However, as discussed above, smoke is expected to be dissipated if the material does during a fire. The fire load of the building is relatively low, based on the fire load of the building.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for the assessment in Section 8.

13.3

The assessment undertaken above demonstrates that for the proposed Dampson and Alabond Plus wall lining within the building, the potential for vertical fire spread and the potential for fire spread between buildings will be mitigated, based on the presence of an automatic sprinkler system to throughout the building (except the swim school), the location of the wall lining and the proximity of the wall lining to other combustibles and occupants.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for the assessment in Section 8.



14 ALTERNATIVE SOLUTION 4 – NON-PROVISION OF FIRE-ISOLATED STAIRWAYS AND SEPARATE RISERS AND DESCENDING STAIR FLIGHTS

14.1 Assessor's Criteria

Table 14.1 provides a summary of the criteria for consideration as the basis of this Alternative Solution.

Table 14.1 – Assessment criteria	
Consideration	Criterion
Applicable BCA DLS provisions	Clause D1.3 of the BCA stipulates that for Class 5 to 8 buildings, every stairway serving as a required exit must be fire-isolated unless it connects, passes through or is adjacent to, or not more than three consecutive storeys if the building has a sprinkler system.
Proposed Alternative Solution	Clause D2.4 of the BCA stipulates that if a stairway serving as an exit is required to be fire-isolated, the building must have a fire-isolated stairway that is not more than three storeys below the lowest level of access to a road or open space and a flight descending from a storey below that level. The proposed alternative solution is based on: (i) Stair 1 which is not fire-isolated and does not feature separation via rising and descending stair flights (ii) Stair 2 which is not fire-isolated and does not feature separation via rising and descending stair flights (iii) The presence of an automatic sprinkler system within the building, except for the exitmarch. (iv) The 2 hour fire separation provides between the stairways and basement carpark level, and (v) Occupants travelling a maximum of two levels to evacuate. Qualitative and quantitative analysis, based on BCA AD50(9) is shown to be at least equivalent to the Deemed-to-Satisfy Provisions⁹⁰ and AD51(6) Comparison with the Deemed-to-Satisfy Provisions⁹¹.
BCA assessment method	Based on a comparative assessment, the methods of analyses to be undertaken are complete:
Acceptance criteria	(i) Determination for the potential for fire and smoke spread via the stairway between storeys and between rising and descending stair flights, based on the fire compartmentation provided from the basement carpark level. (ii) Determination of the potential exposure of occupants to fire during evacuation via the stairway, based on the fire compartmentation provided from the basement carpark level. (iii) Comparison with a BCA DLS design comprising a three-storey, sprinklered building complying with D1.3(1)(b)(i) and inter-connection of three storeys by internal non-fire-isolated stairways. (iv) Review of the ability for occupants to navigate out of the stairway during a fire in proximity to the stairway, based on visual windflicking associated with the transparent (glazed) stairway construction. A comparative acceptance criterion is to be adopted, whereby the proposed alternative solution is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DLS-compliant design, based on the stairway between storeys and between rising and descending flights will be mitigated, based on the fire separation provided at the basement level, and (ii) The potential exposure of occupants to fire as they evacuate via the stairway will be mitigated, based on the need to travel only two levels to evacuate.

Consideration	Criterion
IFED sub-systems	The relevant sub-system from the International Fire Engineering Guidelines⁹² are considered to be: - Sub-system A – Fire Initiation and Development and Control - Sub-system B – Smoke Development and Spread and Control - Sub-system C – Fire Spread and Impact and Control - Sub-system D – Fire Detection, Warning and Suppression - Sub-system E – Occupant Evacuation and Control - Sub-system F – Fire Services Intervention
Relevant performance requirement	DPS and EP2.2.

14.2 Fire Engineering Assessment

14.2.1 Intent of the DLS Provisions for Fire Isolated Stairways

The BCA DLS provision for the protection of stairways relates to both the nature of the occupancy and the number of storeys that occupants must pass to reach a final exit from the building.

The Guide to the BCA⁹³ states that the intent of clause D1.3 is:

To indicate when fire-isolated stairways and ramps are required to enable safe egress in case of a fire.

The BCA separately permits two storeys to be connected via non-fire-isolated stairways and three storeys in the case that the building is sprinkler-protected throughout, or fire separation of the stairway. Where an additional storey is served by a stairway, the BCA addresses the additional time required for occupants to evacuate by the effectiveness of the sprinkler system in controlling the fire or minimises the potential for occupants to be exposed to fire and smoke during evacuation.

The Guide to the BCA⁹⁴ states that for a Class 5-8 building, other than Class 8c:

An extra storey of any classification may be included under certain circumstances where the fire risk associated with the extra storey is low. The circumstances are:

- where the extra storey is used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes.
- where the extra storey is used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes.
- where the extra storey is used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes. In Class 2 buildings, the extra storey may be used for a carpark or other ancillary purposes.

where the exit is separated from the extra storey by walls having an FRL consistent with those required for a public corridor in a Class 2 or 3 building. By having separating walls with an FRL, and by preventing any connection to the extra storey for the purpose of providing access to or egress for fire storey, the non-fire-isolated exit is protected from the fire risk associated with the extra storey.

The Guide to the BCA⁹⁵ states that the intent of clause D2.4 is:

To minimise the risk that an occupant mistakenly passes the lowest storey providing escape when evacuating.

⁹⁰ Australian Building Codes Board, ABCB, International Fire Engineering Guidelines Edition 2005, Australian Building Codes Board, 2005.

⁹¹ Australian Building Codes Board (ABCB), Guide to the BCA 2014, Australia, 2014.

⁹² Australian Building Codes Board (ABCB), Guide to the BCA 2014, Australia, 2014.

⁹³ Australian Building Codes Board (ABCB), Guide to the BCA 2014, Australia, 2014.

14.2.2 Details of the DLS-Compliant Benchmark Design

The hypothetical, DLS-compliant benchmark design is based on the following provisions:

- (i) a three-storey, sprinklered building complying with D1.3(1)(b)(i);
- (ii) the inter-connection of three storeys by internal non-fire-isolated stairways; and
- (iii) an automatic fire sprinkler system being provided throughout the building, as described above.




Figure 14.1 – BCA DLS-compliant benchmark design

14.2.3 Details of the Proposed Alternative Solution

The proposed alternative solution is based on the following provisions:

- (i) Two stairs (Stair 1 and Stair 2) which does not feature separate rising and descending stair flights;
- (ii) The presence of an automatic sprinkler system within the building;
- (iii) The 2 hour fire separation provides between the stairways and basement carpark level, as shown in Figure 14.2; and
- (iv) Occupants travelling a maximum of two levels to evacuate, as shown in Figure 11.2.




Figure 14.2 – Proposed alternative solution




Figure 14.3 – Proposed alternative solution

14.2.4 Fire and Smoke Spread

BCA DLS compliant design

A hypothetical design that complies with the BCA DLS stipulates will be used as the 'benchmark' design for comparison of the proposed alternative solution. This BCA DLS compliant design would comprise non-fire isolated stairs connecting three storeys.

An automatic sprinkler system would be installed throughout the building, mitigating the risk of fire spread. The sprinkler system would be installed throughout the building, mitigating the risk of fire spread. The sprinkler system would be installed throughout the building, mitigating the risk of fire spread.

Fire severity within the building would primarily be influenced by the performance of the sprinkler system, based on the methods discussed previously. It is expected to control the outbreak and spread of fire for at least 95 per cent of incidents where the fire is of a size that is sufficient to activate the sprinklers.

Alternative solution

Referring to Figure 14.3, the fire-isolated Stair 1 and the non fire-isolated Stair 2 extends from the basement carparking level to the ground floor, Level 1 and Level 2. The stairs are not directly connected to the basement carparking, such that the stairs do not directly connect more than three storeys.

Similarly to the BCA DLS compliant design, an automatic sprinkler system forms part of the alternative solution. A high level of performance can be associated with the sprinkler system, as previously discussed.

The risk of fire and smoke spread via the subject stairways is therefore limited to three storeys for both the DLS-compliant design and the proposed alternative solution. Smoke stairways from basement carparking downwards are considered to be minor and can vent directly to open space at Ground Floor. Rising and descending stair flights are not considered to be required in this instance based on the initial level of the separation provided for the BCA DLS design and alternative solution.

Occupant Evacuation

The assessment above demonstrates that the risk of the spread of fire and smoke to the subject fire-isolated exit stair is limited to three storeys only, as the basement carparking is separate – this is similar to the benchmark, DLS-compliant design, whereby a non-fire isolated stairway can serve two storeys and an extra storey of any classification given that the building is sprinkler protected.

In both the BCA DLS compliant benchmark case and the alternative solution, occupants will be required to travel a maximum of two levels beyond the floor of fire origin to evacuate.

The potential exposure of occupants located on a non-fire-affected floor to the effects of fire will therefore also be mitigated to an extent equivalent to the DS-compliant design.

The exposure of occupants to fire and smoke is considered to be equivalent for both designs based on the alternative solution comprising the separation at the exit on basement level.

Due to the glazing construction, occupants will be able to see the lobby outside the stair and identify the level of discharge. Similar to normal wayfinding, occupants will be able to follow the exit signage when the stair.

Thus, the proposed design is considered to result in an evacuation time and fire hazard to the occupants that is at least equivalent to that of the DS-compliant design.

14.2.6

Fire Brigade Intervention

The use of the subject fire-isolated stairway for the proposed building does not increase the risk of fire-affected occupants being unable to evacuate the building, DS-compliant solution where non-fire-affected stairways serve three storeys.

As such, the risk of exposure of fire-fighters to untenable conditions within the stairways is considered to be equivalent to a DS-compliant design.

14.3

Summary

The assessment undertaken above demonstrates that the alternative solution, which comprises non-fire-isolated Stair 2, does not leave separation of rising and descending flights is capable of facilitating occupant evacuation and fire-brigade intervention as a result of fire and smoke spread mitigation to an extent that is at least equivalent to that of the benchmark, DS-compliant design.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for this assessment in section 9.

15 ALTERNATIVE SOLUTION 5 – EXIT TRAVEL DISTANCES AND DISTANCE BETWEEN ALTERNATIVE EXITS (CARPARK)

Assessment Criteria

Table 11.1 provides a summary of the criteria for consideration as the basis of this Alternative Solution.

15.1

Table 15.1 – Assessment criteria

Consideration	Criterion
Applicable BCA DIS provisions	Clause D1.4 of the BCA stipulates that no point on a floor must be more than 20 m to a point from which travel in different directions to two exits is available, in which case the maximum travel distance to one of those exits must not exceed 40 m. Clause D1.5 of the BCA stipulates that exits that are required as alternative exits must be separated from the main exit by at least 10 m, except in Class 7a. The proposed alternative solution is based on: (i) Travel distance of up to 65 metres to an exit to the basement carpark, in lieu of 40 metres; (ii) Travel distance of up to 120 metres between alternative exits within the carparking basement levels, in lieu of 60 metres; (iii) A sprinkler system with listed fast-response heads (activation temperature of 68°C and RTI 50 m ² s ^{1/2}) and maximum coverage of 12 m ² per sprinkler for ordinary hazard throughout the basement car park level, in accordance with BCA Specification E1.5, which includes compliance with the relevant parts of AS2118-1999; and (iv) A building occupant warning system featuring an automatic voice messaging function.
Proposed Alternative Solution	Qualitative and quantitative analysis, based on BCA A0.5(b)(ii) "is shown to be at least equivalent to the relevant provisions of the Deemed-to-Satisfy Provisions" and A0.6(c) "Comparison with the Deemed-to-Satisfy Provisions". Based on a comparative assessment, the method of analysis will comprise a quantitative review of the evacuation time of occupants from SOLs between the proposed Alternative Solution and a similar BCA DIS compliant design, consisting of: (i) Detection time (i.e. based on activation of automatic fire suppression system); (ii) Pre-movement time (i.e. based on pre-movement time from PD 7974-62004 ⁹⁴); (iii) Movement time (i.e. based on methodologies and recommendations of Gwynne and Rosebaurm ⁹⁵); (iv) Completion of the evacuation time for the proposed design with that of the DS-compliant design which do not comprise fast response sprinkler heads.
Methods of analysis	A comparative acceptance criteria is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution from the subject car parking areas is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DIS-compliant design.
Acceptance criteria	

⁹⁴ British Standards, PD 7974-62004, The application of the safety engineering principles to the safety design of building – Part 6: Active fire protection – Fire safety strategies – occupant evacuation, behaviour and condition (sub-system 6), British Standards Institution, 2004, p.140.
⁹⁵ Gwynne, S. M. V. and Rosebaurm, E. R., Employing the Hydraulic Model in Assessing Emergency Movement, Section 3- Chapter 14, The SFPE Handbook of Fire Protection Engineering, 4th edition, National Fire Protection Association, Quincy, Massachusetts, 2001, pp. 9-173-9-186.

Throughout the basement car park level, in accordance with BCA Specification E1.5, which includes compliance with the relevant parts of AS2118-1999,

- (iv) a building occupant warning system featuring an automatic voice messaging function.

15.2.4

Occupant Evacuation

A comparative assessment between a BCA DIS compliant design and the proposed Alternative Solution is to be undertaken to determine the evacuation time of occupants from the subject car parking areas, in both cases, the basement car park features an equivalent floor area, fuel loads, occupant characteristics and fire scenarios.

The travel distances specified under BCA clause D1.4 are based on the characteristics of the occupants. The BCA nominates different travel distance provisions for Class 2 & 3 buildings and Class 5 to 9 buildings, based on the densities of occupants (sleep or awake) and the potential confusion and delays arising from being awoken during a fire alarm. The also applies to the travel distance between alternative exits in the event that the nearest exit is inaccessible and alternative exit needs to be sought for evacuation. For Class 7a car park, the BCA DIS provisions stipulate a travel distance to the nearest exit of up to 40 metres and 60 metres between alternative exits.

The concept of travel distance between alternative exits is illustrated in Figure 15.1⁹⁶. Occupants are shown to be able to reach the nearest exit (Exit A) or the second exit (Exit B) by way of this exit, they will realise that the exit is blocked by a fire resulting in the occupants to express via Route 2 to reach an alternative exit (i.e. Exit B). Pursuant to the BCA, the traditional method of measurement to determine the distance between alternative exits based on the total travel distance travelled via both Route 1 to the nearest exit (Exit A) and route 2 to alternative exit (Exit B) by via Route 2 to reach the second exit (Exit B).

In the event of a fire within the subject car parking areas, transient occupants are expected to evacuate using the multiple alternative exits provided throughout the space. Since the occupants can easily identify that Exit A is blocked from the clear visibility associated with open plan layout of the carparking basement levels, they are likely to seek the shortest route to Exit B (i.e. Route 3). Notwithstanding the above, the following evacuation calculations will be based on the traditional BCA method of measurement through the point of choice, resulting in a BCA DIS compliant design for Class 7a (car park) areas featuring up to 100 metres (i.e. 40 m to the nearest exit and 60 m to reach the second exit) and the Alternative Solution featuring up to 165 metres (i.e. 65 m to the nearest exit and 120 m to reach the second exit).




Figure 15.1 – Measurement of distance between alternative exits

⁹⁶ CBSE Guide E, Fire Engineering, 3rd ed., CBSE, 2003, p.7-12.

Consideration	Criterion
IFEG sub-systems	The relevant sub-system from the International Fire Engineering Guidelines ⁹⁷ are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Relevant performance requirements	OP4 and EP2.2.

15.2

Fire Engineering Assessment

Intent of the BCA DIS Provisions for Exit Travel Distances and Distances between Alternative Exits

The Guide to the BCA⁹⁸ states the intent behind the distance between alternative exits is specified for the following reason:

To ensure that if an exit is inaccessible, access to any required alternative exit must be available within a reasonable distance

And:

Where a building requires multiple exits, the exits maximise the choices of a person evacuating, in case one exit becomes blocked.

Furthermore, the provision of multiple exits is considered:

To maximise the choices of a person evacuating, in case one exit becomes blocked.

The Guide to the BCA⁹⁹ states that distances to exits "are based on an assumption of what is considered 'reasonable' distance to be travelled by occupants in reaching an exit".

15.2.2

Details of the BCA DIS Compliant Design

A BCA DIS compliant design will be used as the "base case" scenario for comparative assessment of the proposed Alternative Solution. The level of fire safety performance measured for the BCA DIS compliant design will be determined and measured against the performance measured for the Alternative Solution.

The BCA DIS compliant design for the building would comprise the following:

- Travel distances to the nearest exit of up to 40 metres within the basement car park.
- Travel distances between alternative exits of up to 60 metres within the basement car park.
- An automatic sprinkler system with standard response heads throughout the basement car park.

15.2.3

Details of the Proposed Alternative Solution

The proposed Alternative Solution will comprise the following features:

- Travel distance of up to 65 metres to an exit to the basement carpark, in lieu of 40 metres.
- Travel distance of up to 120 metres between alternative exits within the carparking basement levels, in lieu of 60 metres
- A sprinkler system with listed fast-response heads (activation temperature of 68°C and RTI 50 m²s^{1/2}) and maximum coverage of 12 m² per sprinkler for ordinary hazard is to be provided

⁹⁷ Australian Building Codes Board, ABCB, International Fire Engineering Guidelines Edition 2005, Australian Building Codes Board, Australia, 2005.
⁹⁸ Australian Building Codes Board (ABCB), Guide to the BCA 2014, Australia, 2014.




Figure 15.2 - Open layout of basement carpark

The total evacuation time is determined to be the summation of detection time, pre-movement time and movement time. In this case, the only variable is the detection and movement times (i.e. pre-movement time is considered to be equivalent in both scenarios).

Detection Time

For the occupants located within close proximity of a fire, the detection is expected to initially occur as a result of receipt of a clear visual cue and occupants are prompted to evacuate prior to the activation of the fire detection system. Conversely, for a fire occurring at a more remote point, the detection is expected to initially occur as a result of receipt of an automatic car alarm occupant warning system, initiated by the fire detection system.

As the automatic detection time received by the remote occupants will be longer than the detection time of occupants within proximity to a fire, the automatic detection time will be used as the basis of the assessment.

For Class 7a areas, the BCA DSS compliant design consists of an automatic sprinkler system with standard response sprinkler heads throughout the car park levels. To provide gullider detection time and control of fire, the alternative solution is to provide fast-response sprinkler heads. For ordinary detection time, the alternative solution is to provide fast-response sprinkler heads. For ordinary detection time, the fire response time is 120 seconds (per AS2118.1-1999). The detection times are summarised within Table 15.2.

Table 15.2 - Detection time	
BCA DSS compliant design (a)	Alternative Solution (b)
313	225

Pre-movement Time

As part of the alternative solution and a BCA DSS compliant design, the occupant warning system is to include an automatic voice-messaging function and equivalent sound pressure level.

As previously mentioned in section 6, a review of fire statistics in car parks¹⁰ by BHP Melbourne Protection Laboratories (BPL) has reported the following:

- There have been no death or serious injuries recorded for fires in car parks in Australia.
- The Australian Iron and Steel Institute (AISI) survey of US and Canadian car parks has indicated that the safety risks within car parks are not significant, as there has been no recorded loss of life from a fire in a car in the car park over a survey period of 60 years. Car parks are generally not a source of death or personal injury.
- The National Fire Protection Association analysed fire loss from US and Canadian car parks from 1982 to 1996 and concluded that there is an extremely low fire safety hazard in car parks.

The referenced AISI report concluded with the following statement, "It is clear from the available fire record that fires in car parks represent little risk to life or of injury, and very low monetary losses, possibly because of a very low frequency of the starts in the type of building. Accordingly, the requirements for the protection should not be excessive."

Based on the active fire protection system being installed for the subject building, the hazard related to violation of travel distance between alternative exits such as the risk of exposure to the products of combustion, reduced visibility, toxic gases and levels of toxicity is also considered to be similar to a BCA DSS compliant design.

With reference to the assessment presented above, the total evacuation time to reach an alternative exit for the alternative solution is expected to be shorter than that associated with the BCA DSS compliant design. This time is based on the alternative solution being proposed, and is considered to be at least equivalent to that of the similar BCA DSS compliant design.

Note that as the building will have a rise in storeys of only three, being less than 25 metres in effective height such that it is not considered to fall within the definition of a high-rise structure, the safety issues relating to the height of the building, as referred to in performance requirement P24 (i.e. reduced provision for external access for the fire-fighters etc.), are not relevant to this assessment. Furthermore, although a part of the building is situated below ground level (i.e. the carpark), the safety issues relating to whether an exit is from "...below ground level" (as referred to in performance requirement P24) is not relevant to this assessment.

In the alternative solution, the fire-fighters' access to the building is not directly affected by the assessment, as the carpark is not required to be provided with fire-hoisted exits, and the risk of fire and smoke spread to the exits has been determined as being equivalent to the benchmark, BCA DSS compliant design.

Fire Brigade Intervention

Assessment of the effects on fire brigade intervention of the subject, exit travel distances and distance between alternative exits has been undertaken, in order to ascertain that the brigade intervention activities will be at least equivalent to that of the similar BCA DSS compliant design.

The Guide to the BCA¹⁰ states the intent of BCA in relation the maximum distances between alternative exits is "to improve the level of safety when evacuating". In terms of hazard to the fire-fighters, variation to the distance between alternative exits does not affect the brigade intervention times adding the set-up phases of the incident nor affect the time required to undertake search and rescue.

The most likely fire scenario is based on a sprinkler-controlled fire within the car park, which involves the fire being contained to the carpark and the fire-fighters' access to the building is not directly affected by the assessment, as the carpark is not required to be provided with fire-hoisted exits, and the risk of fire and smoke spread to the exits has been determined as being equivalent to the benchmark, BCA DSS compliant design.

When an automatic fire suppression system operates, it not only controls or limits the fire development, but statistics show that, in most cases, the fire is extinguished before the fire brigade arrives at the building.

As such, the ability for fire-fighters to carry out fire-fighting operations is at least equivalent to that of the similar BCA DSS compliant design.

As the alternative solution features a voice messaging system, a pre-movement time of 3 minutes is considered suitable. The time was taken from Table 5-12.1 of the SPRF¹⁰ based on pre-recorded voice messaging being available in addition to the standard alarm tone.

As the BCA DSS Design compliant design complies a no voice messaging system, a pre-movement time of 4 minutes is considered suitable. The time was taken from Table 5-12.1 of the SPRF¹⁰ based on a standard alarm tone.

The pre-movement time is expected to be equivalent in both cases as listed in Table 15.3.

Table 15.3 - Pre-movement time	
BCA DSS compliant design (a)	Alternative Solution (b)
240	180

Movement Time to Reach an Alternative Exit

The movement time is the time interval between the commencement of evacuation and the completion of evacuation to a specified point. In the event that an exit is unavailable for egress, this assessment is concerned with the movement time to reach an alternative exit. The total travel distance measured through the point of choice is 100 metres for a BCA DSS compliant design (i.e. 40 metres to the nearest exit and 60 metres to the second exit) and 165 metres for the alternative solution (i.e. 65 metres to the nearest exit and additional 100 metres to the second exit).

With reference to Appendix A the movement times are governed by walking time to reach an exit, as the alternative solution is based on a standard alarm tone, there again the calculations apply to travel time to the exit and the time to reach the second exit, which is considered unlikely to occur in practice, due to the open plan nature of the carpark.

Table 15.4 - Movement time	
BCA DSS compliant design (a)	Alternative Solution (b)
155	64

Comparison of Evacuation Times

In terms of the evacuation times within the basement car park, the provision of a voice messaging system in the alternative solution is expected to result in a shorter evacuation time. The alternative solution provides gullider detection time for those who are not in the vicinity of the fire to receive a direct cue and promptly move away from the fire, hence resulting in a smaller exit size. Furthermore, the basement car park levels feature an open layout with various egress paths around or through the car park spaces is possible whereby the occupants are unlikely to be trapped by the seat of the fire.

Comparison of the evacuation times between a BCA DSS compliant design and the proposed Alternative Solution are summarised in Table 15.5 below.

Table 15.5 - Evacuation times	
BCA DSS compliant design (a)	Alternative Solution (b)
Detection time = 207	Detection time = 224
Pre-movement time = 240	Pre-movement time = 180
Movement time = 155	Movement time = 64
Total = 602 seconds	Total = 568 seconds

15.3 Summary

Summary

The assessment undertaken above demonstrates that the evacuation time arising from the proposed exit travel distance and travel distance between alternative exits that form the basis of the alternative solution is at least equivalent to that of the similar BCA DSS compliant design.

It is therefore considered that the proposed design will satisfy the acceptance criteria nonified for the assessment in section 9.

ALTERNATIVE SOLUTION 6 – EXIT TRAVEL DISTANCES TO A SINGLE EXIT (TENTANCY 03 MEZZANINE)

Assessment Criteria

Table 11.1 provides a summary of the criteria for consideration at the basis of this Alternative Solution.

Table 15.1 – Assessment criteria

Consideration	Criterion
Applicable BCA DLS provisions	Clause D1.4 of the BCA stipulates that no point on a floor must be more than 20 m from an exit, or a point from which travel in different directions to two exits is available.
Proposed Alternative Solution	The proposed alternative solution is based on: (i) travel distance of up to 25 metres to the single exit in lieu of 20 m (ii) a building occupant warning system featuring an automatic voice messaging function; (iii) The presence of an automatic sprinkler system; (iv) The low population expected within the mezzanine; and (v) The open-plan layout of the mezzanine which provides maximum visual access to exit location
BCA assessment method	Qualitative and quantitative analysis, based on BCA A2.9.2(9) 'is shown to be at least equivalent to the Deemed-to-Satisfy Provisions' and A2.9.4(9) 'Compliance with the Deemed-to-Satisfy Provisions'. Based on a comparative assessment, the method of analysis will compare a proposed alternative solution with the Deemed-to-Satisfy Provisions.
Methods of analysis	(i) Comparison of the proposed Alternative Solution and a similar BCA DLS compliant design, consisting of: (i) Detection time; (ii) Pre-movement time (i.e. based on pre-movement time from PD 79/4-6:2004) (iii) Movement time (i.e. based on methodologies and recommendations of Glynn and Roseburn) (iv) Acceptance criteria
Acceptance criteria	A comparative acceptance criterion is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution from the subject mezzanine is less than or equivalent to (i.e. not greater than) that of the benchmark, BCA DLS compliant design.
	The relevant sub-system from the International Fire Engineering Guidelines ¹⁰⁵ are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Impact and Control • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Performance requirement	DP4 and EP2.2

¹⁰³ British Standards, PD 79/4-6:2004, The application of the safety engineering principles to the safety design of buildings – Part 6: Human factors, L16 safety strategies – occupant evacuation, behaviour and control (sub-system B), British Standards Institution, 2004, p 146.
¹⁰⁴ Glynn, J. K. V and Roseburn, E. R., Employing The Hydraulic Model in Assessing Emergency Movement, Section 3, International Fire Engineering Guidelines, 4th edition, National Fire Protection Association, Quincy, Massachusetts, 2000, pp 3-273-3-285.
¹⁰⁵ Australian Building Codes Board, ABCB, International Fire Engineering Guidelines Edition 2005, Australian Building Codes Board, Australia, 2005.




Figure 15.1 – Open layout of warehouse mezzanine (Level 2)

Occupant Evacuation

A comparative assessment between a BCA DLS compliant design and the proposed alternative solution is undertaken to investigate the differences in evacuation time associated with travel distance from the mezzanine to the exit. The proposed alternative solution features an equivalent floor area, fuel loads, occupant characteristics and fire scenarios.

The travel distances specified under BCA clause D1.4 are based on the characteristics of the mezzanine. The BCA stipulates that the travel distance from any point on the mezzanine to the nearest exit shall not exceed 20 m. The proposed alternative solution features a travel distance of up to 25 metres. The BCA stipulates that the travel distance from any point on the mezzanine to the nearest exit shall not exceed 20 m. The proposed alternative solution features a travel distance of up to 25 metres.

The total evacuation time is determined to be the summation of detection time, pre-movement time and movement time. In this case, the only variable is the detection and movement times (i.e. pre-movement time is considered to be equivalent in both scenarios).

Detection Time

For the occupants located within close proximity of a fire, fire detection is expected to initially occur as a result of receipt of a clear visual cue and occupants are prompted to evacuate prior to the activation of the fire detection system or sprinkler system. Conversely, for a occupant at a more remote point, the detection is expected to initially occur as a result of receipt of an automatic cue from occupant warning system, initiated by the fire detection system or sprinkler system.

For Class 7a areas, the BCA DLS compliant design consists of an automatic sprinkler system with automatic response sprinkler heads throughout. The detection times are considered to be similar for the BCA DLS compliant design and alternative solution as summarised in Table 15.2.

Table 15.2 – Detection time

BCA DLS compliant design (i)	Alternative Solution (i)
Equivalent	Equivalent

Evacuation Time

As part of the alternative solution, the occupant warning system is to include an automatic voice messaging function.

Fire Evacuation Assessment

Intent of the BCA DLS Provisions for Exit Travel Distance

Initiations are placed on the maximum distances that occupants are required to travel in order to reach 'safer' places, such as an exit, refuge or a final exit, and thereby to open space.

The deemed-to-satisfy provisions, in part, attempt to limit the exposure of occupants to a fire by ensuring that the travel distance from any point on the floor to the nearest exit is not greater than 20 m. The provisions of multiple exits minimise the critical occupants have in the case that one exit is blocked.

In relation to being trapped by the seat of the fire, initiations are placed on the maximum distances that occupants are required to travel in order to reach 'safer' places, such as an exit, refuge or a final exit, and thereby to open space.

The goal is to 'support' the viewpoint, stating that multiple exits are specified for the following reason:
To require that if an exit is inaccessible, access to any required alternative exit must be available within a reasonable distance¹⁰⁶ and 'where a building requires multiple exits, the exits must be maintained the choice of a person evacuating, in case one exit becomes blocked.

Details of the BCA DLS Compliant Design

A BCA DLS compliant design will be used as the 'base case' scenario for comparative assessment of the proposed design. The level of the safety performance measured for the BCA DLS compliant design will be determined and measured against the performance measured for the Alternative Solution.

The BCA DLS compliant design for the building would comprise the following:
(i) Travel distance to the nearest exit of up to 20 metres within the warehouse mezzanine;
(ii) A building occupant warning system with no voice messaging system; and
(iii) An automatic sprinkler system.

Details of the Proposed Alternative Solution

The proposed Alternative Solution will comprise the following features:

- (i) Travel distance of up to 25 metres to an exit in lieu of 20 m;
- (ii) A building occupant warning system featuring an automatic voice messaging function;
- (iii) The presence of an automatic sprinkler system;
- (iv) The low population expected within the mezzanine; and
- (v) The open-plan layout of the mezzanine which provides maximum visual access to exit location, as shown in Figure 15.1.

¹⁰⁶ Australian Building Codes Board (ABCB), Guide to the BCA, Class 2 to Class 9 Buildings, Australian Building Codes Board, Canberra, Australia, 2011.

As the alternative solution features a voice messaging system, a pre-movement time of 5 minutes is considered suitable. The time was taken from Table 3.12.1 of the SP711¹⁰⁷ based on pre-recorded verbal messaging being available in addition to the standard alarm tone.

As the BCA DLS Design compliant design does not feature a voice messaging system, a pre-movement time of 4 minutes is considered suitable. The time was taken from Table 3.12.1 of the SP711¹⁰⁷ based on a standard alarm tone.

The pre-movement times for both cases are summarised below in Table 15.3.

BCA DLS compliant design (i)	Alternative Solution (i)
240	180

Table 15.3 – Pre-movement time

The movement time for both cases are summarised below in Table 15.4.

BCA DLS compliant design (i)	Alternative Solution (i)
21	21

Construction of Evacuation Times

In terms of the evacuation times within the warehouse mezzanine, the provision of a voice messaging system provides an improved pre-movement time. Furthermore, the mezzanine level feature an open layout whereby the occupants are unlikely to be trapped by the seat of the fire.

Comparison of the evacuation times between a BCA DLS compliant design and the proposed Alternative Solution are summarised in Table 15.5 below.

Location	BCA DLS compliant design (i)	Alternative Solution (i)
Detection time – Equivalent		
Pre-movement time – 240		
Movement time – 17		
Therefore, BCA DLS compliant is at least 56 seconds longer than the Alternative Solution due to longer pre-movement time.		
Detection time – Equivalent		
Pre-movement time – 180		
Movement time – 21		
Therefore, Alternative is at least 56 seconds shorter than the BCA DLS compliant design due to shorter pre-movement time.		

Based on the active fire protection system being installed for the subject building, the hazard related to initiation of travel distance to an exit such as the risk of exposure to the products of combustion, including elevated temperatures, toxic gases and levels of visibility is also considered to be similar to a BCA DLS compliant design.

Now that the building will have a fire in situations of only three, being less than 25 metres in effective height such that it is not considered to fall within the definition of a high-rise structure, the safety issues relating to the height of the building, as referred to in performance requirement DP4 (2, medium) for external fire, are not considered to be a safety issue. Furthermore, the safety issues relating to 'whether an exit is from ... below ground level', as referred to in performance requirement DP4 (i.e. a potential lack of external access to a basement area, potentially internal ventilation etc.), are not directly affected by the assessment as the

¹⁰⁷ The SP711, Australian Fire Protection Engineering, 3rd ed, National Fire Protection Association, US, 2002.
¹⁰⁸ The SP711, Australian Fire Protection Engineering, 3rd ed, National Fire Protection Association, US, 2002.

occupant is not required to be provided with fire-isolated exits, and the risk of fire and smoke spread to the exit has been determined as being equivalent to the benchmark, BCA DIS compliant design.

16.2.5 Fire Brigade Intervention

Assessment of the effects on the brigade intervention of the subject, exit travel distances has been undertaken in order to establish that the brigade intervention activities will be at least equivalent to that of the similar BCA DIS compliant design.

The Guide to the BCA¹¹⁶ states, the intent of BCA is reducing the maximum distance between alternative exits is to improve the level of safety by providing "exit shelter". In terms of hazard to the fire-fighters, variation to the exit travel distance does not affect fire brigade intervention activities during the set-up phase of the incident nor affect the time required to undertake search and rescue.

The most likely fire scenario is based on a sprinkler-controlled fire within the workplace, which involves containment of fire to the region of fire origin such that the building is not affected structurally. The extent of fire-fighting activities required in this instance will be minimal, with the objective of the automatic sprinkler system being to contain and extinguish fire¹¹⁷, as stated in the Guide to the BCA¹¹⁶. This is further elaborated stating that:

When an automatic fire suppression system operates, it not only controls or limits the fire development, but statistics show that, in most cases, the fire is extinguished before the fire brigade arrives at the building.

As such, the ability for fire-fighters to carry out fire-fighting operations is at least equivalent to that of the similar BCA DIS compliant design.

16.3

Summary

The assessment undertaken above demonstrates that the evacuation time arising from the proposed exit travel distances that form the basis of the alternative solution is at least equivalent to that of the similar BCA DIS compliant design.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for this assessment in section 6.

17 ALTERNATIVE SOLUTION 7 – EXIT TRAVEL DISTANCES TO A SINGLE EXIT (LEVEL 2 OFFICE)

17.1

Assessment Criteria

Table 11.1 provides a summary of the criteria for consideration as the basis of the Alternative Solution.

17.2

Table 11.1 – Assessment criteria

Consideration	Criteria
Applicable BCA DIS provisions	Clause D1.4 of the BCA stipulates that no part of a floor must be more than 20 m from an exit, or a point from which travel in different directions to two exits is available.
Proposed Alternative Solution	(i) Proposed alternative solution is based on: (ii) travel distance of up to 30 metres to the single exit in lieu of 20 m (iii) Provision of smoke detection system in accordance with AS 1670.1:2004 (iv) A building occupant warning system featuring an automatic voice messaging function
BCA assessment method	Qualitative and quantitative analysis, based on BCA A0.5(b)(ii) "is shown to be at least equivalent to the Deemed-to-Safely Provisions" and A0.5(c) "Comparison with the Deemed-to-Safely Provisions".
Multiple of analysis	Based on a comparative assessment, the method of analysis will comprise a quantitative review of the evacuation time of occupants from Level 2 office between the proposed Alternative Solution and a similar BCA DIS compliant design, consisting of: (i) Detection time, (i.e. based on activation of automatic fire detection system) (ii) Pre-movement time (i.e. based on pre-movement time from PD 7974, 82004) (iii) Movement time (i.e. based on methodologies and recommendations of Gyeyne and Rosecrance) ¹¹⁸
Acceptance criteria	A comparative acceptance criterion is to be adopted, being that the occupant evacuation time for the proposed Alternative Solution from Level 2 office is at least equivalent to (i.e. not greater than) that of the benchmark, BCA DIS compliant design.
IFEG sub-systems	The proposed design is compliant with the International Fire Engineering Guidelines ¹¹⁹ are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Relevant performance requirement	DP4 and EP2.2.

¹¹⁶ British Standards, PD 7974-82004, The application of the safety engineering principles to the safety design of buildings – Part 6: Evacuation, 2004, p 1-60.
¹¹⁷ Gyeyne, S. M. V. and Rosecrance, E. R. Employing the hydraulic model in assessing Emergency Movement, Gordon S. Rosecrance, 2005, p 3-72.
¹¹⁸ International Fire Engineering Guidelines, 4th edition, National Fire Protection Association, Quincy, Massachusetts, 2005, pp 3-072-3-088.
¹¹⁹ Australian Building Codes Board, ABCE, International Fire Engineering Guidelines Edition 2005, Australian Building Codes Board, Australia, 2005.

17.2

Fire Engineering Assessment

17.2.1

Intent of the BCA DIS Provisions

The Guide to the BCA¹¹⁶, in discussing the issue of travel distances pursuant to performance requirement DP4, states that the intent of Clause D1.4 is:

To maximise the safety of occupants by enabling them to be close enough to an exit to safely evacuate.

The BCA stipulates the maximum distances that occupants are required to travel in order to reach a 'safe place, such as an exit stairway or a final exit doorway to open space. The BCA DIS Provisions permit attempt to limit the exposure of occupants to a fire by controlling the maximum travel distances to final exit points.

The potential for occupants within the floor of fire origin being exposed to a fire is addressed within the BCA, as follows:

• In relation to being trapped by the seat of the fire, initiations are placed on the maximum travel distance along a single exit path prior to a point of choice between exits being reached. The provision of multiple exits maximises the choice occupants have in the case that the one exit becomes blocked.

• In relation to being exposed to the products of combustion generally, limitations are placed on the maximum travel distance to an exit from the storey, as well as the maximum travel distance to the BCA¹¹⁶, states that distances to exits "are based on an assumption of what is considered 'reasonable' distances to be travelled by occupants in reaching an exit".

17.2.2

Details of the BCA DIS Compliant Design

A BCA DIS compliant design will be used as the "base case" scenario for comparative assessment of the proposed design. The level of the safety performance measured for the BCA DIS compliant design will be determined and measured against the performance measured for the Alternative Solution.

The BCA DIS compliant design for the building would comprise the following:

- (i) Travel distance of up to 20 metres to a single exit;
 - (ii) An automatic smoke detection system throughout the building (note that this not required, however, 1989.1 is included for consistency); and
 - (iii) A building occupant warning system with no voice messaging system.
- The proposed Alternative Solution involves the following elements:
- (i) travel distance of up to 30 metres to an exit in lieu of 20 m (note that an allowance has been made for the office area to comprise two separate fire zones, as shown in Figure 17.1);
 - (ii) Provision of smoke detection system in accordance with AS 1670.1:2004 to the office areas; and
 - (iii) A building occupant warning system featuring an automatic voice messaging function.




Figure 17.1 – Exit to level 2 office area

17.2.4

Comparative Assessment

The Guide to the BCA states that distances to exits "are based on an assumption of what is considered 'reasonable' distances to be travelled by occupants in reaching an exit".

However, the distances stipulated in BCA Clause D1.4 are only based on the characteristics of the building. The Guide to the BCA provides specific provisions for Class 2 & 3 buildings from provisions for Class 5 to 8 buildings, based on the distances of occupants (leaves or exits) and the potential collision arising from being smothered during a fire alarm. For Class 5, BCA DIS provisions stipulate that the distance of travel to an exit is 20 metres.

For this comparative assessment, it is considered that both the BCA DIS compliant design and the proposed alternative solution feature the same building design. This includes equivalent floor area, fuel loads, total heat output, occupant characteristics and fire scenarios.

The total evacuation time is determined to be the summation of detection time, pre-movement time and movement time. In this case, the only variable is the detection and movement time (i.e. pre-movement time is considered to be equivalent in both scenarios).

Detection time

Occupants are expected to receive a visual cue within a short period of time given the floor area of the room. In the case that a visual cue is not initially received, the fire detection system would provide building occupant warning in the initiation of a fire within the building.

The detection time for the Alternative Solution is expected to be shorter, based on the 112 metre spacing of the detectors associated with the proposed AS 1670.1:2004 system, which contrasts with the 20.4 metre spacing as stipulated in AS 1668.1:1989. The detection times are summarised within Table 17.2.

Table 17.2 – Detection time

BCA DIS compliant benchmark	Alternative Solution
167	113

Pre-movement time

As part of the alternative solution, the occupant warning system is to include an automatic voice-messaging function.

As the alternative solution features a voice messaging system, a pre-movement time of 3 minutes is considered suitable. The time was taken from Table 5-12.1 of the SFFE¹¹⁹ based on pre-recorded verbal messaging being available in addition to the standard alarm tone.

As the BCA DIS compliant design does not feature a voice messaging system, a pre-movement time of 4 minutes is considered suitable. This time was taken from Table 5-12.1 of the SFFE¹¹⁹ based on a standard alarm tone.

¹¹⁵ The SFFE Handbook of Fire Protection Engineering, 3rd ed, National Fire Protection Association, US, 2002.
¹¹⁶ The SFFE Handbook of Fire Protection Engineering, 3rd ed, National Fire Protection Association, US, 2002.

The pre-movement times for both cases are summarised below in Table 17.3.

Table 17.3 – Pre-movement time	
Alternative Solution (a)	BCA DIS compliant benchmark (a)
180	240

Movement time to reach a point of choice

The movement time is the time interval between the commencement of evacuation and the completion of evacuation to a specified point. This assessment is concerned with the movement time to reach a point of choice.

The time to travel 30 metres in the level 2 office to the exit is approximately 25 seconds. The movement times to reach a single exit are summarised in Table 17.4 below.

Table 17.4 – Movement time to reach a point of choice	
Alternative Solution (a)	BCA DIS compliant benchmark (a)
25	17

Comparison of Evacuation Times to Point of Choice

Comparison of the evacuation times between a BCA DIS compliant design and the proposed Alternative Solution are summarised in Table 17.5 below.

Table 17.5 – Evacuation times for the BCA DIS design and Alternative Solution

Alternative Solution (a)		BCA DIS compliant benchmark (a)	
Detection time = 113		Detection time = 157	
Pre-movement time = 180		Pre-movement time = 240	
Movement time = 25		Movement time = 17	
Total = 318 s		Total = 414 s	

As a result of the assessment presented above, the total evacuation time to reach an exit for the alternative solution is expected to be shorter than that associated with the BCA DIS compliant design. This improved safety during travel to an exit, by way of the proposed fire safety strategy that features the alternative solution, is considered to be consistent to the BCA DIS compliant design.

Note that as the building will have a risk in design of only three, being less than 25 metres in effective height such that it is not considered to fall within the definition of a high-rise structure, safety issues relating to the 'height of the building', as referred to in performance requirement DP4 (i.e. reduced provision for external access for fire fighters etc), are not relevant to this assessment. Furthermore, although a part of the building is situated below ground level (i.e. the carpark), the safety issues relating to whether an exit is from '... below ground level', as referred to in performance requirement DP4 (i.e. provision of external access to a basement area, potentially minimal external circulation and directly affected by the fire and smoke spread to the carpark) is not required to be provided with fire-isolated exits, and the risk of fire and smoke spread to the exits has been determined as being equivalent to the benchmark, BCA DIS-compliant design.

Supporting Assessments

The primary assessment of comparison of evacuation times for both the proposed and DIS compliant designs has been carried out above. However, two additional assessments are to be provided below in support of this.

As the supporting assessments below will place some reliance on the performance of the automatic sprinkler system, review will be made of the expected reliability of such a system. In order to demonstrate that the level of life safety associated with sprinkler-controlled conditions is a reasonable expectation.

A fire scenario coincident with sprinkler failure is considered to be rare event, as reported in literature for correctly designed, commissioned and maintained sprinkler systems.



protection in these countries (it should be noted that data excludes fire where the sprinklers failed to operate).

In addition, statistics from the United States¹²⁴ describe the number of deaths that occurred within both sprinklered and unsprinklered office buildings over the period 1984 to 1998. There were 0 deaths per 1,000 fires for the sprinklered buildings over this time, whilst there were 0.3 deaths per 1,000 fires within the unsprinklered buildings.

The control of fire development and spread by automatic sprinklers serves to safeguard the occupants whilst they are evacuating. In many cases, where effective control of the seat of the fire can be established, temperatures and toxicity levels may be maintained that allow occupants to remain within the building for some time without being exposed to life threatening conditions, as reflected by the above statistics.

Sprinkler activation and control will generally serve to prevent flashover occurring and restrict the potential for the rapid fire spread throughout an enclosed area or to an adjacent area, such as to an open plan space or to adjacent offices.

The risk of death or injury to the occupants can therefore be seen as being minimal for the subject occupancy. As such, the proposed Alternative Solution is one that is not only considered to be at least equivalent to that of a similar BCA DIS compliant design, but is also considered to be superior (as reported above) but is one that features an inherently low level of fire safety risk to the occupants.

Fire Brigade Intervention

Assessment of the effects on fire brigade intervention of the subject variation to exit travel distances has been undertaken. In order to ascertain that the design does not adversely affect fire brigade intervention activities.

Fire brigade intervention is considered to be primarily affected by the difficulty in entering a building or part of a building, the structural stability of the building, the fuel load and the fuel load energy density and the number of occupants that may need rescuing or assistance.


In this case, the alternative solution relates specifically to exit travel distances for occupants evacuating from the level 2 office, does not affect any of these factors and the impact of the design on fire brigade intervention (i.e. on search and rescue and fire-fighting activities) is therefore considered to be insignificant. As fire-fighters are typically entering a building during a fire rather than exiting from it, the exit travel distances will primarily affect building occupants rather than fire-fighters.

As such, the ability for fire-fighters to carry out fire-fighting operations is at least equivalent to that of the similar BCA DIS compliant design. It is also expected that the ability for fire-fighters to carry out fire-fighting operations will not be adversely affected.

Summary

The assessment undertaken above demonstrates that the evacuation time arising from the proposed Alternative Solution is at least equivalent to that of the alternative solution is at least equivalent to that of a similar BCA DIS compliant design.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for this assessment in section 8.



England and Young¹²⁷ estimated the reliability of automatic sprinkler systems to be approximately 95 per cent based on Australian fire incident statistics collected by the Australian Fire Statistics Council (AFSC) for the period 1989/90–1993/94. The same document also reported that the fire size was too small to operate the sprinkler heads in 77 per cent of the cases.

NSW data collected by NSWFB¹²⁸ in its Annual Statistical Report 2001/2002 indicates that for incidents where sprinklers were present and operated, the fire was extinguished in 70 per cent of cases and was prevented from spreading in a further 26 per cent of cases – for storage premises, all incidents involved extinguishment or control of the fire.

This is consistent with data from the United States, where Des¹²⁹ reported that insurers assume the reliability figure for sprinklers to be in the range 92-97 per cent over the period 1989-2000.

Key reliability factors for sprinkler systems in Australia¹³⁰ include the protection of concealed spaces (roof and ceiling spaces), adequate maintenance of the system and the provision of stop valve (monitoring devices). As these items are addressed either by stipulation by AS 2118 or by inclusion within the fire safety design strategy specified in the report.

As a result, a high level of reliability is expected to be achieved by the sprinkler system.

Comparison with Low-Rise DIS Compliant Design

The minimum travel distances permitted by the DIS provisions for the subject, office building, being 20 metres to a single exit, would then apply to a similar low-rise office building.

The low-rise building would generally not be required to feature the same fire safety measures that are required in the subject building, such as:

- an automatic sprinkler system
- a smoke detection system

As a result, the comparison of the two solutions could include a DIS compliant design that does not incorporate automatic sprinkler protection. This would be the case for the subject building, with a marginally longer travel distance to a single exit but lower overall evacuation time to an exit and the inclusion of sprinkler protection, is substantially higher than the non-sprinklered, BCA DIS compliant low-rise design case. The high reliability of sprinkler systems has been discussed above. It should be noted that the level of reliability of the sprinkler system relates to the ability of the system to control a fire and, therefore, reduce the possibility of occupants being either trapped by a large fire or overcome by smoke and toxic combustion products.

As a result, the exposure of occupants in the alternative solution to a fire whilst travelling to a single exit is expected to be lower than the DIS compliant design, as the protection of products of combustion will not be as extensive during the evacuation period. This is also consistent with the growing of the same rate for both designs, based on identical fuel loads and the commonality of an automatic sprinkler system.

Supporting Non-Conservative Assessment

In addition to demonstrating an equivalent level of fire safety to that of the BCA DIS compliant design, the proposed alternative solution is also intended to demonstrate that the proposed design is intrinsically safe in an absolute sense.

Both the BCA DIS compliant building and the subject building include an automatic fire sprinkler system.

A high level of performance can be associated with the sprinkler system, the being substantiated by evidence from Australia's fire service. Murray¹³¹ data indicates that no deaths have occurred in sprinklered office buildings in Australia or New Zealand during the 100 years of sprinkler

- 117 England, J.P. & Young, S. A., Fire Risk Management for Buildings with Aged Accommodation, Fire Australia
- 118 New South Wales Fire Brigades (NSWFB), Annual Statistical Report 2001/2002 Incorporating a Ten Year Review 1989/90 to 1989/90, ISBN 1033 9505 New South Wales Fire Brigades, 2003.
- 119 Des, S., Estimating Small Board and Case House Sprinklered vs Non Sprinklered Fire Protection, NFST, 1990.
- 120 Research Division, National Fire Protection Association (NFPA), Quincy, MA, 2005.
- 121 Murray, H. W., Fire: A Century of Automatic Sprinkler Protection in Australia and New Zealand 1898-1998, Australia, 1998.
- 122 Murray, H. W., Fire: A Century of Automatic Sprinkler Protection in Australia and New Zealand 1898-1998, 1998.



18 ALTERNATIVE SOLUTION 8 – TRAVEL DISTANCES BETWEEN ALTERNATIVE EXITS (TENANCY C3)

18.1 Assessment Criteria

Table 18.1 provides a summary of the criteria for consideration as the basis of this Alternative Solution.

Table 18.1 – Assessment criteria	
Consideration	Criterion
Applicable BCA DIS provisions	Clause D1.5 of the BCA stipulates that exits that are required as alternative means of egress must be not more than 60 m apart in Class 7b occupancies.
Proposed Alternative Solution	(i) Travel distance of up to 70 metres between alternative exits within Tenancy C.3, in lieu of 60 metres. (ii) A sprinkler system in accordance with BCA Specification E1.5, which includes compliance with the relevant parts of AS2119-1998. (iii) A building occupant warning system featuring an automatic voice messaging function. (iv) The significant reservoir size for the smoke to fill.
BCA assessment method	Qualitative and quantitative analysis, based on BCA A0.50(b) 'is shown to be at least equivalent to the Deemed-to-Satisfy Provisions' and A0.8(c) 'Comparison with the Deemed-to-Satisfy Provisions'.
Methods of analysis	Based on a comparative assessment approach, the methods of analysis to be undertaken will comprise: (i) Calculation of the available safe evacuation time (ASET) for the proposed alternative solution based on zone modelling. (ii) Calculation of the ASET for a BCA DIS-compliant benchmark design which could have a ceiling height of 2.4 metres; and travel distances of 20 / 40 / 60 m. (iii) Comparison of the ASET for both the alternative solution and the BCA DIS-compliant benchmark design. (iv) Determination of the impact of the additional travel time that occupants would experience during the evacuation period, which improved tenability could be expected during the evacuation period.
Acceptance criteria	A comparative acceptance criterion is to be adopted, being that the potential for occupants to be exposed to the products of combustion for the proposed design is at least equivalent to (i.e. not greater than) that associated with the BCA DIS-compliant benchmark design, based on the increased ASET (being the result of the proposed design) compensating for the reduced RSET (being a result of the longer travel distances). The relevant sub-system from the International Fire Engineering Guidelines ¹³² are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Relevant performance requirement	DP4.



Fire Engineering Assessment

16.2.1 Intent of the DTS Provisions for Exit Travel Distances

Limitations are placed on the maximum distances that occupants are required to travel in order to reach a safe place, such as an exit delivery or a final exit doorway to open space. The deemed-to-safely provisions, in part, attempt to limit the exposure of occupants to a fire by stipulating these maximum travel distances. The potential for occupants within the floor of the origin to be exposed to the fire is addressed as follows:

- In relation to being trapped by the seal of the fire, limitations are placed on the maximum travel distances along a single exit path prior to a point of choice between exits being reached. The provision of multiple exits maximises the choice occupants have in the case that one exit becomes blocked.
- In relation to being exposed to the products of combustion generally, limitations are placed on the maximum travel distances to an exit from the storey, as well as the maximum travel distances to an alternative exit should the chosen exit be unavailable.

The Guide to the BCA "to support the Viewpoint, stating that multiple exits are specified for the following reason:

To require that if an exit is inaccessible, access to any required alternative exit must be available within a reasonable distance" and "Where a building requires multiple exits, the exits:

Further, the provision of multiple exits is considered to:

maximise the choice of a person evacuating. In case one exit becomes blocked.

16.2.2 Details of the Proposed Alternative Solution

The proposed Alternative Solution involves the following elements:

- Travel distances of up to 70 metres between alternative exits within Tenancy G.3. In lieu of 60 metres.
- A sprinkler system in accordance with BCA Specification E1.5, which includes a connection with the wettest point of AS2118-1989.
- A building occupant warning system featuring an automatic voice messaging function.
- The significant reservoir size for the smoke to fill for the alternative solution, as shown in Figure 16.1.




Figure 16.1 – Cross section of warehouse

16.2.3 Details of the DTS-Compliant Benchmark Design

A BCA DTS-compliant design has been used as the "benchmark" scenario for assessment of the proposed exit travel distances. The design is identical to the alternative solution, with the following exceptions:

- Travel distances of up to 40 metres to an exit or point of choice and up to 60 metres between alternative exits through the point of choice.

125 Australian Building Codes Board (ABCB), Guide to the BCA, Class 2 to Class 9 Buildings, Australian Building Codes Board, Canberra, Australia, 2014.



19

16.2.4

Assessment Criteria

Table 11.1 provides a summary of the criteria for consideration as the basis of the Alternative Solution.

Table 11.1 – Assessment criteria

Criteria	Assessment
Applicable BCA provisions	Class 2 to 9 of the BCA stipulates that exits that are required as alternative DTS provisions must be at least 60 m apart in Class 9 buildings.
Proposed Alternative Solution	(i) Travel distances of up to 70 metres between alternative exits within the child care centre on Level 2. In lieu of 60 metres. (ii) Provision of a 30 m refuge area to Level 2 adjacent to the lift lobby and fire stair with the bounding walls being lined with fire resisting plasterboard to achieve a +120/120 FRL and extending to the underside of the roof covering or a +120/120 FRL ceiling. (iii) The distance between exits and refuge area not exceeding 60 metres.
BCA assessment method	Qualitative assessment based on BCA A050(1) Formulating an Alternative Solution which complies with the Performance Requirements and A050(1)(i) demonstrating compliance with the Performance Requirements.
Methods of analysis	Based on a comparative assessment approach, the methods of analysis to be undertaken will comprise: (i) Consideration the fire separation provided by the proposed refuge area which reduces the distances between alternative exits. (ii) Determination of the impact of the additional travel time that occupants may need to reach an alternative exit and the presence of the refuge area and the outdoor area.
Acceptance criteria	A comparative acceptance criterion is to be adopted whereby the occupant evacuation time will be at least equivalent to a BCA DTS-compliant design based between places of relative safety not exceeding 80 m.
Referenced performance requirement	The relevant sub-system from the International Fire Engineering Guidelines ¹⁸ are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention

16.2.4

Warehouse Comparative Assessment

- a ceiling height of 2.4 metres throughout (as permitted under clause F3.1 for Class 7 occupancies).

Occupants evacuating from a warehouse tenancy will need to travel a distance of up to 40 metres to reach an exit and up to 70 metres to reach an alternative exit after travelling to the first exit. Occupants will take approximately 34 seconds to reach an exit and 59 seconds to reach an alternative exit based on an unobstructed evacuation speed of 1.1 m/s for an occupant. Therefore, it is considered that 60 seconds to reach an alternative exit for the proposed design complied with the BCA DTS-compliant design.

Method of Warehouse Assessment and Exit Distances During Evacuation

A number of considerations need to be taken into account when assessing the likelihood of occupant exposure to smoke during evacuation, being:

- Floor area – the BCA DTS provisions do not stipulate a minimum or maximum floor area for an exit, which could result in a significantly larger floor plate, resulting smoke to travel a much greater distance across the floor to reach an opening in one of the naturally ventilated enclosure impermeable and reduced visibility associated with rapid layering and smoke descent.
- Ceiling height – the warehouse space has an average floor to ceiling height of 10 metres. In comparison, the BCA DTS-compliant design could feature a clear height of just 2.4 metres throughout.

It is considered that the likely amount of smoke accumulation within the warehouse tenancy during a fire event would not be greater than that of the BCA DTS-compliant design and is, in fact, likely to lead to improved conditions for a longer period of time, due to the higher ceiling height providing a larger reservoir for smoke accumulation.

In order to demonstrate that the conditions are likely to improve as a result of the proposed geometry to result in a longer period of usability for evacuating occupants, a zone modelling analysis has been undertaken, with the details presented within Appendix B.

The modelling results indicate that the lower enclosure associated with the BCA DTS-compliant designs lead to a more rapid descent of smoke.

Smoke height for the alternative solution is generally above the height required for tenable conditions to be sustained (i.e. 2.4 metres).

Fire Scenario	Temperature to reach 185°C	Smoke layer height to reach below 2.1 m
Alternative Solution	Approx. 700 s	Approx. 600 s
BCA DTS-compliant design	Approx. 100 s	Approx. 100 s

16.3. The ASRT values correspond to the time when the visibility is 4 metres from the floor and all ambient temperature reaches 185°C (approximately equivalent to 2.25kW/m²) completely across the entire fire enclosure at any height.

Method of Endurance Conditions and Exit Distances on Occupant Evacuation

For consideration of the above results and the proposed design, design against the ability for occupants to safely evacuate as part of the alternative solution when compared to the BCA DTS-compliant design, consideration is given to the following factors:

- In the event of a fire, occupants are able to move directly away from the seat of the fire within a short distance, to a point of choice not exceeding the 20-metre distance nominated by the BCA DTS provisions. The proximity for occupants to be trapped by the seal of the fire is therefore low (and equivalent to the DTS-compliant design).
- The additional travel time that occupants may need to reach an exit or an alternative exit of up to 6 seconds compares favourably to the period during which improved tenability is expected to be experienced during the evacuation period. Based on the modelling indicating that the geometry of the alternative solution allows a greater volume for smoke to accumulate prior to descending to the height of the occupants.



19.2.2 Fire Evacuation Assessment

Intent of the DSS Provision for Travel Distance

Limitations are placed on the maximum distances that occupants are required to travel in order to reach a 'safe' place, such as the entry doorway to a fire-isolated exit.

The DSS Provisions, in part, attempt to limit the exposure of occupants to a fire by stipulating these maximum travel distances. In relation to being trapped by the seat of the fire, limitations are placed on the maximum travel distance along a single exit path prior to a point of choice between exits being reached. The provision of multiple exits maximises the choice occupants have in the case that one exit becomes blocked; and

The Guide to the BCA¹²⁷ supports this viewpoint, stating that multiple exits are specified for the following reason:

To ensure that if an exit is inaccessible, access to any required alternative exit must be available within a reasonable distance¹²⁸ and where a building requires multiple exits, the exits maximise the choices of a person evacuating. In case one exit becomes blocked¹²⁹

maximise the choices of a person evacuating. In case one exit becomes blocked.

Proposed Alternative Solution

The Alternative Solution for the building would comprise the following:

- Travel distance of up to 70 metres between alternative exits within the child care centre on Level 2, in lieu of 60 metres;
- Provision of a 30 m² refuge area to Level 2 adjacent to the lift lobby and fire stair. The bounding walls are to be lined with fire resisting plasterboard to achieve a /120/120 FRL and are to extend to the underside of the roof covering or a 120/120/120 FRL ceiling;
- Distance between exits and refuge area not exceeding 60 metres; and

¹²⁷ Australian Building Codes Board (ABCB), Guide to the BCA (Class 2 to Class 9 Buildings, Australian Building Codes Board, Canberra, 2014).

In addition to this, the building is considered to have 'high building legibility' based on its simple layout. Way finding is expected to be minimal and the exit is relatively easy to identify without much guidance due to the following items:

- ease at which occupants can orient themselves within the child care centre; and
- easy identification of the main exit and entry into the child care centre.

19.2.6 Fire Hazard

The likelihood of a fully-developed fire occurring is low during occupied hours, due to the presence of trained staff who could undertake fire-fight fire fighting.

The floor is also constructed of concrete. The ability for the floor to withstand the effects of a fire for a period of time will provide a structurally stable environment for facilitation of occupant evacuation within the childcare centre.

The fire hazard is considered to be the same for both the Alternative Solution and the BCA DSS-compliant benchmark design.

19.2.6 Occupant Evacuation

Staff members are expected to be awake and conscious of their surroundings and will be generally familiar with the building layout and the location of exits. Staff members are expected to be familiar with the building layout and the location of exits. Staff members are expected to be familiar with the building layout and the location of exits. Staff members are expected to be familiar with the building layout and the location of exits.

The Guide to the BCA limits the travel distance to a point of choice in order to maximise the safety of occupants by enabling them to be close enough to an exit to safely evacuate. The BCA nominates a travel distance of 20 m travel distance to a point of choice on a 'floor'. A 'floor area' is the area of a room, a room, a fire compartment or an atrium, as defined in the BCA. The subject non-enclosed area is a rooftop and is not considered to fall under any of these categories. The maximum travel distance to the effects of fire, this level of safety is considered at least equivalent to a BCA DSS-compliant benchmark design based on the maximum permitted exit travel distance of 20 m to an exit on a 'floor'. The intention for the limitations on the exit travel distances is also partly to maximise the safety of occupants by enabling them to be close enough to an exit to safely evacuate.

In addition, a refuge area is to be provided to the child care centre which will provide a distance of less than 60 m between the refuge area and the alternative exit.

In addition, for a fire occurring either within or outside the enclosed area, occupants are likely to receive visual or olfactory cues due to the formation of smoke and the non-enclosed rooftop area can act as a building / assembly area. In the event of a fire blocking the egress stairway, occupants could remain within the rooftop area by adopting a 'hold in place strategy' while waiting for fire brigade intervention to occur.

Note that as the building will have a rise in storeys of only three, being less than 25 metres in effective height such that it is not considered to fall within the definition of a high-rise structure, fire safety issues relating to the 'height of the building', as referred to in performance requirement DP4 (i.e. fire safety issues relating to the 'height of the building'), are not considered to be relevant to the assessment. Furthermore, although a portion of the building is situated below ground level (i.e. the carpark), fire safety issues relating to whether an exit is from '... below ground level', as referred to in performance requirement DP4 (i.e. a potential lack of external access to a basement area, potentially minimal external ventilation etc), are not directly affected by the assessment as the childcare centre is not affected by the subject alternative solution.




Figure 19.1 - Travel distance between alternative exits

19.2.3 Details of the BCA DSS-compliant Benchmark Design

A BCA DSS compliant design will be used as the 'base case' scenario for comparative assessment of the proposed design. The level of fire safety performance measured for the DSS compliant design will be determined and measured against the performance measured for the alternative solution.

The BCA DSS compliant design for the building could comprise a distance between alternative exits of up to 60 metres on a floor containing non-fire-separated areas.

19.2.4 Layout of the Child Care Centre

The child care centre comprises an indoor area and an outdoor area as shown in Figure 19.1 above. The open plan design of the non-enclosed outdoor area results in an environment where cues from a fire will be able to be readily identified by the occupants in the early stages of the fire's development. A 30 m² refuge area adjacent to the lift lobby and fire stair is to be provided, as shown in the figure above. The bounding walls are to be lined with fire resisting plasterboard to achieve a /120/120 FRL and are to extend to the underside of the roof covering or a 120/120/120 FRL ceiling.

19.2.7 Fire Brigade Intervention

Assessment of the effects on the brigade intervention of the proposed design involving variations to the benchmark design is to be made. The assessment is to be made in order to ensure that the design does not compromise the level of safety associated with the fire fighting activities in comparison to that of the similar, BCA DSS compliant design.

The primary design measure to impact on effective fire brigade intervention relates to the provision of fire compartmentation. This measure is provided in accordance with the BCA DSS Provisions for the subject development, providing an equivalent level of safety compared to a BCA DSS-compliant benchmark design.

Fire fighters will also not have to travel for a greater distance internally than what is prescribed by the BCA DSS provisions distance to reach all parts of the 'floor', based on the extent of external space within the child care facility.

The floor areas for the alternative solution are also at least equivalent to a BCA DSS-compliant benchmark design, such that the total load is not greater than the DSS-compliant design.

As it has been shown above that the fire safety strategy for the building, including provision for fire lighting and compartmentation, is not affected by the proposed travel distances, it is considered that the alternative solution will not adversely affect fire brigade intervention activities within the building.

As such, it is considered that the alternative solution, involving variation distances between alternative exits within the child care centre, will facilitate fire brigade intervention to a degree that is equivalent to that of the BCA DSS design.

19.3 Summary

As a result of the above assessment, it is considered that the proposed Alternative Solution, involving distances between alternative exits being up to 70 m, will not adversely affect occupant evacuation or fire-fighting activities within the building, based on the provision of a refuge area which provides a maximum distance between the refuge area and an alternative exit being within 60 metres and a portion of the area of travel being non-enclosed area.

It is therefore considered that the proposed design will satisfy the acceptance criteria given for this assessment within section 9.

20 ALTERNATIVE SOLUTION 10 – EXIT WIDTH WITHIN SCHOOLS

20.1 Assessment Criteria

Table 20.1 provides a summary of the criteria for consideration as the basis of the Alternative Solution.

Table 20.1 – Assessment criteria	Consideration
Applicable BCA provisions	Clause D1.6 of the BCA nominates a clear, minimum width of 1,000 mm for exits and paths of travel to exits.
Assessment method	The proposed Alternative Solution is based on the egress width within the school. Qualitative and quantitative analysis, based on BCA A0.50(1) is shown to be at least equivalent to the Deemed-to-Safely Provision and A0.50(1) Comparison with the Deemed-to-Safely Provisions. ¹³
Methods of analysis	Based on a comparative assessment approach, the method of analysis is to undertake an anthropometric assessment to determine the ability for the exit width to adequately facilitate the single-file passage of occupants to the exit. The assessment will consider for both the proposed design and the BCA DS-compliant design: (i) the number of occupants saved; and (ii) the occupant movement time.
Acceptance criteria	Comparative acceptance criteria are to be adopted, whereby: (i) The ability for the proposed exit and pathway widths forming the basis of the Alternative Solution to facilitate the single-file passage of a 95th percentile adult male is shown to be at least equivalent to the nominal BCA DS-compliant benchmark design; (ii) The occupant movement time from the assessment is at least equivalent to that associated with the nominal, BCA DS-compliant benchmark design.
IFEG sub-systems	The relevant sub-system from the International Fire Engineering Guidelines ¹⁴ are considered to be: • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Relevant performance requirement	DP4.

20.2 Fire Engineering Assessment

20.2.1 Intent of the DS Provision for Exit Width

The intent of BCA D1.6 in relation to dimensions of exits and paths of travel to exits is based on facilitating occupant evacuation from a building within a satisfactory time period. This includes allowing the occupants to evacuate without having to spend an excessive time travelling through the exit, and not to experience a dangerous situation, such as the formation of tight queues, panic and potential for trampling. The Guide to the BCA¹⁵ states that the intent of controlling dimensions of exits and paths of travel to exits is:

¹³ Listered, D., Metric Handbook, Planning and Design Data, third edition, Architectural Press, Oxford, UK, 2006.
¹⁴ Pressman, S., Bridgeport – Anthropometry, Ergonomics and the Design of Work, Third Edition, Taylor & Francis Group, 2006.
¹⁵ Listered, D., Metric Handbook, Planning and Design Data, third edition, Architectural Press, Oxford, UK, 2006.
¹⁶ Australian Building Codes Board (ABCB), BCA 2014 Class 2 to 9 Buildings, Australian Building Codes Board, Canberra, Australia, 2014.

EXOVO
WISCONSIN




Figure 20.2 – Body dimensions for various positions

Further to this, ergonomic data published by Listered¹⁶ indicates that a single male can move or walk comfortably within a pathway width of 550-600 mm. Pressman¹⁷ gives similar data to this, suggesting that a person is able to walk normally along a pathway width of 650 mm. Historically, as discussed in a NIST review of International regulations for egress system design¹⁸, this has been reflected in the United States by the adoption of the standard-walk exit width of 22 inches (560 mm) for single-file passage, which becomes 1,100 mm for side-by-side movement for two persons.

As a result, the occupants should be able to move with comfort and ease through the subject 820 mm exit path between the pods and columns within the swimroom.

Consideration is to be given to the hypothetical, BCA DS compliant design, where the ergonomic data indicates that a continuous width of 1000 mm would be insufficient to allow for side-by-side movement. Pressman and Listered give minimum widths for two, 95th-percentile males walking shoulder-to-shoulder that exceed 1000 mm (i.e. they range from 1,050 mm to 1,280 mm).

It is of note that the standard, US minimum exit width of 550 mm for single-file movement mentioned above (which becomes 1,100 mm for the side-by-side movement of two people) is consistent with the minimum width of 1,000 mm for the side-by-side movement of two people side-by-side at least 1,100 mm is discussed in the aforementioned NIST document, where it states:

Clearly, the current 44 in (1100 mm) minimum exit stair width is intended to support two, 22 in (560 mm) wide individuals walking side-by-side. The 22 in dimension includes the need to provide for body sway, as people move down the stairs (Pawley) and the need to allow for some personal space (Fulton, Panchotcheval and Murrells).

As such, a DS-compliant egress path width of 1000 mm would be insufficient to accommodate side-by-side movement and its capacity would therefore not significantly differ from the proposed 820 mm exit widths. In any scenario where occupants are grouped or bunched up, it is anticipated that they would move through the pathways in a staggered formation if necessary. Based on this, it is considered that the proposed stair width will be sufficient to allow occupants to move comfortably in single-file motion to the exit in each case, in a manner equivalent to the benchmark, DS-compliant design.

For both the Alternative Solution and the BCA DS compliant design, it is anticipated that occupants will move through the stairway in a staggered formation, with the higher access requiring occupants to station out to one side of the pathway to travel against the flow.

¹⁷ Listered, D., Metric Handbook, Planning and Design Data, third edition, Architectural Press, Oxford, UK, 2006.
¹⁸ NIST Building and Fire Research Laboratory, Gaithersburg, Maryland, USA, paper in Proceedings of the 7th International Conference on Performance-based Codes and Fire Safety Design Methods, SFPE, Auckland, NZ, 2006, pp. 167-181.

EXOVO
WISCONSIN

To require exits and paths of travel to an exit to have dimensions to allow all occupants to evacuate within a reasonable time.

20.2.2 Details of the BCA DS Compliant Design

A BCA DS compliant design will be used as the 'base case' scenario for comparative assessment of the proposed Alternative Solution. The design will be determined and measured against the performance measured for the Alternative Solution.

A BCA DS compliant design could comprise an unobstructed clear width of 1000 mm. Occupant numbers are considered to be similar for both designs.

20.2.3 Details of the Proposed Alternative Solution

The Alternative Solution comprises an unobstructed clear width of 820 mm within the swim school, as shown below in Figure 20.1. Occupant numbers are considered to be similar for both designs.




Figure 20.1 – Egress widths to swim school

20.2.4 Anthropometric Assessment

An assessment is to be made of the dimensions the subject stairway that is less than the minimum, DS-compliant width of 1000 mm, studying anthropometric data to ascertain whether or not the occupants can generally move comfortably through the egress pathways and in a manner at least equivalent to that commensurate with the DS-compliant, benchmark design.

Data presented by Pressman¹⁹, based on British and American adults aged 19-65, indicates that the 95th percentile of the studied population does not exceed the following dimensions:

- male – a shoulder breadth of 510 mm (shoulder width being the limiting factor)
- female – a hip breadth of 458 mm (hip breadth being the limiting factor)
- Further to this, Pressman²⁰ gives similar data, which indicates the following maximum body depth dimensions:
• Males are between 255 to 330 mm.
• Females are between 225 to 325 mm.

¹⁹ Pressman, S., Bridgeport – Anthropometry, Ergonomics and the Design of Work, Third Edition, Taylor & Francis Group, 2006.

²⁰ Listered, D., Metric Handbook, Planning and Design Data, third edition, Architectural Press, Oxford, UK, 2006.

EXOVO
WISCONSIN

Based on the above, it is considered that the proposed 820 mm width is sufficient to allow the occupants to evacuate the swim room. The proposed design is shown to be at least equivalent to the BCA DS compliant exit and does not impact on the potential for safe and effective movement of persons any more than the DS-compliant exit width.

20.2.5 Assessment Time to an Exit

Based on the hypothetical, BCA DS compliant design involving a minimum exit width of 1,000 mm, the proposed stairway configuration, involving an 820 mm width will provide an equivalent exit width and, therefore, an equivalent flow of occupants and total evacuation time that does not exceed that of the BCA DS compliant design.

The time to evacuate from the basement for both the Alternative Solution and the BCA DS compliant design is considered similar based on the same occupancy figures and the exit width not allowing for side-by-side movement of two persons.

As a result, it is considered that the safety of the occupants during emergency evacuation will be sufficiently facilitated by the proposed Alternative Solution, whereby the evacuation time will be at least equivalent to the BCA DS compliant design.

20.2.6 Available Safe Egress Time

Based on the following qualitative assessment, the available safe egress time from the swimroom is expected to be at least equivalent to the BCA DS compliant design based on 1,000 mm exit width, and the Alternative Solution, which is based on 820 mm exit width, resulting in equivalent fire and smoke development for each design.

20.2.7 Fire Brigades Intervention

Assessment of the effects of the proposed number of occupants within the building and the aggregate exit width of the stair has been made, which ascertains that the design does not increase the risk associated with the lighting activities in comparison to that of the BCA DS compliant design. The means of egress carried out above identified that the time for occupants to evacuate from the building will be at least equivalent for the Alternative Solution when compared with a BCA DS compliant design. Therefore, it is considered that the Alternative Solution will facilitate the brigade intervention to a degree that is at least equivalent to that of the BCA DS compliant design.

Consideration has been given to the effect of the exit width on the passage of individual fire fighters, according to data presented by FEMA²¹ on dimensions of US fire fighters (male and female), fitted with standard fire-fighting turnout gear (similar dimensions for Australian fire fighters not being available at this point, as assessed by Fire and Rescue NSW), the 95th percentile of the studied population did not exceed the following dimensions when fully dressed:

- male fire fighters – a shoulder breadth of 562 mm and a width across arms of 660 mm
- female fire fighters – a shoulder breadth of 554 mm and a width across arms of 650 mm (note that in contrast to the dimensions on the general population for females given previously in this report, shoulder width exceeded hip width for female fire fighters)
- As the clear width of the path of travel within the subject building will be a minimum of 820 mm, the 95th percentile dimensions of the above-mentioned shoulder widths and width across arms for both males and females will be achieved. Based on this, the design will be capable of facilitating movement for the 95th percentile male fire fighter, with no effect expected on the flow times into and through the exit.

As such, it is considered that the Alternative Solution, involving a variation in the exit width will facilitate the brigade intervention activities to an extent that is at least equivalent to that of the benchmark, BCA DS-compliant design.

Note: Fire Brigade intervention has not been relied upon in the assessment carried out above.

20.3 Summary

In relation to the proposed exit width within the swim school, the assessment undertaken above demonstrates a level of safety which is at least equivalent to the BCA DS-compliant design by very

²¹ FEMA Technical Committee, Casual Subcommunities, Firefighter Anthropometric Data White Paper, Fire Apparatus Manufacturer's Association, October, 2007.

EXOVO
WISCONSIN

of the proposed fire safety strategy for the subject development. This results in the facilitation of occupant evacuation to a degree that is at least equivalent to that of the benchmark, BCA DS compliant, case.

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for this assessment in section 9.

21 ALTERNATIVE SOLUTION 11 – FIRE RESISTANCE LEVEL TO ROOF, SPANDREL SEPARATION AND SMOKE HAZARD MANAGEMENT

Assessment Criteria

Table 21.1 provides a summary of the criteria for consideration as the basis of this Alternative Solution.

Table 21.1 – Assessment criteria

Consideration	Criteria
Applicable BCA DS provisions	Clause C1.1 of the BCA which refers to Clause 9.5 of Specs C1.1 stipulates that the roof of a building need not have an FRL of 120/60/30 if the covering is non-combustible and the building is sprinkler protected throughout. Clause C2.6(b) of the BCA stipulates that the requirements of Clause C2.6(b) for vertical separation do not apply to a building which has a sprinkler system installed throughout. Clause E2.2 of the BCA refers to Table E2.2a which stipulates that, for the subject building, an automatic smoke detection system or sprinkler system is provided throughout to satisfy the smoke hazard management provisions. The proposed alternative solution is based on: (i) The non-provision of a sprinkler system to the swimchocool; (ii) The swimchocool being a separate fire compartment from the remainder of the building; (iii) The non-provision of a roof having an FRL of 120/60/30; (iv) The non-provision of separation between vertical openings in external walls; (v) The provision of a sprinkler system throughout the building with the exception of the swim school; and (vi) The provision of a beam type automatic fire detection system to the swimchocool.
BCA assessment method	Qualitative assessment based on BCA A0.5b(i) 'formulating an Alternative Solution' and BCA A0.5b(ii) 'assessing the Alternative Solution' and A0.5b(iii) 'each other Verification Methods as the appropriate authority accepts for determining compliance with the Performance Requirements'. Based on a direct assessment against the performance requirements, the nature and will comprise: (i) Review of the potential for fire spread from the subject building to the adjoining buildings; (ii) Review and determination for the potential for fire spread from the swimchocool to the adjacent areas within the building; (iii) Review and determination of the potential for the spread between storeys via external openings; (iv) Review of the proposed smoke hazard management system for the building which comprises a combination of an automatic sprinkler system and smoke detection system.
Methods of analysis	

Consideration	Criteria
Acceptance criteria	Acceptance criteria are to be adopted, being as follows: (i) The potential for fire spread from the subject building to the adjoining buildings is mitigated based on the provision of an automatic sprinkler system throughout the building except for the swim school, which is located on Ground Floor. (ii) The potential for fire spread from the swim school to the adjacent areas within the building is mitigated based on the provision of an automatic sprinkler system throughout the building except for the swim school, which is located on Ground Floor. (iii) Fire spread between vertical openings is mitigated, based on an automatic sprinkler system provided throughout the building except for the swim school which do not comprise any vertical openings to its external walls. (iv) The combination of an automatic sprinkler system and smoke detection system will not adversely affect the smoke hazard management system. The above sub-system from the International Fire Engineering Guidelines are considered to be: • Sub-system A – Fire Initiation and Development and Control • Sub-system B – Smoke Development and Spread and Control • Sub-system C – Fire Spread and Impact and Control • Sub-system D – Fire Detection, Warning and Suppression • Sub-system E – Occupant Evacuation and Control • Sub-system F – Fire Services Intervention
Relevant performance requirement	CP1, CP2, EP1.4 and EP2.2.

21.2 Fire Engineering Assessment

21.2.1 Intent of the DS Provisions for Roof Fire Resistance Levels

The stipulation of fire resistance levels by the BCA is matched to each of the nominated occupancy classes, such that those that are considered to contain higher fuel loads, such as retail and industrial/storage uses, are given higher FRLs (S-4 hours) and those that are considered to contain lower fuel loads, such as residential, health care and office use, are given lower FRLs (1-2 hours).

The intent can be seen to allow a building to adequately resist the impact of fire to limit the potential for the spread of fire between fire compartments, buildings and classifications having different FRLs, reflecting the Objective of Section C of the BCA, CO1.

In relation to the specific role played by the roof structure, the fire resistance level stipulated in 120/60/30 effects an objective to limit the spread of fire via the roof structure, which could result in neighbouring buildings being affected.

This viewpoint is supported by the Guide to the BCA¹³⁸, which states that:

The roofs of certain types of buildings can be required to have an FRL to limit the spread of fire from the roof to another building, or from another building to the roof

21.2.2 Intent of the DS Provisions for Vertical Separation in External Walls

Clause C2.6 of the DS provisions of the BCA require vertically aligned openings to be separated by vertical spandrels of 900mm height, of which 600mm is required to extend above the finished floor level between the two storeys, or to be separated by horizontal spandrels projecting 1,100mm from the face of the building and extending 450 mm, as illustrated in Figure 21.1 and Figure 21.2 below.

¹³⁸ Australian Building Codes Board, ABCB, International Fire Engineering Guidelines Edition 2005, Australian Building Codes Board, Australia, 2005.
¹³⁹ Australian Building Codes Board (ABCB), Guide to the BCA 2014 Class 2 to Class 9 Buildings, ABCB, Canberra, Australia, 2014.




Figure 21.1 – Section View of Compliant Spandrel in accordance with the BCA DS provisions




Figure 21.2 – Elevation View of Compliant Spandrel in accordance with the BCA DS provisions
Spandrels are provided in order to prevent fire spread from one floor to another within a building of Type A construction via the external walls. The flames from a fire on a level below may rise up the side of a building e.g. after glassing failure and ignite materials on another floor level via radiant heat transfer or direct flame impingement.

The Guide to the BCA¹³⁹ supports the viewpoint stating that:

To minimise the risk of fire spreading from one floor to another via openings in external walls in buildings of Type A construction.

21.2.3 Intent of the DS Provisions for Smoke Hazard Management

The intent of BCA Table E2.2b in relation to smoke hazard management is, having specific regard to the stipulation of some general and specific strategies for smoke hazard management, for minimising

smoke risks within a building which can pose a significant hazard to the occupants, as discussed in The Guide to the BCA¹⁴¹.

To specify the requirements for minimising the smoke risks.

21.2.4

Assessment on the Spread of Fire

Fire Spread from the Swim School

A detailed assessment has been made of the potential for fire spread between the swim school and the adjacent tenancies. The potential for fire spread will largely be based on the severity of the fire, this being a factor of the low fuel loads (compared to typical class 9b occupancies) commensurate with a swim school and the intensity of an uncontrolled fire.

Fire severity within the building will primarily be influenced by the expected low fuel loads. The classification of the building is assembly related (i.e. typically dining, social activities and educational training), which results in a relatively low fuel load. However, the use of the subject building primarily relates to a swim school, with lobby areas and change rooms having minimal combustibles and fuel load. Fuel loads within the swim school may comprise fixed furniture being the reception desk, chairs and benches, as shown in Figure 21.3. Furnishings typically associated with the majority of class 9b assembly buildings, comprising items such as tables, chairs and kitchen equipment will therefore be limited.

The swim school will be a separate fire compartment from the remainder of the building via FRL 120/120/120 construction. The ability for the 120-minute bounding fire wall to withstand the effects of a fire for a specified period of time will enable the performance of the building to be quantified and the resulting in the ability for the building to provide a fire separation for the period required.




Figure 21.3 - Floor Plan of Swim School


Fire Spread from Sprinkler Protected Area

Fire development within the subject building would be governed by the arrangement of fuels and the ability for either occupants or fire fighters to intervene to control the fire and limit further fire spread.

For the subject development, a non-flashover fire presents as the "most probable" fire scenario for the building, based on the presence of an automatic sprinkler system throughout the building, except for the swim school which is a separate fire compartment, and located on Ground Floor, and occupants who may attempt to undertake first-aid fire-fighting during the early stages of the fire growth.

Fire Spread via Roof

A fully-developed compartment fire is unlikely in a sprinkler protected building. In the unlikely event of a fully developed fire, fire spread via the roof is unlikely to occur, as there are presently no buildings or fire source within close proximity of the subject building, as shown in Figure 21.4. As such, specific, quantitative fire spread calculations will not be performed for the determination of radiant heat flux values within each allotment. This is based on control of the permissible extent of construction on the neighbouring allotment.



Southern neighbouring property

Figure 21.4 - Proximity of Subject Building to Neighbouring Buildings

Fire Spread from Adjoining Property

As previously discussed, there are no nearby building structures located within the adjoining property; therefore, the risk of fire spread from the adjacent property is not applicable in this case.

21.2.5

Vertical Fire Spread via External Openings

Assessment on the potential for fire spread via vertical openings is to be made based on the non-provision of sprinklers to the swim school. The northern and southern facade of the swim school, as shown in




Figure 21.5 and

Figure 21.6, comprises masonry construction.

Fire spread via vertical openings from the swim school to the above tenancies is not expected to occur based on the Level 2 office roofline being setback at least 10 metres from the swim school below for the northern facade. The eastern and western facade comprises bounding walls and the southern facade does not comprise any openings.

As previously discussed, the potential for fire spread will largely be based on the severity of the fire, this being a factor of the low fuel loads (compared to typical class 9b occupancies) commensurate with a swim school.




Figure 21.5 - Swim school Level 1 plan




Figure 21.6 - Swim school Ground Floor plan

21.2.6

Impact of a Combination of Two Systems to Satisfy the Smoke Hazard Provisions

As detailed above, a number of fire safety measures have been included within the building design to satisfy the smoke hazard requirements, being:

- An automatic sprinkler system throughout the building, except for the swim school;
- An automatic fire detection and alarm system to the Level 2 offices and swim school;
- The low fuel load within the swim school

On the basis of the above, it is considered that the smoke hazard management will not be adversely affected by the combination of two systems detailed above.

The likelihood of fully-developed conditions within the swim school occurring is low, based on the minimal fuel load associated with typical swimming pools, as previously discussed. The swim school layout is shown in Figure 21.3 above, which shows the proposed fixed furnishing. The building is separated via fire compartments (the swim school is separated from the remainder of the building) resulting in the risk of fire and smoke spread being mitigated.

An automatic sprinkler system installed throughout the remainder of the building is expected to mitigate the risk of significant fire development and spread in the event that control is unable to be facilitated by the occupants prior to arrival at the scene by fire-fighting crews.

A sprinkler-controlled fire will have limited impact on fire-resisting elements such as walls, floors or columns, with the likelihood of a fully developed fire occurring being very low during occupied hours, due to the relatively large number of staff members that could undertake either first aid fire-fighting or raise an alarm during the early stages of a fire.

21.2.7

Fire Brigade Intervention

Assessment of the effects on fire brigade intervention of the proposed design is to be made, in order to ascertain that the design does not adversely affect the hazard associated with fire-fighting activities. Based on the fuel loads expected within the swim school, the low risk of fire spread between the subject building and neighbouring buildings via the roof, no vertical openings to the external wall of the swim school which could result in vertical fire spread, the proposed Alternative Solution is not expected to adversely affect fire brigade intervention.

It is also understood that fire brigades are also able to fight a fire externally in the event of a fire spread to the intervening floor above throughout the perimeter of the building.

21.3

SUMMARY

The assessment undertaken above demonstrates that the proposed Alternative Solution is considered to facilitate an acceptable level of fire and life safety in minimising the risk of fire spread

It is therefore considered that the proposed design will satisfy the acceptance criteria nominated for this assessment in section 9.

LEVEL

221

Table 22.1 – Assessment criteria

Relevant performance	EP1.4 and EP2.2.
----------------------	------------------

Fire Safety Assessment

Intent of the DCR Provisions for Smoke Exhaust

must comply with the relevant provisions for its classification

A BCA DIS compliant design will be used as the "base

The proposed Alternative Solution

(1) The provision of let-fans to the business

collected (such as counts, counts and the like) and efficiency.

Exova
Wilmington

2228

Based on the above information a comparative approach has been undertaken to show that both the BCA DIS compliant design and the proposed Alternative Solution feature the same risk profile.

Committee Assessment on Sorbitor Activation Time

- 201-761-1111




Figure 22.1 - Proposed jet-fan position

- Jet-fans will be monitored and controlled by the main jet-fan controller and at the main fire indicator panel.
- The jet-fans are to be located along the driveways and oriented such that the jet-stream is parallel to the driveways.
- Fire signalling cable recommended for the fire trip to the jet-fan panel from the Fire Indicating Panel (FIP) unless it has a fail-safe switch which switches it off should the connection be severed by a fire.
- Manual operation of the jet-fans from the main controller or the indicator panel is proposed.

22.2.8 Comparing the movement of smoke as it relates to visibility

It is considered that the likely amount of smoke accumulation within the car park during a fire event is similar to that of the BCA DBS-compliant design. In order to demonstrate that the conditions are similar as a result of the proposed geometry to result in a similar usability period for evacuating occupants, CFD modelling has been undertaken, with the details presented within Appendix D.

The modelling results indicate that the standard response sprinkler heads associated with the BCA DBS-compliant design lead to a faster time of smoke descent, as shown in Figure 22.2 and Figure 22.3 for times of 200 seconds and 400 seconds.




Figure 22.2 - Comparison of visibility at 200 seconds at a height of 2 metres for Alternative Solution and BCA DBS compliant design

22.2.9 Fire Brigade Intervention

Assessment of the effects on fire brigade intervention of the proposed design is to be made, in order to ascertain that the design does not adversely affect fire-fighting activities.

The above assessment has demonstrated that the design is at least equivalent to a BCA DBS compliant design in relation to sprinkler operation and usability, based on the operation and configuration of the jet-fans and the presence of fail response sprinkler heads. As such, the impact on the brigade search and rescue activities for the Alternative Solution is considered to be at least equivalent to a BCA DBS compliant design.

22.3 Summary

The assessment undertaken above demonstrates that proposed Alternative Solution relating to the provision of jet-fans to the basement carparking level in lieu of a conventional air handling system is at least equivalent to that of the similar BCA DBS compliant benchmark design.

It is therefore considered that the proposed design will satisfy the acceptance criteria given for this assessment within section 8.




Figure 22.3 - Comparison of visibility at 400 seconds at a height of 2 metres for Alternative Solution and BCA DBS compliant design

Although these results should be treated with caution, due to the approximations associated with achieving a clear, uniform layer height in a compartment with such a low ceiling height which could affect the results, the use of the results for a comparative assessment is considered acceptable for the purposes of demonstrating the significant effects that the different designs have on smoke spread and, as a result of this, the advantages associated with the design of the Alternative Solution.

Impact of Evacuation Conditions and Self-Defence on Occupant Evacuation

For consideration of the above results and the proposed design against the ability for occupants to safely evacuate as part of the Alternative Solution when compared to the BCA DBS-compliant design, consideration is given to the following factors:

- In the event of a fire, occupants are able to move directly away from the seat of the fire within a short distance, due to the presence of alternative exits within the basement carparking levels; and
- Travel distances to a point of choice not exceeding the 20-metre allowance nominated by the BCA DBS provisions. The proximity for occupants to be trapped by the seat of the fire is therefore low (and equivalent to the DBS-compliant design).

22.2.7 Additional Absolute Assessment

The potential for fire start and development within proximity to the driveway location where the jet-fans are located was assessed by the use of the carpark fire hazard severity and fuel load with the Alternative Solution. The severity of the fire hazard was assessed by the use of the travel time and it is therefore not likely that any storage items would be placed within these areas.

A review of fire statistics in carparks "" by BHP Melbourne Research Laboratories (MRL) has reported the following:

- There have been no death or serious injuries recorded for fires in carparks in Australia.
- The Australian Iron and Steel Institute (AISI) survey of US and Canadian carparks has indicated that the safety risks within carparks are not significant, as there have been no recorded loss of life from a fire in a car in the carpark over a survey period of 80 years. Carparks are generally not a source of death or personal injury.
- The National Fire Protection Association analysed the loss from US and Canadian carparks from 1982 to 1989 and concluded that there is an extremely low safety hazard in carparks.
- The referenced AISI report concluded with the following statement: "It is clear from the available fire record that fires in carparks represent little risk to life or injury, and very low monetary losses, possibly because of a very low frequency of the fires in the type of building. Accordingly, the requirements for the protection should not be excessive".

As the carpark levels are of a relatively open-plan design, a fire within the carpark level would be quickly noticed and occupants would evacuate to open spaces.

23

ANALYSIS AGAINST BCA PERFORMANCE REQUIREMENTS

23.1

Methodology

This section considers the proposed Alternative Solutions derived in the fire safety engineering analysis and compares them against the proposed fire safety engineering analysis against the relevant Performance Requirements in the BCA. The BCA Assessment Methods that have been used are Chapter A0.9(a) and Chapter A0.9(c).

23.2

Structural Stability

The proposed fire safety analysis was analysed against BCA Performance Requirement CP1. Table 23.1 summarises the discussions of each parameter nominated by the BCA Performance Requirement.

Table 23.1 - BCA Performance Requirement CP1


Parameter for Consideration	Discussion	Parameter Addressed?
CP1 A building must have elements which will, to the degree necessary, maintain structural stability during a fire.	CP1 A function or use of the building has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(a) the function or use of the building; and	The fire load has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(b) the fire load; and	The potential fire intensity has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(c) the potential fire intensity; and	The fire hazard (the danger in terms of potential harm and degree of exposure arising from the start and spread of fire and the smoke and gases that are liberally generated) has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(d) the fire hazard;	The height of the building has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(e) the height of the building; and	The proximity to other property has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(f) its proximity to other property; and	The active fire safety systems installed in the building have been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(g) any active fire safety systems installed in the building; and	The size of any fire compartment has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(h) the size of any fire compartment; and	The support of other elements has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(i) the brigade intervention; and	The support of other elements has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(j) other elements they support; and	The evacuation time has been considered in relation to the proposed alternative solution, as discussed in sections 2.3 and 11.2.2.	Yes
(k) the evacuation time.		Yes

In accordance with acceptable methods outlined during the Fire Engineering Brief process, it is the considered opinion of Exova that the design satisfies the stakeholder-agreed fire safety objectives as they relate to the BCA Performance Requirement, subject to recommendations made in this report.

23.3

Fire Strategy
The proposed fire safety strategy was analysed against BCA Performance Requirement EP2. Table 23.2 summarises the discussions of each parameter nominated by this BCA Performance Requirement.

Parameter for Consideration	Discussion	Parameter Addressed?
CP2 (a) A building must have elements which will, to the degree necessary, avoid the spread of fire.		
(i) to exits; and	Refer to comments under (i) to (iv) below.	N/A
(ii) to sub-occupancy units and public areas; and	N/A	N/A
(iii) between buildings; and	Refer to comments under (i) to (iv) below.	N/A
(iv) in a building.	Refer to comments under (i) to (iv) below.	Yes
CP2 (b) Avoidance of the spread of fire referred to in (a) must be appropriate to:		
(i) the function or use of the building; and	The function or use of the building has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3, 11.2.2, 12.2.4, 21.2.4 and 21.2.5.	Yes
(ii) the fire load; and	The fire load has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 21.2.4 and 21.2.5.	Yes
(iii) the potential fire intensity; and	The fire hazard (the danger in terms of potential harm and degree of exposure arising from the start and spread of fire and the smoke and gases that are thereby generated) has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 21.2.4 and 21.2.5.	Yes
(iv) the fire hazard; and	The fire hazard (the danger in terms of potential harm and degree of exposure arising from the start and spread of fire and the smoke and gases that are thereby generated) has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 21.2.4 and 21.2.5.	Yes
(v) the number of storeys in the building; and	The height of the building has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes
(vi) its proximity to other property; and	The proximity of other property has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes
(vii) any active fire safety systems installed in the building.	The active fire safety systems installed in the building have been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes
(viii) the size of any fire compartment; and	The size of any fire compartment has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes
(ix) fire brigade intervention; and	Fire brigade intervention has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes
(x) other elements in support; and	The support of other elements has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes
(xi) the evacuation time.	The evacuation time has been considered in relation to the proposed Alternative Solution, as discussed in sections 11.2.2, 12.2.4, 13.2.2, 21.2.4 and 21.2.5.	Yes



23.4

In accordance with acceptable methods outlined during the Fire Engineering Brief process, it is the considered opinion of Exova that the design satisfies the stakeholder-agreed fire safety objectives as they relate to the BCA Performance Requirement, subject to recommendations made in the report.

Means, Distances and Detention of Exits
The proposed fire safety strategy was analysed against BCA Performance Requirement DP4. Table 23.3 summarises the discussions of each parameter nominated by this BCA Performance Requirement.

Parameter for Consideration	Discussion	Parameter Addressed?
DP4 Exits must be provided from a building to allow occupants to evacuate safely, with their number, location and dimensions being appropriate to:		
(a) the travel distance; and	The travel distance has been considered in relation to the proposed Alternative Solution, as discussed in sections 15.2.4, 16.2.4, 17.2.4, 17.2.5, 18.2.4, 19.2.6 and 20.2.5.	Yes
(b) the number, mobility and other characteristics of occupants; and	The relevant occupant characteristics have been considered in relation to the proposed Alternative Solution, as discussed in sections 15.2.4, 16.2.4, 17.2.4, 17.2.5, 18.2.4, 19.2.6 and 20.2.4.	Yes
(c) the function or use of the building; and	The function or use of the building as a shopping centre has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3, 15.2.4, 16.2.4, 17.2.4, 17.2.5, 18.2.4, 19.2.6 and 20.2.3.	Yes
(d) the height of the building; and	The height of the building has been considered in relation to the proposed Alternative Solution, as discussed in sections 15.2.4, 16.2.4, 17.2.4, 17.2.5, 18.2.4, 19.2.6 and 20.2.3.	Yes
(e) whether the exit is from above or below ground level.	Whether the exit is from above or below ground level has been considered in relation to the proposed Alternative Solution, as discussed in sections 15.2.4, 16.2.4, 17.2.4, 17.2.5, 18.2.4, 19.2.6 and 20.2.3.	Yes

In accordance with acceptable methods outlined during the Fire Engineering Brief process, it is the considered opinion of Exova that the design satisfies the stakeholder-agreed fire safety objectives as they relate to the BCA Performance Requirement, subject to recommendations made in the report.

23.5

Fire Isolation of Exits
The proposed fire safety strategy was analysed against BCA Performance Requirement DP5. Table 23.4 summarises the discussions of each parameter nominated by this BCA Performance Requirement.

Parameter for Consideration	Discussion	Parameter Addressed?
DP5: To protect evacuating occupants from a fire in the building exits must be fire isolated, to the degree necessary, appropriate to –		
(a) the number, mobility and other characteristics of occupants; and	The number of storeys connected by the exits has been considered in relation to the proposed Alternative Solution, as discussed in sections 14.2.4 and 14.2.5.	Yes
(b) the fire safety systems installed in the building; and	The fire safety systems have been considered in relation to the proposed Alternative Solution, as discussed in sections 14.2.4 and 14.2.5.	Yes
(c) the function or use of the building; and	The function or use of the building has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3, 14.2.4 and 14.2.5.	Yes



23.6

Fire Suppression System
The proposed fire safety strategy was analysed against BCA Performance Requirement EP1.4. Table 23.5 summarises the discussions of each parameter nominated by this BCA Performance Requirement.


Parameter for Consideration	Discussion	Parameter Addressed?
EP1.4 An automatic fire suppression system must be installed to the degree necessary to control the development and fire appropriate to:		
(a) the size of the fire compartment	The size of the fire compartment has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3 and 22.2.3.	Yes
(b) the function or use of the building	The function or use of the building has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3 and 22.2.3.	Yes
(c) the fire hazard; and	The fire hazard has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3 and 22.2.3.	Yes
(d) the height of the building.	The height of the building has been considered in relation to the proposed Alternative Solution, as discussed in sections 2.3 and 22.2.3.	Yes

In accordance with acceptable methods outlined during the Fire Engineering Brief process, it is the considered opinion of Exova that the design satisfies the stakeholder-agreed fire safety objectives as they relate to this BCA Performance Requirement, based on a comparative assessment to demonstrate equivalence with the DNS provisions, subject to recommendations made in this report.


Smoke Means Management

The proposed fire safety strategy was analysed against BCA performance requirement EP2.2. Table 23.6 summarises the discussions of each parameter nominated by this BCA performance requirement.

Parameter for Consideration	Discussion	Parameter Addressed?
EP2.2 (a) In the event of a fire in a building the conditions in any evacuation route must be maintained for the period of time occupants take to evacuate the part of the building so that:		
(i) the temperature will not endanger human life; and	The temperature level of visibility and level of toxicity has been considered in relation to the proposed Alternative Solution, as discussed in sections 14.2.5, 15.2.4, 16.2.4, 17.2.4, 21.2.6 and 22.2.6.	Yes.
(ii) the level of visibility will enable the evacuation route to be determined and		Yes.



In accordance with acceptable methods outlined during the Fire Engineering Brief process, it is the considered opinion of Exova that the design satisfies the stakeholder-agreed fire safety objectives as they relate to the BCA Performance Requirement, subject to recommendations made in the report.



24 CONCLUSION

24.1 GENERAL

The proposed alternative solutions described herein have been formulated in consideration of BCA clauses A0.5(b)(i), A0.5(b)(ii) and A0.8 and assessment methods A0.9(b)(i) and A0.9(c), as agreed by the stakeholders during the FEB process.

It is the considered opinion of Exova Warringtonfire Aust Pty Ltd that the proposed alternative solutions satisfy BCA performance requirements CP1, CP2, DP4, DP5, EP1.4 and EP2.2 subject to the implementation of the fire safety strategy identified below.

24.2 RECOMMENDED FIRE SAFETY DESIGN STRATEGY

A description of the proposed fire safety design strategy for the development is outlined within section 7.1, 7.2 and 7.3 "Fire Safety Design".

24.3 CONSTRUCTION & COMMISSIONING REQUIREMENTS

A description of the proposed construction, commissioning and certification requirements for the development is outlined within section 7.4 "Standards of Construction, Commissioning, Management and Maintenance".

24.4 ENGINEERING JUDGEMENT

Engineering judgement has been used in the fire safety engineering analyses to determine and undertake appropriate methods to assess in qualitative terms the fire safety engineering issues relevant to this project.

24.5 EXPERT JUDGEMENT¹⁴⁶

Expert judgement has been relied upon to the extent that determination of the BCA Deemed-to-Satisfy Provisions and intent, together with determination of the BCA Performance Requirements and intent, require expertise in the use, interpretation and application of the BCA in relation to a comparative analysis.

25 VALIDITY / DISCLAIMER

This report is prepared for the proposed development at 2 Daydream Street, Warriewood NSW 2102 and should not be applied to other buildings.

This report has formulated and analysed a fire safety design solution against fire safety objectives developed in conjunction with relevant stakeholders and Authorities Having Jurisdiction during the Fire Engineering Brief process. Other issues not specifically addressed in the context of that detailed in the Fire Engineering Brief process have been excluded from the scope of this report.

Any modifications or changes to the building, fire safety management system, or building usage from that described may invalidate the findings of this report. Should such changes occur, a re-assessment should be sought.

Arson has been shown statistically to contribute to fire. This report has addressed the incidence of minor forms of arson as a single ignition source; however, major arson involving accelerants and/or multiple ignition sources are beyond the scope of this analysis and therefore have been excluded from the report.

Attention is drawn to the conditions of use depicted on page 2 of this report.

145 As required by the Documentation of Decisions section in the Introduction to the BCA.



APPENDIX A EVACUATION CALCULATIONS

A.1. OCCUPANT EGRESS ASSESSMENT OVERVIEW

This appendix addresses the evacuation of occupants from the building, given the variation relating to exit travel distances, travel distances to a point of choice and travel distances between alternative exits from each of the subject tenancy spaces.

The total evacuation time for the occupants within each respective part of the building is the summation of the following component times¹⁴⁶:

- Detection (cue) phase (T_d) – detection time or time until people become aware of the fire.
- Pre-movement / response phase (T_{pm}) – time taken for occupants to begin to move towards the exits once an alarm or intrinsic cue has been received.
- Movement phase (T_m) – time for occupants to move to an exit or a safe place (being the point of choice in this case).
- Evacuation phase (RSET) = $T_d + T_{pm} + T_m$

A.2. DETECTION TIME

The detection time, T_d , is the time interval between the ignition of the fire and the time that the occupants become aware of a fire incident within the building.

The detection time is generally given by the time at which the fire alarm is sounded by the automatic fire detection system or the time at which the occupants receive a clear visual or olfactory cue, such as from smoke. Real events usually include the response of occupants being subject to physical cues, such as seeing the fire or smoke, smelling smoke etc. Multiple cues are considered to be consistent with real events.

Basement Carpark Detection Time

With regard to the detection time for the occupants located within the basement carpark, the proposed sprinkler heads will provide an alarm cue in the event of a fire in any part of the building for those not intimate with the fire who are expected to initially receive a cue. The activation of the sprinkler system has been calculated using FireCalc¹⁴⁷, based on a medium fire for the basement carpark and the following sprinkler head characteristics:

- RTI = 200 m³ s^{1/2} (BCA DIS compliant design)¹⁴⁸ / 50 m³ s^{1/2} (Alternative Solution)¹⁴⁹
- Activation Temperature = 68 °C
- Radial distance from fire plume = 2.5 m
- Ceiling height within the car park areas = 2.85 metres




Figure A.1 – Detection time based on the activation of standard-response sprinkler head (BCA DIS compliant design)




Figure A.2 – Detection time based on the activation of fast-response sprinkler head (Alternative Solution)

As such, the detection time for the alternative solution is expected to be shorter based on the provision of fast-response sprinkler heads, in lieu of standard response sprinkler heads.

146 Australian Building Codes Board, ABCB, International Fire Engineering Guidelines Edition 2005, Australian Building Codes Board, Australia, 2005.

147 CSIRO, FIRECALC, Version 2.3, CSIRO Division of Building Construction and Engineering, 1993.

148 Chartered Institute of Building Services Engineers, "CIBSE Guide E – Fire Engineering", CIBSE Publications Department, Second Edition, 2003.

149 Chartered Institute of Building Services Engineers, "CIBSE Guide E – Fire Engineering", CIBSE Publications Department, Second Edition, 2003.



G.3 Warehouse Tenancy Detection Time (excludes mazzanina)

With regard to the detection time for the occupants located within the warehouse, the proposed sprinkler heads will provide an alarm cue in the event of a fire in any part of the building for those not intimate with the fire. The activation of the sprinkler system has been calculated using FireCalc⁵⁰, based on a medium fire for the warehouse area and the following sprinkler head characteristics:

- $RTI = 200 \text{ m}^{1/2} \text{ s}^{1/2}$
- Activation Temperature = 68°C
- Radial distance from fire plume = 2.5 m

The Firecalc program showing the output data is given below in Figure A.3.




Figure A.3 – Activation time for a fast t^2 fire within Tenancy G.3

The detection time is therefore 288 seconds for the proposed alternative solution in Tenancy G.3.

Level 2 Office Detection Time

As shown in Figure A.6 to Figure A.7, activation of the detection system has been calculated using FireCalc[®] with the following detector characteristics:

- Activation temperature = 15°C (note that for the purposes of the use of *Fluorescence* as a detector response estimation, the actual ambient temperature selected does not affect the outcome of the calculation, subject to a difference of 13°C between ambient and activation temperatures being maintained)
- Radial distance from the = 14.4 metres (BCA DIS compliant design – refer to Figure A.4)
- Radial distance from the = 7.2 metres (Actual Solution – refer to Figure A.5)
- $RTI = 10 \text{ m}^2 \text{ s}^{-1/2}$
- Medium's δ growth rate

CSIRO, FIRECALC, Version 2.3, CSIRO Division of Building Construction and Engineering, 1993.

151 CSIRO, FIRECALC, Version 2.3, CSIRO Division of Building Construction and Engineering, 1993.
152 Fire Safety Engineering Guidelines (Second Edition), Australian Building Codes Board, November 2001.
153 Bukowski, R. W. and Averett, J. D., Methods for Predicting Smoke Detector Activation, Proceedings of the Fire Suppression and Detection Research Application Symposium, Research & Practice, Bridging the Gap, Feb 25-27, 1996, Orlando, FL, NFPPF, Quincy, MA, 1996.




Figure A.6 – Detection time based on activation of smoke detection system (BCA D48 compliant design)




Figure A-7 - Detection time based on activation of smoke detection system (Alternative Solution)

The detection time for the Alternative Solution is shorter, based on the 10.2 metre spacing of the detectors associated with the proposed AS 1670.1-2004 system, which contrasts with the 20.4 metre spacing as stipulated in AS 1689.1-1998.




Figure A.4 – Radial distance of detectors to a fire for the BCA D18 compliant design




Figure A.5 – Radial distance of detectors to a fire for an Alternative Solution

Report No. 2008-0700-APP01-4
Page 144 of 170

A.3. PRE-MOVEMENT TIME

The pre-movement time, T_{pre} , is the time interval between occupants becoming aware of the fire and commencement of evacuation. One response is to seek more information about the nature of the fire and another is to try to extinguish the fire.

A number of other factors influence the response time to an incident, such as occupant familiarity with the building, interaction between occupants in groups, the perceived threat of the fire and the type of "evacuation alarm". In the case that the occupants receive a clear visual cue, such as a smoke, the pre-movement time would be short (60 seconds or less in some cases¹⁰), as typically encountered in the room of fire origin.

This is consistent with findings from studies in the evacuation of open plan buildings, including the work of Frantzich¹⁶, and would apply to occupants within the floor of fire origin who are located in proximity to the fire.

As the building is to feature an automatic alarm system incorporating a pre-recorded voice message, the best possible scenario with the occupants responding to a voice message is 120 seconds.

For the BCA DIS-compliant design, the benchmark DIS-compliant design is not required to incorporate a voice message. The response time for the BCA DIS design would therefore be based on an automatic alarm not incorporating a voice message. The best possible scenario, with the occupants responding to an alarm bell in 180 seconds.

A.4. MOVEMENT TIME WITHIN TENANCY Q.3 BETWEEN EXITS

The movement time, T_m , is the time interval between the commencement of evaluation and the completion of evaluation to a specified point. This assessment is concerned with the movement times to reach a point of choice.

The total occupant movement time to an exit or past a specified point is either:

- (i) walking time to the exits (usually governs the movement time when the number of occupants is low relative to the width of the exits)
- (ii) queuing time through the exits (usually governs the movement time when the number of occupants is high relative to the width of the exits and the occupants are well-distributed).

Walking speeds will vary, based on the occupant density in each part of the building and the physical abilities of the occupants. For a person with an average mobility, such as a staff member or visitor, an unobstructed egress speed of 1.19 m/s has been reported¹⁷, whilst for people with disabilities, who may require the assistance of a walking frame, an egress speed of 0.57 m/s has been reported¹⁸. These unobstructed speeds and flows are considered to be appropriate for occupants travelling through open areas to exit points and stairways, based on an occupant density of less than 0.54 persons/m².

In addition to a walking speed of 1.19 m/s, a speed of 0.57 metres/s will also be considered as part of a sensitivity study to account for the walking speed of occupants with disabilities.

The most severe assessment involves consideration of the occupant walking time to a second exit, rather than the queuing time to the exits, as the queuing time will be equivalent for both the proposed and DIS compliant designs due to identical populations and exit widths. As such, the queuing time will not be calculated, which will result in an improved level of performance associated with the DIS compliant benchmark design.

The following equation has been used to determine the walking time:

$$T = d's$$

- 154 Shaw, J. D., *Assessing Occurrence Potential: A New Issue for Risk Assessment*, in R. Barham (ed.) *Fire and Emergency Research: Methods and Applications*, E & FN Spon, London, UK, pp462-469, 1998.
- 155 Shaw, J. D., *Fire Risk Assessment: A Review of the State of the Art*, in R. Barham (ed.) *Fire and Emergency Research: Methods and Applications*, E & FN Spon, London, UK, pp470-481, 1998.
- 156 The Fire Code (HSE) *Fire Safety in Shopping Centres Final Research Report*, Prepared by J. D. Shaw, 1998. Proceedings to the 2nd International Symposium on Human Behaviour in Fire, International Communications, 199-105, Boston, MA, 2001.
- 157 Shaw, J. D., *Conference Proceedings for the 2nd International Symposium on Human Behaviour in Fire*, International Communications, 199-105, Boston, MA, 2001.
- 158 Proulx, G., *Measurement of the Evacuation Time*, The SFPE Handbook of Fire Protection Engineering, 3rd ed., National Fire Protection Association, USA, 2002.
- 159 Proulx, G., *Measurement of the Evacuation Time*, The SFPE Handbook of Fire Protection Engineering, 3rd ed., National Fire Protection Association, USA, 2002.
- 160 Proulx, G., *Measurement of the Evacuation Time*, The SFPE Handbook of Fire Protection Engineering, 3rd ed., National Fire Protection Association, USA, 2002.

APPENDIX B WAREHOUSE TENANCY FIRE MODELLING

B.1. ZONE MODELLING

The relatively small floor area with and geometrically simple compartment of the warehouse is considered to result in zone modelling being applicable to the assessment. As the subject warehouse could be separated into two separate tenancies, a floor area of approximately 800 m² has been considered for the purposes of modelling.

The major limitation of zone modelling techniques is the lack of details within the zone. Variation of temperature and densities within the zones (e.g. stratification, turbulence) is not modelled. However, with respect to enclosure volume, zone model programs have been extensively validated against data from smaller enclosures. In particular, the application of CFAST to smoke modelling in relatively large spaces has been verified in a number of instances, as reported below.

- By Chow¹⁶⁶ in comparing the smoke filling processes in an atrium of dimensions 30 m x 24 m and 25.3 m high (volume approx. 10,000 m³) with a 1.5 MW fire and the author stated that the model gave a satisfactory prediction of the experimental results.
- By Diong¹⁶⁷ in comparing the test results for a 38 MW fire with roof vents in an aircraft hanger of approximate dimensions of 54.2 m x 94 m with an affected roof of 60m maximum height. The model was used to predict the smoke filling process and the smoke layer depth and temperature. The FAST model was more conservative.

Project 6 – Fire Safety in Shopping Centres¹⁷¹ states that a zone model, such as CFAST, can be used to estimate the smoke layer (hot layer) depth in an enclosure in the event of a fire. Based on the above discussion, and given that the building layout for the area to be modelled feature a relatively simple, rectangular compartment, it is considered appropriate to employ zone modelling techniques for the purposes and the depth of this study.

Each compartment is modelled as two zones, a relatively 'hot' upper layer where the combustion effluents would accumulate and relatively 'cool' lower zone where the oxygen supply is obtained for combustion. It is assumed that physical properties such as temperature and density are uniform within a zone. The fire serves as the engine in the model to transfer mass and energy from the lower layer to the upper layer. In general, as the fire develops with time, the upper layer expands, its temperature increases and the interface of the two layers descends. The formation of two layers is in general accordance with what has been observed from room fire tests.

As discussed above, the major limitation of zone modelling techniques is the lack of details within the zone. Variation of temperatures and densities within the zones (e.g. stratification, turbulence) is not modelled. However, for the purposes and the depth of this study, it is considered appropriate to employ zone modelling techniques for the assessment.

The computer based zone fire model CFAST Version 3.1.7¹⁷² has been used to predict the interface smoke layer height for the selected fire scenarios and the results used to estimate tenancy conditions.

B.2. BASIC MODEL GEOMETRY

The warehouse has been considered in the model based on it being the worse-case scenario. The model inputs are shown in Table 6 below.

166 Chen, W.K., "A Short Note on the Simulation of Atrium Smoke Filling Process Using Fire Zone Models", Journal of Fire Sciences, Vol. 12, 1994, pp. 514-523.
167 Diong, D.O., "The Accuracy of Computer Fire Models: Some Comparisons with Experimental Data from Australia", Fire Technology, Vol. 1, 1990, pp. 415-427.
171 FRODO, Fire Safety in Shopping Centres, Final Research Report - Project 6, Fire Code Reform Centre Ltd, Sydney, Australia, 1998.
172 Peacock, Richard D., et al., FAST: The Consolidated Model of Fire Growth and Smoke Transport, NIST Technical Note, 1992, February 1992.




Figure 8 – BCA DBS design result

B.3. ASSET VALUES

Tenability Criteria

The environment around the evacuating occupants in the Level 1 carpark is deemed to have reached untenable conditions when the following temperatures occur:

1. Air / smoke temperature reaches 183°C (approximately equivalent to 2.5kW/m²) consistently across the entire fire enclosure at any height.
2. Air / smoke temperature reaches 60°C in the vicinity of the egress paths at a height of 2.1 m or less.

The criteria for tenability are generally derived from those presented in the International Fire Engineering Guidelines¹⁷³ and the SFPE Handbook¹⁷⁴.

Visibility within Floor slab

The environment around the evacuating occupants in the warehouse tenancy is deemed to have reached untenable conditions when stagnant smoke is formed below 2.1 m in the vicinity of the egress path which limits the visibility to less than 10 m, which is equivalent to an optical density of 0.1m⁻¹ or 1.0 db/m (e).

173 International Fire Engineering Guidelines (IFEG), Australian Building Codes Board, 2005.
174 SFPE Handbook of Fire Protection Engineering, 3rd ed, National Fire Protection Association, U.S., 2002.



Table 6 – Warehouse geometry for each scenario		
Model run	Floor area (m ²)	Average enclosure height (m)
Alternative pollution	20 x 40	10.35
BCA DBS design	20 x 40	2.4

B.3. SMOKE TOXICITY ASSESSMENT

Toxicity is required to be assessed in the event where smoke descends to less than 2.1m above floor level.
An assessment of the smoke concentration is not required to be undertaken, as the smoke layer height does not reach 2.1m throughout the course of the model.

B.4. ZONE MODELLING RESULTS

The modelling results from Figure 8 and Figure 9 indicate that the lower enclosure heights associated with the BCA DBS-compliant design lead to a more rapid descent of smoke.
Hot layer temperatures are similar for both designs for the initial period of burning that would coincide with the time during which occupants are evacuating from the car park.

Although these results should be treated with caution, due to the approximations associated with achieving a clear uniform layer height in a compartment with such a low ceiling height and the lack of detail in the model, the results do indicate that the model is capable of demonstrating the significant effects that the different geometries have on smoke spread and, as a result of this, the advantages associated with the geometry of the Alternative Solution.

Table 7 – Warehouse tenancy result

Scenario	Time to onset of untenability	Smoke layer height to reach below 2.1 m
Alternative Solution	Approx. 700 s	Approx. 600 s
BCA DBS compliant design	Approx. 100 s	Approx. 100 s



Figure 9 – Alternative Solution result



APPENDIX C FIRE BRIGADE INTERVENTION MODEL

C.1.

GENERAL

Fire brigade intervention time has been estimated from the Fire Brigade Intervention Model, developed by Australian Fire Authorities Council for use primarily in performance-based fire safety engineering design.¹⁷⁵

The FBIM is an event-based methodology, quantifying fire brigade actions from time of notification through to fire control and extinguishment. For this project, the model has been used to predict brigade arrival time on site and the time for commencement of fire-fighting activities. The intervention of the fire brigade may be critical in the event of a major fire or system component failure.

C.2. LOCATION OF FIRE SERVICES

In the event of an emergency in the building, FRNSW has advised that the closest responding fire stations would be Moya Vale Fire Station and Narrabeen Fire Station, as given in 2.1.5.

C.3. FIRE BRIGADE INTERVENTION MODEL

- The following considerations have been made in the adoption of the FBIM for this building:
- (i) The closest fire station at Moya Vale may not be available at the time of the incident. As such, the nearest fire station to the building, Narrabeen Fire Station, is used to estimate a worst-case response time. A worst-case response time is estimated for both fire stations from headquarters for line-ground attendance. This is consistent with FRNSW policy.
 - (ii) Fire brigade call-out is based on receipt of an automatic fire alarm, as there is a low probability of both the sprinkler system and the fire detection system failing to operate and transmit a signal to FRNSW, based on an estimated reliability for the sprinkler system of 80 per cent¹⁷⁶ and, for the fire detection system, 72 per cent¹⁷⁶ – the risk of both systems failing is approximately 3 per cent.
 - (iii) The Fire Brigade Intervention Model has been conducted with a safety factor based on the 90th percentile and assumed normal distribution for all activity times with the exception of travel to site. The travel time, which is based a travel speed, is related based on the average travel time for the fire brigade to the site. The model assumes a travel time of 9 minutes for the greater metropolitan area of 9 minutes for at least 80 per cent of incidents.¹⁷⁶
 - (iv) The FBIM model is to be used to arrive at a time that indicates the period in which the fire brigade will arrive at the site, setting-up equipment and the fire and carrying out fire-fighting activities at the site.
 - (v) Fire brigade access into the building is available from a bounding roadway on the eastern side of the building.

The main times associated with the fire brigade are summarised in Table 8.

Table 8 – Fire brigade intervention modelling summary

Event	Time (s)
Moya Vale Fire Station arrival	779 (~ 13 min)
Narrabeen Fire Station arrival	957 (~ 16 min)
Application of water	1 070 (~ 18 min)

175 Australian Fire Authorities Council, Fire Brigade Intervention Model, Version 2.2, Australia, October 2004.
176 NFPA, NFPA 72, National Fire Protection Association, Fire Alarm and Signaling Equipment, Fire Alarm and Research Division, National Fire Protection Association (NFPA), Quincy, MA, 2002.
177 England, J.P. & Young, S.A., Fire Risk Management for Buildings with Aged Accommodation, Fire Australia Proceedings.
178 Newman, R. W.; Burdick, E. K.; Schenck, C. F., Estimates of the Operational Reliability of Fire Protection Systems, Fire Protection Strategies for 21st Century Building and Fire Codes Symposium, EXTENDED ABSTRACTS, Proceedings, Society of Fire Protection Engineers and American Institute of Architects, September 17-18, 2002, Baltimore, MD, 11-15th, National Fire Protection Association, 2002.
179 NSW Audit Office, NSW Audit-General's Financial Audit, Volume 3b, Sydney, 2002.



GANTRY CHART OF FBI

GANTRY CHART OF FBI

determination of total fr

can be necessary at
minutes) for Mona Vale

Figure 10 - Free English Intervention Model Results

Figure 10 – Fire Brigade Intervention Model timelines

comp

GENERAL

GENERAL

Modelling has been used to study the dynamics of similar

considered suitable to
basement carpark.


species concentrations using the Smokeview¹²

MODEL GEOMETRY

MODEL GEOMETRY

air/gas mixture has been
combustion.

An internal layout of the




Model inputs

Model inputs




Each scenario was run

Each scenario was run



D.4.2

Scenario 1b




Exova
Washington

Exova
Washington




D.4.2

Scenario 2a



D.4.4

Scenario 2b



D.4.5

Scenario 2a (Alternative Solution)

Exova
Washington

Exova
Washington




Figure 24 – Scenario 2a velocity at 200 seconds




Figure 25 – Scenario 2a velocity at 400 seconds




Figure 24 – Scenario 2a velocity at 200 seconds

7.4.4 Scenario 2b (Alternative Solution)




Figure 25 – Scenario 2b velocity at 200 seconds




Figure 26 – Scenario 2b velocity at 400 seconds




Figure 27 – Scenario 2b velocity at 200 seconds

APPENDIX E BASINENT CARPARK SPRINKLER ACTIVATION SLIDE FILES




Figure 28 – Driveway fire with Standard sprinkler (without jet-down) activation time




Figure 29 – Driveway fire with Standard sprinkler (with jet-down) activation time




Figure 30 – Driveway fire with fast response sprinkler (with jet-fan) activation time




Figure 31 - Parked car fire with Standard sprinkler (no jet-fan) activation time




Figure 32 – Parked car fire with standard sprinkler (with jet-fan) activation time






Figure 33 - Partial car fire with fast-response Sprinkler (with let-go) activation time





APPENDIX F JET FAN SPECIFICATION




- [illegible]



-



APPENDIX G ALLUCOBOND CERTIFICATE OF CONFORMITY



APPENDIX H ALUCOBOND TEST REPORT EXCERPT



TEST REPORT 14576A

Sponsor

SA COMPOSITES GmbH
Alkungerplatz 1
78224 SINGEN
GERMANY

Construction product and trade name
Composite panels "ALUCOBOND® plus"

Nature of the test

Full-scale room test for surface products according to ISO 9705 - 1st edition 1993

Summary of the results

FIGRA ₉₀ (W/s)	0.427
THR ₉₀ (kJ)	170.48
SHOORA value (m ² /s)	1.388
TSP ₉₀ (m ²)	550.1
Time to flash over (s)	No flash over

Ghent, 9 & 10th 2010

Prof. F. DUTRIEUX
Project manager

Prof. Dr. P. VANDEVELDE
Director

ISO 9705-WG-1E

This report contains 16 pages including 7 annexes

This document is the original version of this test report and is written in English.

This report may be used only briefly and completely for publications. - For publications of certain parts, in which this report is mentioned, our permission must be obtained in advance.



WARRINGTON - Chemiedienstleistungen 24h 7/11 - 24h-Notdienst - Belgien
T: +32(0) 243 77 30 - F: +32(0) 243 77 31 - E: info@warringtonbelgium.com
WARRINGTON - Dienstleistungen 24h 7/11 - 24h-Notdienst - Belgien



WARRINGTON ist ein zertifiziertes Unternehmen für die Umwelt und die Arbeitssicherheit nach ISO 14001 und ISO 45001. WARRINGTON ist ein zertifiziertes Unternehmen für die Arbeitssicherheit nach ISO 45001. WARRINGTON ist ein zertifiziertes Unternehmen für die Arbeitssicherheit nach ISO 45001.



Test Report Nr 14576A
Page 2 of 16



1. DESCRIPTION OF THE TEST METHOD

ISO 9705 - 1993 - Full-scale room test for surface products according to ISO 9705.

The standard ISO 9705 prescribes the following procedure:

- 0 - 10 minutes: heat output level of the burner: 100 kW
- 10 - 20 minutes: heat output level of the burner: 300 kW
- 20 minutes: extinction of the burner

2. IDENTIFICATION OF THE PRODUCT

Date of sample arrival : 2010-07-12

Identification of the samples : Not applicable

Remission done by : The sponsor

Remission date : Not communicated

Name of the manufacturer / supplier : SA COMPOSITES GmbH
Architecture & Display Europe / CT
Alkungerplatz 1
78224 SINGEN
GERMANY

Trade name : ALUCOBOND® plus

Description of the product :

This description is based on information given by the sponsor.

The tested product consists of composite panels aluminium substrate outside, lacquered on both sides; mineral filled core inside bonded with polyolefin based medium.

WARRINGTON ist ein zertifiziertes Unternehmen für die Umwelt und die Arbeitssicherheit nach ISO 14001 und ISO 45001. WARRINGTON ist ein zertifiziertes Unternehmen für die Arbeitssicherheit nach ISO 45001. WARRINGTON ist ein zertifiziertes Unternehmen für die Arbeitssicherheit nach ISO 45001.



Niky Makroglou

From: Niky Makroglou
Sent: Friday, 29 May 2015 10:17 AM
To: 'bfs@fire.nsw.gov.au'
Cc: Tony Heaslip
Subject: Notice of Design Change - BFS15/399 (6766) 2 Daydream Street, Warriewood
Attachments: 26664700-RPT01-8.pdf; Request for Report - Initial Fire Safety Report Notice of Design Change Form.docx

Please find attached Notice of Design Change Form and Fire Engineering Report Revision 8.

Kind Regards

Niky Makroglou
Personal Assistant



**BLACKETT
MAGUIRE+
GOLDSMITH**

SYDNEY
Suite C2.01,22-36
Mountain St
Ultimo
PO Box 167,
Broadway NSW
2007

WOLLONGONG
Suite 1, 100
Railway St,
Corrimal
PO Box 90,
Corrimal NSW
2518

Ph: 02 9211 7777 **Fax:** 02 9211 7774 Wollongong **Ph:** 02 4285 5696

www.bmplusg.com.au

This e-mail and attachments (if any) is intended only for the addressee(s) and is subject to copyright. This email contains information which may be confidential or privileged. If you are not the intended recipient please advise the sender by return email, do not use or disclose the contents and delete the message and any attachments from your system. Unless specifically stated, this email does not constitute formal advice or commitment by the sender or Blackett Maguire + Goldsmith Pty Ltd or any of its subsidiaries.

Niky Makroglou

From: BFS <BFS@fire.nsw.gov.au>
Sent: Friday, 29 May 2015 7:57 PM
To: Niky Makroglou
Subject: RE: Notice of Design Change - BFS15/399 (6766) 2 Daydream Street, Warriewood

Fire & Rescue NSW acknowledge receipt of your email and supporting documentation.

If you have any further queries regarding this matter, please contact the Fire Safety Branch on 9742 7434 quoting your reference number.

Fire Safety Branch
Community Safety Directorate



E bfs@fire.nsw.gov.au | T (02) 9742 7434 | F (02) 9742 7483 | www.fire.nsw.gov.au
Amarina Avenue, Greenacre, NSW 2190 | Locked Bag 12, Greenacre, NSW 2190

[Twitter.com/FRNSW](https://twitter.com/FRNSW) | [Facebook.com/FRNSW](https://facebook.com/FRNSW) | [YouTube.com/FireAndRescueNSW](https://youtube.com/FireAndRescueNSW)

Do a Home Fire Safety Audit. It could save your life. www.homefiresafetyaudit.com.au

From: Niky Makroglou [<mailto:niky@bmplug.com.au>]
Sent: Friday, 29 May 2015 10:17 AM
To: BFS
Cc: Tony Heaslip
Subject: Notice of Design Change - BFS15/399 (6766) 2 Daydream Street, Warriewood

Please find attached Notice of Design Change Form and Fire Engineering Report Revision 8.

Kind Regards

Niky Makroglou
Personal Assistant



**BLACKETT
MAGUIRE+
GOLDSMITH**

SYDNEY
Suite
C2.01,22-36
Mountain St
Ultimo
PO Box 167,
Broadway
NSW 2007

WOLLONGONG
Suite 1, 100
Railway St,
Corrimal
PO Box 90,
Corrimal NSW
2518

Ph: 02 9211 7777 Fax: 02 9211 7774 Wollongong Ph: 02 4285 5696

www.bmplusg.com.au

This e-mail and attachments (if any) is intended only for the addressee(s) and is subject to copyright. This email contains information which may be confidential or privileged. If you are not the intended recipient please advise the sender by return email, do not use or disclose the contents and delete the message and any attachments from your system. Unless specifically stated, this email does not constitute formal advice or commitment by the sender or Blackett Maguire + Goldsmith Pty Ltd or any of its subsidiaries.

This message, and any files transmitted with it, is intended only for the addressee named and may contain confidential and/or legally professional privileged material. If you are not the intended recipient, please delete it and notify the sender immediately. Any retransmission, dissemination, reliance on or other use of this communication by people other than the intended recipient is prohibited. Views expressed in the message are those of the individual sender, and are not necessarily the views of Fire & Rescue NSW. Use of electronic mail is subject to FRNSW policy and guidelines. FRNSW reserves the right to filter, inspect, copy, store and disclose the contents of electronic mail messages, as authorised by law.