

Environmental Health Referral Response - acid sulfate soils

Application Number:	DA2021/1511
Date:	08/09/2021
Responsible Officer	Gareth David
Land to be developed (Address):	Lot 1 DP 105823 , 33 Beach Road COLLAROY NSW 2097

Reasons for referral

This application seeks consent for one or more of the following:

- All development in class 1 land
- Any works below ground surface or will lower water table in area class 2 land
- Any works beyond 1 metre or lower water table by 1 metre in class 3 land
- Any works beyond 2 metres or lower water table by 2 metres in class 4 land
- Works on land below 10 metres AHD and within 500m of class 1, 2, 3 or 4 land which are likely to lower water table below 1 metre

And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

Officer comments

General Comments

Investigation of soils was demonstrated via acid sulfate soil and geotechnical reports. No actual or potential acid sulfate soils were found in the area of proposed excavations.

Environmental Health is satisfied that the information provided is an adequate representation of the subsurface soil profile, and have no objections to the proposal.

Recommendation

APPROVAL - no conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Investigations Conditions:

Nil.