

Natural Environment Referral Response - Coastal

Application Number:	DA2019/1242
Responsible Officer	Kye Miles
Land to be developed (Address):	Lot 1 DP 1035682 , 159 Riverview Road AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The application has been assessed in consideration of the Coastal Management Act 2016, State Environmental Planning Policy (Coastal Management) 2018 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development.

The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Coastal Management) 2018

As the subject site has been identified as being within the coastal zone and therefore SEPP (Coastal Management) 2018 is also applicable to the proposed development.

The subject land has been included on the 'Coastal Environment Area' and 'Coastal Use Area' maps but not been included on the Coastal Vulnerability Area Map under the State Environmental Planning Policy (Coastal Management) 2018 (CM SEPP). Hence, Clauses 13, 14 and 15 of the CM SEPP apply for this DA.

Comment:

On internal assessment, the DA satisfies requirements under clauses 13, 14 and 15 of the CM SEPP.

As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Coastal Management) 2018.

Pittwater LEP 2014 and Pittwater 21 DCP

The subject property has also been identified as affected by estuarine wave action and tidal inundation on Council's Estuarine Hazard Mapping. As such, the Estuarine Risk Management Policy for Development in Pittwater (Appendix 7, Pittwater 21 DCP) and the relevant B3.7 Estuarine Hazard Controls will apply to any proposed development of the site.

Estuarine Risk Management

In accordance with the Pittwater Estuary Mapping of Sea Level Rise Impacts Study (2015), a base estuarine planning level (EPL) of RL 2.66m AHD would apply at the subject site. A reduction factor (RF) based upon the distance from the foreshore of proposed development may also apply at a rate of 0.07m reduction to the EPL for every 5.00m distance from the foreshore edge up to a maximum distance of 40.00m.

On internal assessment, the ground floor level for the proposed disabled access platform is much above the applicable EPL of 2.66m AHD for the site.

The proposed development is therefore able to satisfy the relevant estuarine risk management requirements of P21 DCP.

Referral Body Recommendation

Recommended for approval

Refusal comments

Recommended Natural Environment Conditions:

Nil.