



## NSW RURAL FIRE SERVICE

Northern Beaches Council  
PO Box 882  
MONA VALE NSW 1660

Your reference: DA2023/0379 (CNR-54582)  
Our reference: DA20230629002829-Original-1

**ATTENTION:** Northern Beaches Council

Date: Tuesday 1 August 2023

Dear Sir/Madam,

**Integrated Development Application**  
**s100B – Subdivision – Subdivision**  
**107 Iris Street Beacon Hill NSW 2100, 18//DP19022**

I refer to your correspondence dated 29/06/2023 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

### Asset Protection Zones

***Intent of measures: to provide sufficient space and maintain reduced fuel loads to ensure radiant heat levels at the buildings are below critical limits and prevent direct flame contact.***

1. At the issue of a subdivision certificate, and in perpetuity to ensure ongoing protection from the impact of bush fires, the entirety of the proposed residential lots (Lots 1 to 4 inclusive) must be managed as an inner protection area (IPA) in accordance with the requirements of Appendix 4 of Planning for Bush Fire Protection 2019. When establishing and maintaining an IPA the following :

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover; and
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and

#### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

- leaves and vegetation debris should be removed.

When establishing and maintaining an outer protection area (OPA) the following requirements apply:

- trees tree canopy cover should be less than 30%;
- canopies should be separated by 2 to 5m.
- shrubs should not form a continuous canopy;
- shrubs should form no more than 20% of ground cover;
- grass should be kept mown to a height of less than 100mm; and
- leaf and other debris should be removed.

### **Access – Property Access**

***Intent of measures: to provide safe operational access to structures and water supply for emergency services, while residents are seeking to evacuate from an area.***

2. Property access roads must comply with the general requirements of Table 5.3b of *Planning for Bush Fire Protection 2019* and the following:

- property access roads are two-wheel drive, all-weather roads;
- minimum 4m carriageway width;
- a minimum vertical clearance of 4m to any overhanging obstructions, including tree branches;
- provide a suitable turning area in accordance with Appendix 3;
- curves have a minimum inner radius of 6m and are minimal in number to allow for rapid access and egress;
- the minimum distance between inner and outer curves is 6m; the crossfall is not more than 10 degrees;
- maximum grades for sealed roads do not exceed 15 degrees and not more than 10 degrees for unsealed roads; and
- Some short constrictions in the access may be accepted where they are not less than 3.5m wide, extend for no more than 30m and where the obstruction cannot be reasonably avoided or removed.

### **Water and Utility Services**

***Intent of measures: to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.***

3. The provision of water, electricity and gas must comply with the following in accordance with Table 5.3c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419.1:2005;
- hydrants are and not located within any road carriageway;
- reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:

a) lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and

b) no part of a tree is closer to a power line than the distance set out in accordance with the specifications in ISSC3 Guideline for Managing Vegetation Near Power Lines.

- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - The storage and handling of LP Gas, the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

**General Advice - Consent Authority to Note**

- This approval is for the subdivision of the land only. Any further development application for class 1,2 & 3 buildings as identified by the *National Construction Code of Australia* may be subject to separate application under section 4.14 of the *EP & A Act* and address the requirements of *Planning for Bush Fire Protection 2019*.

For any queries regarding this correspondence, please contact Craig Casey on 1300 NSW RFS.

Yours sincerely,

Nika Fomin  
**Manager Planning & Environment Services**  
**Built & Natural Environment**



**NSW RURAL FIRE SERVICE**

# **BUSH FIRE SAFETY AUTHORITY**

Subdivision – Subdivision

107 Iris Street Beacon Hill NSW 2100, 18//DP19022

RFS Reference: DA20230629002829-Original-1

Your Reference: DA2023/0379 (CNR-54582)

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

**Nika Fomin**

**Manager Planning & Environment Services  
Built & Natural Environment**

Tuesday 1 August 2023