

Natural Environment Referral Response - Riparian

Application Number:	DA2021/0321
Date:	14/04/2021
To:	Adam Mitchell
Land to be developed (Address):	Lot 19 DP 14883 , 5 Elvina Avenue AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed application, for the development of a carport, has been assessed against relevant legislation for the protection of waterways. It does not significantly increase impervious surfaces. Standard sediment and erosion controls must be installed prior to the commencement of works. With the appropriate controls it is considered unlikely that the development will have an adverse impact on the integrity and resilience of the biophysical, ecological and hydrological environment.

It is therefore recommended for approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prepared by Nvisage prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.