


# SIGNAGE DESIGN

ARTISTIC DESIGN - SHOWN FOR VISUAL REPRESENTATION PURPOSES OF THE SIGNAGE ELEMENTS ONLY

### SITE INVESTIGATION

- A COMPLETE INVESTIGATION OF SERVICES HAS NOT BEEN UNDERTAKEN FOR THIS SITE PLAN.
- SERVICES LOCATIONS, DEPTHS AND INVERTS HAVE BEEN LOCATED BY FIELD SURVEY OR TAKEN FROM DBYD OR COUNCIL DOCUMENTS.
- CONFIRMATION OF CRITICAL POSITIONS SHOULD BE OBTAINED WITH ON SITE DETECTION SERVICES.
- THIS PLAN SHOULD NOT BE USED FOR CRITICAL DESIGN DIMENSIONS IN RELATION TO EXISTING STRUCTURES AND SERVICES.
- PRIOR TO ANY DEMOLITION, EXCAVATION OR CONSTRUCTION ON THE SITE, AUTHORITIES SHOULD BE CONTACTED FOR LOCATION OF ALL SERVICES.
   NEGLECTING TO DIAL 1100 BEFORE DIGGING OR EXCAVATING CAN LEAD TO COSTLY DISRUPTION TO ESSENTIAL SERVICES, AND INJURY OR DEATH TO WORKERS AND THE GENERAL PUBLIC. IT CAN ALSO LEAD TO HEAVY FINANCIAL PENALTIES.









CLIE

BROOKVALE PUBLIC SCHOOL

**PROJECT** 

INSTALLATION OF DIGITAL SIGN

LOCATION

LOT 14 DP 5876 2-8 OLD PITTWATER ROAD BROOKVALE NSW 2100

### GENERAL NOTES:

Figured dimensions take preference, do not scale from plans. IF IN DOUBT, ASK.
Contractions are responsible to check and verify all information prior to tendering
and shall report any discrepancies or omissions.

Incorrect inclusions or omissions or typographical errors are not be used in the interpretation of any information in these drawings. Nor can they be used to claim any additional or alternate items or services as a result of such errors. The incorrect or omitted details shall be subject to subsequent correction by CEO and the documentation re-issued.

These drawings are to be read in conjunction with the relevant client-builder contract. The contract is to take precedence over these drawings in all matters including but not limited to: finishes, inclusions, upgrades, exclusions, additional costs and works by owner/builder.

All work to be carried out in a tradesman like manner, and in accordance with

All work to be carried out in a tradesman like manner, and in accordance with local codes, the BCA, Australian Standards and any relevant authority requirements.

requirements.


All concrete and structural details to engineer's specification.

Engineers details and specifications take precedence over these plans.

Finished ground levels are approximate only and should be confirmed onsite

### ALL CONTENT COPYRIGHTED:-

This design and/or print is the property of CEO Design & Consult Pty Ltd. and is protected by the Commonwealth Copyright Act 1948. It must not be used or reproduced in whole or in part without written permission. Any attempt to copy, use or reproduce the same, in whole or in part, will result in legal proceedings. A single use licence will be granted to the person/s named as CLIENT in relation to their respective plan. The design may only be constructed on the land stated as LOCATION. Final permission will only be deemed granted upon receipt of full powment for all services.





CHEET TITLE

SITE NOTIFICATION PLAN

SHEET No.

° SPC223027





## MEMBER SCHEDULE

MEMBER	SIZE	COMMENTS
C1	127x127x6 SHS	ALU 6060 T5 (FULLY WELDED FRAME)
B1	50x50x3.0 RHS	ALU 6060 T5 (FULLY WELDED FRAME)

ELEVATION SCALE 1:50

ALL ALUMINIUM & STEEL TO BE SEPARATED WITH NEOPRENE WASHERS/PADS + 'TEFGEL'.

TITLE:

FOR CONSTRUCTION

ISS	DATE	COMMENT
1	23/11/16	FOR CONSTRUCTION
2	08/09/17	RE-ISSUED FOR CONSTRUCTION



Suite 1, Building 8, 49 Frenchs Forest Road East, Frenchs Forest, NSW 2086 P.O. Box 652, Forestville, NSW 2087 Ph: 02 9451 3455 Fax: 02 9451 3466 Email: info@dbce.com.au

ABN 23 039 013 724

CLIENT:
SIGNPAC

SIGNPAC DIGITAL SIGN

PROJECT:

SINGLE SIDED DIGITAL SIGN

DRAWN RAS	DESIGN JL	DATE:	Nov'16
JOB NO:	16335	DWG N	O: S02
SCALE @ A	A3: AS SHOWN	REV: 2	

## **GENERAL**

- G1. THESE DRAWINGS SHALL BE READ IN CONJUNCTION WITH ALL ARCHITECTURAL AND OTHER CONSULTANTS

  DRAWINGS AND SPECIFICATIONS AND WITH SUCH OTHER WRITTEN INSTRUCTIONS AS MAY BE ISSUED.
- G2. ANY QUERIES OR DISCREPANCIES SHALL BE REFERRED TO THE ENGINEER OR PROJECT MANAGER FOR A DECISION PRIOR TO PROCEEDING WITH THE WORK.
- G3. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH THE APPROPRIATE AUSTRALIAN STANDARD AND THE BCA AS AMENDED.
- G4. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
- GS. ALL DIMENSIONS SHALL BE VERIFIED BY THE BUILDER ON SITE PRIOR TO ANY FABRICATION OR CONSTRUCTION.
- G6. DIMENSIONS AND SITE SETOUT SHALL NOT BE OBTAINED BY SCALING THE STRUCTURAL DRAWINGS.
- G7. TEMPORARY BRACING OR PROPPING TO ENSURE THE STRUCTURE IS KEPT IN A STABLE STATE IS THE RESPONSIBILITY OF THE BUILDER.
- G8. THE STRUCTURAL ELEMENTS SHOWN ON THESE DRAWINGS HAVE BEEN DESIGNED FOR THE FOLLOWING LIVE LOADS:

STRUCTURAL ELEMENT	LIVE LOAD kPa
N/A	N/A

#### G9. WIND LOADS TO AS1170.2

REGION	A	В	C
WIND TERRAIN CATEGORY	3	3	3
REGION WIND SPEED ULS V500	45m/s	57m/s	69.3m/s
REGION WIND SPEED SLS V1	30m/s	26m/s	23m/s

### FOUNDATIONS

- F1. THE FOUNDATIONS HAVE BEEN DESIGNED FOR AN ALLOWABLE BEARING PRESSURE OF 150 KPα.
- F2. APPROVAL OF THE FOUNDING MATERIAL SHALL BE OBTAINED FROM THE ENGINEER OR GEOTECHNICAL ENGINEER PRIOR TO PLACING THE CONCRETE.
- F3. EXCAVATION NEAR FOOTINGS SHALL NOT EXTEND BELOW THE BASE OF THE FOOTINGS WITHOUT THE APPROVAL OF THE ENGINEER.
- F4. THE BUILDER IS RESPONSIBLE FOR MAINTAINING ANY EXCAVATION IN A STABLE CONDITION WITHOUT AFFECTING SURROUNDING PROPERTY FOR SERVICES. BUILDER TO ALLOW FOR ALL SHORING REQUIRED FOR EXCAVATION OF PILE CAPS
- F5. BUILDER TO ALLOW FOR REMOVAL OF ALL SPOIL FROM SITE FROM EXCAVATIONS, PILING AND PIERING.
- F6. ALL TOP-SOIL & LOOSE MATERIAL TO BE REMOVED FROM THE SLAB AREA. COMPACTED FILL IN ACCORDANCE WITH AS2870 SECTION 6.4 IF REQUIRED.

### CONCRETE

- C1. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH THE LATEST VERSION OF AS3600.
- C2. 'READYMIX' CONCRETE SHALL COMPLY WITH AS1379 AND HAVE THE FOLLOWING QUALITY.

STRUCTURAL ELEMENT	AS3600, f'c (Mpa) AT 28 DAYS	SLUMP (mm)	AGG SIZE (mm)
PIERS	32	80	20

- C3. ALL CONCRETE SHALL BE MECHANICALLY VIBRATED TO GIVE MAXIMUM COMPACTION WITHOUT SEGREGATION OF THE CONCRETE.
- C4. THE DESIGN, CONSTRUCTION, INSPECTION AND CERTIFICATION OF THE FALSEWORK, FORMWORK, PROPPING OR LOADING OF STRUCTURES DURING CONSTRUCTION BY THE FALSEWORK OR PROPPING SHALL BE THE RESPONSIBILITY OF THE BUILDER AND SUB-CONTRACTORS.
- C5. CLEAR CONCRETE COVER TO THE REINFORCEMENT SHALL BE AS FOLLOWS:

STRUCTURAL ELEMENT	COVER INTERNAL (mm)	COVER EXTERNAL (mm)
PIERS	45 ALL AROUND	

### CONCRETE (CONTINUED)

C6. LAPPED SPLICE LENGTHS FOR HORIZONTAL BARS WITH MORE THAN 300mm CONCRETE CAST BELOW THE BAR & SPACED AT ≥ 150mm CENTRES TO COMPLY WITH THE FOLLOWING U.N.O:-

COVER	fc	N12	N16	N20	N24	N28	N32
≥25	≥20	770	1150	1570	-	-	•
≥30	≥25	630	980	1350	1740	-	-
≥40	≥32	510	770	1100	1440	1810	2230
≥50	≥40	460	630	890	1200	1530	1890

DO NOT INTERPOLATE INTERMEDIATE VALUES OF SPLICE LENGTHS.

LAPPED SPLICE LENGTHS FOR BARS IN COLUMNS REFER TO AS3600 OR SUPERINTENDENT.

EPOXY COATED BARS, BARS IN LIGHTWEIGHT CONCRETE & SLIP FORMED CONCRETE WILL REQUIRE LONGER

SPLICE LENGTHS. REFER TO AS3600 OR SUPERINTENDENT.

C7. LAPPED SPLICE LENGTHS FOR VERTICAL BARS (& HORIZONTAL BARS WITH LESS THAN 300mm CONCRETE CAST BELOW THE BAR) SPACED AT ≥150mm CENTRES TO COMPLY WITH THE FOLLOWING:-

COVER	fc	N12	N16	N20	N24	N28	N32
≥25	≥20	590	890	1210	-	-	-
≥30	≥25	490	750	1040	1340	-	-
≥40	≥32	390	600	840	1110	1400	1710
≥50	≥40	350	480	690	920	1180	1450

NOT APPLICABLE FOR BARS IN COLUMNS.

DO NOT INTERPOLATE INTERMEDIATE VALUES OF SPLICE LENGTHS.

LAPPED SPLICE LENGTHS FOR BARS IN COLUMNS REFER TO AS3600 OR SUPERINTENDENT.

EPOXY COATED BARS, BARS IN LIGHTWEIGHT CONCRETE & SLIP FORMED CONCRETE WILL REQUIRE LONGER

ONE SHEET OVERLAP TWO OUTERMOST WIRES OF ADJACENT SHEET BY AT LEAST 25mm, THUS:-

SPLICE LENGTHS. REFER TO AS3600 OR SUPERINTENDENT.
PROVIDE MINIMUM MESH LAPS TO CROSS WIRES OF REINFORCING MESH SO THAT TWO OUTERMOST WIRES OF

MESH TYPE	END LAP	SIDE LAP
RECTANGULAR MESHES	225	125
SQUARE MESHES SL102 TO SL42	225	225
SL81	125	125
TRENCH MESH	500	N/A

USE LAP LENGTHS BASED ON LARGEST WIRE SPACING. DO NOT LAP MORE THAN THREE SHEETS AT ANY ONE POINT

- C9. REINFORCEMENT SHALL NOT BE HEATED OR WELDED ON SITE WITHOUT THE APPROVAL OF THE ENGINEER.
- C10. ALLOW FOR N12-300 SUPPORT BARS PERPENDICULAR TO ALL REINFORCEMENT WHERE NO PERPENDICULAR BARS ARE SHOWN ON PLAN.
- C11. REINFORCEMENT SHALL BE IN ACCORDANCE WITH AS1302 AND AS4671 FOR 500 MPa REINFORCEMENT AND DUCTILITY CLASS N.

  IN ACCORDANCE WITH AS1303, 1304 AND AS4671 FOR 500 MPa REINFORCEMENT DUCTILITY CLASS L.
- C12. DAMP PROOF MEMBRANE SHALL BE 'FORTECON' ORANGE POLYTHENE.
- C13. 250 INDICATES SUSPENDED SLAB THICKNESS.
- C14. (250) INDICATES SLAB ON GROUND THICKNESS.

### STRUCTURAL STEEL

- S1. ALL MATERIALS AND WORKMANSHIP SHALL BE IN ACCORDANCE WITH AS4100, AS1554 AND AS4600.
- S2. STEEL MEMBERS TO HAVE THE FOLLOWING GRADES:

MEMBER	GRADE
HOT ROLLED SECTIONS UB's, UC's, PFC's AND ANGLES	300
HOLLOW SECTIONS CHS, SHS AND RHS	350
COLD FORMED PURLINS AND GIRTS	400
FLAT BARS, PLATES AND RODS	250

#### S3. BOLT DESIGNATION:

4.6/S GRADE 4.6 BOLTS TO AS1111 SNUG TIGHTENED

8.8/S HIGH STRENGTH GRADE 8.8 TO AS1252 SNUG TIGHTENED

8.8/TB HIGH STRENGTH GRADE 8.8 TO AS1252 FULLY TENSIONED TO

AS4100 AS A BEARING JOINT

HIGH STRENGTH GRADE 8.8 TO AS1252 FULLY TENSIONED TO

AS4100 AS A FRICTION JOINT WITH CONTACT SURFACES LEFT UNCOATED

- S4. ALL BOLTS TO BE M20 GRADE 8.8/S U.N.O ON STRUCTURAL DRAWINGS. NO STEEL TO STEEL CONNECTION TO HAVE LESS THAN 2 BOLTS.
- S5. ALL PLATES, GUSSETS, FINS ETC TO BE 10mm THICK MINIMUM.

  ALL WELDS TO BE 6mm CONTINUOUS FILLET WELDS ALL AROUND U.N.O.

  BUTT WELDS TO BE FULL PENETRATION.

  ELECTRODES TO BE E48XX/W50X U.N.O.

  ALL WELDS TO BE STRUCTURAL PURPOSE (SP) U.N.O.
- S6. THE BUILDER SHALL PROVIDE ALL CLEATS AND HOLES NECESSARY FOR ALL ATTACHMENTS WHETHER SHOWN ON STRUCTURAL DRAWINGS OR NOT.
- S7. PROVIDE HOOK BOLTS FROM BRACING TO PURLINS AT BRACING MID POINT TO PREVENT SAG IN BRACING.
- S8. THE BUILDER SHALL MAINTAIN THE STRUCTURE AND STRUCTURAL STEEL IN A STABLE CONDITION DURING THE CONSTRUCTION AND SHALL PROVIDE TEMPORARY BRACING, FALSEWORK OR PROPPING AS REQUIRED TO ACHIEVE THIS. THIS BRACING ETC SHALL BE AT THE COST OF THE BUILDER.
- S9. THE BUILDER SHALL PROVIDE 4 COPIES OF STRUCTURAL STEEL SHOP DRAWINGS FOR APPROVAL BY THE ENGINEER 14 DAYS PRIOR TO FABRICATION.
- S10. STRUCTURAL STEELWORK TO HAVE THE FOLLOWING SURFACE TREATMENT:

ELEMENT		SURFACE TREATMENT	SURFACE COATING				
	ALL STEEL	PICKLE TO AS1627 PART 5	HOT DIP GALVANISE TO AS4680:2006				

S11. ALL SITE WELDED GALVANIZED STEELWORK TO BE PAINTED WITH 2 COATS OF 'GALVANITE'.

FOR CONSTRUCTION

ISS DATE COMMENT CLIENT: DRAWN **DESIGN** Suite 1, Building 8, 49 Frenchs Forest Road East DATE: Nov'16 23/11/16 FOR CONSTRUCTION RAS **SIGNPAC** Frenchs Forest, NSW 2086 STRUCTURAL NOTES 2 25/11/16 STEELWORK NOTES ADDED P.O. Box 652, Forestville, NSW 2087 JOB NO: 16335 DWG NO: S01 Dennis Bunt Ph: 02 9451 3455 Fax: 02 9451 3466 PROJECT: Email: info@dbce.com.au SIGNPAC DIGITAL SIGN ABN 23 039 013 724 SCALE @ A3: AS SHOWN | REV: 2

Brookvale Public School Date: 24/10/2023





The artwork supplied by Signpac is claimed as copyright by our author. This artwork has been developed by Signpac for the exclusive manufacture by Signpac for the application solely designed as shown. Any reproduction of this artwork, elements of the graphic design and or structure are copyright for the intended use only. The future use of the design on other intended and specified sign projects remain the copyright design of Signpac.

"Copyright Signpac 2020 ©"

Contact | T: 1800 140 940 | P: 02 9987 4900 | F: 02 9987 4911 | E: Sales@signpac.com.au

Schedule of Colours & Finishes

Brookvale Public School
2-8 Old Pittwater Rd, Brookvale NSW 2100

Version A



ABN 23 039 013 724 Suite 1, Building 8 49 Frenchs Forest Road East Frenchs Forest NSW 2086

PO Box 652 Forestville, NSW, 2087 PH: (02) 9451 3455 FX: (02) 9451 3466 Email:info@dbce.com.au

27<sup>th</sup> March 2020

Signpac 20/45 Leighton Place Hornsby, NSW, 2077

Ref: 16335

## Structural Design Certification Signpac Digital Signs

We, Dennis Bunt Consulting Engineers Pty Ltd, certify that we have designed the structural components for the single sided and double sided digital signs, as shown on our structural engineering drawings for job number 16335:- S01 [2], S02 [4], S03 [4], S04 [1], S05 [2] & S06 [2]. We certify that the digital signs are structurally adequate for Wind Region A, B & C, Terrain Category 3 in accordance with the following structural Australian Standards and relevant structural sections of the BCA.

- AS 1664.1: 1997 Aluminium Structures
- AS 4100: 1998 Steel Structures
- AS 3600: 2018 Concrete Structures
- AS 1170 Structural Design Actions

We also certify that the footing has been designed for an allowable bearing pressure of 150 kPa in Wind Region A, B & C, Terrain Category 3.

This certificate shall not be construed as relieving any other party of their responsibilities, liabilities or obligations.

Yours Faithfully.

John Linsell BE(Hons), MIEAust, CPEng, NPER(Struct) for Dennis Bunt Consulting Engineers Pty Ltd.

	SCHOOL SIGNS by Signpac
MODULE	

Company:	Signpac					
Address:	20/45 Leighton Place Hornsby NSW 2077					
Contact:	act: Kishwor Poudel		1800 140 940			
Email:	sales@signpac.com.au	Website:	www.signpac.com.au			

### Technical specification :P6.67SMD Outdoor LED Sign

#### MODULE



Pixel Pitch		6.67								
LED Lamp			SMD wit	h gold wire						
Dimension	Wi	dth		Height	Total					
Dimension	320	mm	320	mm	0.1024	m²				
Resolution	48	Pixel	48	Pixel	2,304	Pixel				

## **CABINET -Single sided**



Lifetime

Humidity

Running Files

Ingress Protection

Running Temperature

Dimension without border	Width			Height	Total			
Differsion without border	1920	mm	960	mm	1.8432	m²		
Dimension with border	2000	mm	1040	mm	1.7472	m²		
Resolution	288	pixel	144	pixel	41,472	pixel		
Thickness	145mm							
Weight	71KG							
Material	Aluminium							

## SCREEN

Item		Description								
Model		P6.67								
	Size	1.920	m	(W)	Χ	0.960	m	(H)=	1.8432	m²
LED sign	Resolution	288	pixels	(W)	Х	144	pixels	(H)=	41,472	pixels
	Maximum input Current for this sign	7.5 Amperage								
	Average input Current	2.5Amperage								
	Brightness	≥6000CD/M²								
90.00	Colors	281 Trillion								
	Viewing angle	H:140°, V:140°								
Bradbury Public School	Best Viewing Distance	>6 meters								
	Gray Scale	65535								
	Input Power	110~240V 50 or 60Hz								
1000 ( 100 mg)	Driving Mode	1/6 constant current								
	Refresh Rate	≥1920Hz								
	Control Mode	Asynchronization control ( offline play content )								

100,000 Hours plus

Text&Picture&Video

Rear:IP54

**–20**°C ∼ +60°C

10% ~90%

Front:IP65,



## MAKING SCHOOLS SEEN & SAFE

## **Electronic Digital Sign Electrical requirements**

Please pass this information to your electrical contractor.

Power: 240v 50hz Amps usage:

Single side sign: approx. 7amps Double side sign: Approx. 12amps

### **Electrical Cable:**

For short runs 2.5mm TPS twin & earth. Thicker dependant on distance.

- 1. The sign must be on its own circuit, sourced from the nearest electrical point/building that has a switchboard where the sign has its own isolation switch. A 15amp isolation switch for single sided sign and a 20 amp for a double-sided sign will suffice.
- 2. On the sign frame, a lockable waterproof on/off switch needs to be secured on the backside of the frame, either up high or near the footing.
- 3. The sign will come with a cable directly connected by us in the inside. This cable has approx. 5 Mtr of length. You can run this cable down the inside of the post by drilling an access hole from the inside of the screen cabinet and bring it out at the bottom of the frame and connect it to the waterproof on / off switch. The posts are made of aluminium.
- 4. We highly suggest that you only start your work after we have installed the sign.

### **Ground Search**

signpac.com.au

Please include in your assessment a ground search of the area, including the location of where the sign will be going and pass that search report to your / our customer. Please ask them to send this onto us for our records. If there are any underground services where the sign is to be installed, please alert us and the customer so an alternative location can be found.

Should you need any further information, please ask the client who the Signpac contact person is for the job and call anytime.

**HEAD OFFICE** 

20/45 Leighton Place Hornsby NSW 2077 QLD OFFICE

61 Southgate Avenue Cannon Hill, Brisbane QLD 4170 VIC OFFICE

805/220 Collins Street Melbourne VIC 3000