

DEVELOPMENT APPLICATION ASSESSMENT REPORT

Application Number:	DA2016/0775
----------------------------	-------------

Responsible Officer:	Lashta Haidari
Land to be developed (Address):	Lot 3 DP 807013, 2 Minna Close BELROSE NSW 2085
Proposed Development:	Alterations and Additions to a light industry and warehouse and distribution centre
Zoning:	LEP - Land zoned B7 Business Park LEP - Land zoned E2 Environmental Conservation LEP - Land identified in Schedule 1 Additional Permitted Uses. Refer to attached extract of WLEP2011
Development Permissible:	Yes - Zone B7 Business Park Yes - Zone E2 Environmental Conservation
Existing Use Rights:	No
Consent Authority:	Northern Beaches Council
Land and Environment Court Action:	No
Owner:	Wu Properties Pty Ltd
Applicant:	Nature'S Care

Application lodged:	28/07/2016
Application Type:	Local
State Reporting Category:	Other
Notified:	16/08/2016 to 31/08/2016
Advertised:	Not Advertised, in accordance with A.7 of WDCP
Submissions:	0
Recommendation:	Approval

Estimated Cost of Works:	\$ 2,012,310.00
---------------------------------	-----------------

ASSESSMENT INTRODUCTION

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;
- A site inspection was conducted and consideration has been given to the impacts of the development upon all lands whether nearby, adjoining or at a distance;
- Consideration was given to all documentation provided (upto the time of determination) by the applicant, persons who have made submissions regarding the application and any advice provided by relevant

Council / Government / Authority Officers on the proposal.

SUMMARY OF ASSESSMENT ISSUES

Warringah Development Control Plan - C3 Parking Facilities

SITE DESCRIPTION

Property Description:	Lot 3 DP 807013 , 2 Minna Close BELROSE NSW 2085
Detailed Site Description:	The subject site is located at the eastern end of Minna Close and shares a frontage to Mona Vale Road to the north. The site is located within the Austlink Business Park. The development comprises three (3) buildings, including a two (2) and (3) storey office buildings at the western side of the site and a warehouse to the east. Carpark is located on the basement level and at grade. Access to the site and car park is provided from Minna Close. The existing premises comprise an office development with warehouse/distribution space at the easternmost part of the building, serviced by a number of loading docks.

Map:



SITE HISTORY

BA1453/1990 – (Original approval) Use and construction for two office buildings with an atrium between and warehouse.

DA2009/267 – Internal alterations to office L1.

DA2009/297 – Internal alterations to existing office building.

DA2010/1370 – Fit-out level 1 as an office.

DA2014/1371 - Use of premises as light industry and associated warehouse and distribution centre including minor fit out works to the waste storage area.

Pre - Lodgement Meeting

A Pre-DA meeting in relation to the subject application was held with Council on 2 September 2015 (Ref PLM2015/0095).

PROPOSED DEVELOPMENT IN DETAIL

The site comprises three (3) buildings, comprising two (2) office buildings and one (1) warehouse building within the eastern and western portion of the site, respectively. A previous Consent (DA2014/1371) for a change of use to the existing two (2) office buildings to light industry has been granted by Council on 23 March 2015.

The proposal seeks consent for additions alterations to an existing and approved light industrial and warehouse building including:

- Change of use of part of existing basement to warehouse storage area;
- Infill between existing 'south-wing' building and warehouse above existing basement level;
- New warehouse building over existing tennis court and basketball court; and
- Facade changes to main entrance and internal vehicle circulation.

Other proposed changes in proximity to the entry include:

- The reconfiguration of the drop off area by the provision of a smaller "round-a-bout";
- Landscaping works around the entry and in front of the building;
- The removal of a square concrete structure; and
- The removal of a small landscaped bay located between parking spaces adjacent to the western site boundary close to the entry; the relocation of a light pole; and, the addition of three car spaces in its spaces; and

In consideration of the application a review of (but not limited) documents as provided by the applicant in support of the application was taken into account detail provided within Attachment C.

ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

Section 79C 'Matters for Consideration'	Comments
Section 79C (1) (a)(i) – Provisions of any environmental planning instrument	See the discussion on "Environmental Planning Instruments" in this report.
Section 79C (1) (a)(ii) – Provisions of any draft environmental planning instrument	None applicable.
Section 79C (1) (a)(iii) – Provisions of any development control plan	Warringah Development Control Plan applies to this proposal.
Section 79C (1) (a)(iia) – Provisions of any planning	None applicable.

NORTHERN BEACHES COUNCIL

Section 79C 'Matters for Consideration'	Comments
agreement	
Section 79C (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2000 (EP&A Regulation 2000)	<u>Division 8A</u> of the EP&A Regulation 2000 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent. <u>Clauses 54 and 109</u> of the EP&A Regulation 2000, Council requested additional information and has therefore considered the number of days taken in this assessment in light of this clause within the Regulations. No additional information was requested. <u>Clause 92</u> of the EP&A Regulation 2000 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent. <u>Clauses 93 and/or 94</u> of the EP&A Regulation 2000 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This matter has been addressed via a condition of consent. <u>Clause 98</u> of the EP&A Regulation 2000 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.
Section 79C (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social and economic impacts in the locality	(i) The environmental impacts of the proposed development on the natural and built environment are addressed under the Warringah Development Control Plan section in this report. (ii) The proposed development will not have a detrimental social impact in the locality considering the character of the proposal. (iii) The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.
Section 79C (1) (c) – the suitability of the site for the development	The site is considered suitable for the proposed development.
Section 79C (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs	See the discussion on "Public Exhibition" in this report.
Section 79C (1) (e) – the public interest	No matters have arisen in this assessment that would justify the refusal of the application in the public interest.

EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

NOTIFICATION & SUBMISSIONS RECEIVED

NORTHERN BEACHES COUNCIL

The subject development application has been publicly exhibited in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2000 and Warringah Development Control Plan.

As a result of the public exhibition of the application Council received no submissions.

MEDIATION

No requests for mediation have been made in relation to this application.

REFERRALS

Internal Referral Body	Comments
Building Assessment - Fire and Disability upgrades	No objections subject to conditions.
Development Engineers	The submitted concept drainage plan including on-site stormwater detention (OSD) by Northern Beaches Consulting has been assessed and is considered to be satisfactory subject to conditions. The existing driveway crossing is to remain which is satisfactory. No objection to approval subject to conditions as recommended.
Environmental Investigations (Industrial)	No objection to the proposed development.
Landscape Officer	No objections subject to conditions as recommended.
Natural Environment (Biodiversity)	Council's natural environment, biodiversity section raise no objections to the proposal, subject to conditions.
Traffic Engineer	The proposed changes from industrial to warehouse use would generally result in a lower traffic and parking generation. There are no objection to this proposal on traffic grounds subject to the residual parking requirements for the existing industrial building(s) including any office components is satisfactory.

External Referral Body	Comments
Ausgrid: (SEPP Infra.)	The proposal was referred to Ausgrid. No response has been received within the 21 day statutory period and therefore, it is assumed that no objections are raised and no conditions are recommended.

ENVIRONMENTAL PLANNING INSTRUMENTS (EPIs)*

All, Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs, REPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

SEPP 55 - Remediation of Land

Clause 7 (1) (a) of SEPP 55 requires the Consent Authority to consider whether the land is contaminated. Council records indicate that the subject site has been used for light industrial / commercial purposes for a significant period of time with no prior land uses. In this regard, it is considered that the site poses no risk of contamination and therefore, no further consideration is required under Clause 7 (1) (b) and (c) of SEPP 55 and the land is considered to be suitable for the light industrial / commercial land use.

SEPP (Infrastructure) 2007

Ausgrid

Clause 45 of the SEPP requires the Consent Authority to consider any development application (or an application for modification of consent) for any development carried out:

- within or immediately adjacent to an easement for electricity purposes (whether or not the electricity infrastructure exists).
- immediately adjacent to an electricity substation.
- within 5.0m of an overhead power line.
- includes installation of a swimming pool any part of which is: within 30m of a structure supporting an overhead electricity transmission line and/or within 5.0m of an overhead electricity power line.

Comment: The proposal was referred to Ausgrid. No response has been received within the 21 day statutory period and therefore, it is assumed that no objections are raised and no conditions are recommended.

Warringah Local Environment Plan 2011

Is the development permissible?	Zone B7 : Yes Zone E2 : Yes
After consideration of the merits of the proposal, is the development consistent with:	
aims of the LEP?	Yes
zone objectives of the LEP?	Yes

Principal Development Standards

Standard	Requirement	Proposed	% Variation	Complies
Height of Buildings:	11.0m	11m	N/A	Yes

Compliance Assessment

Clause	Compliance with Requirements
2.5 Additional permitted uses for particular land	Yes

NORTHERN BEACHES COUNCIL

Clause	Compliance with Requirements
4.3 Height of buildings	Yes
4.6 Exceptions to development standards	Yes
5.3 Development near zone boundaries	Yes
5.8 Conversion of fire alarms	Yes
6.2 Earthworks	Yes
6.4 Development on sloping land	Yes

Warringah Development Control Plan

Built Form Controls

33.3%

Built Form Control	Requirement	Proposed	% Variation*	Complies
B4 Site Coverage	33.3%	Existing and Proposed approximately 32%	No change to existing	N/A
B5 Side Boundary Setbacks	5m	5m (Eastern Boundary) 8.92 (Southern Boundary)	N/A	Yes
B7 Front Boundary Setbacks	30m	30m from the new entry	N/A	Yes
D1 Landscaped Open Space (LOS) and Bushland Setting	33.3%	Existing unchanged	N/A	N/A

Compliance Assessment

Clause	Compliance with Requirements	Consistency Aims/Objectives
A.5 Objectives	Yes	Yes
B4 Site Coverage	Yes	Yes
B5 Side Boundary Setbacks	Yes	Yes
Corner of Mona Vale Road and Forest Way, Belrose (known as Austlink Business Park)	Yes	Yes
Side Setback Exceptions - B7	Yes	Yes
B7 Front Boundary Setbacks	Yes	Yes
Land, generally at the corner of Mona Vale Road and Forest Way, Belrose (known as Austlink Business Park) with frontage to Mona Vale Road or Forest Way	Yes	Yes
Land generally at the corner of Mona Vale Road and Forest Way, Belrose (known as Austlink Business Park) with frontage to roads other than Mona Vale Road or Forest Way	Yes	Yes
Front Boundary Exceptions - All Zones	Yes	Yes
B10 Merit assessment of rear boundary setbacks	Yes	Yes
B14 Main Roads Setback	Yes	Yes
C2 Traffic, Access and Safety	Yes	Yes
C3 Parking Facilities	Yes	Yes

NORTHERN BEACHES COUNCIL

Clause	Compliance with Requirements	Consistency Aims/Objectives
C4 Stormwater	Yes	Yes
C5 Erosion and Sedimentation	Yes	Yes
C6 Building over or adjacent to Constructed Council Drainage Easements	Yes	Yes
C7 Excavation and Landfill	Yes	Yes
C8 Demolition and Construction	Yes	Yes
C9 Waste Management	Yes	Yes
Non-Residential Development	Yes	Yes
D1 Landscaped Open Space and Bushland Setting	Yes	Yes
D3 Noise	Yes	Yes
D6 Access to Sunlight	Yes	Yes
D7 Views	Yes	Yes
D8 Privacy	Yes	Yes
D9 Building Bulk	Yes	Yes
D10 Building Colours and Materials	Yes	Yes
D11 Roofs	Yes	Yes
D12 Glare and Reflection	Yes	Yes
D14 Site Facilities	Yes	Yes
D18 Accessibility	Yes	Yes
D20 Safety and Security	Yes	Yes
D21 Provision and Location of Utility Services	Yes	Yes
D22 Conservation of Energy and Water	Yes	Yes
D23 Signs	N/A	N/A
E1 Private Property Tree Management	Yes	Yes
E2 Prescribed Vegetation	Yes	Yes
E3 Threatened species, populations, ecological communities listed under State or Commonwealth legislation, or High Conservation Habitat	Yes	Yes
E4 Wildlife Corridors	Yes	Yes
E5 Native Vegetation	Yes	Yes
E6 Retaining unique environmental features	Yes	Yes
E10 Landslip Risk	Yes	Yes

Detailed Assessment

C3 Parking Facilities

The development provides the following on-site car parking:

Use	Appendix 1 Calculation	Required	Provided	Difference (+/-)

NORTHERN BEACHES COUNCIL

Light Industry	1.3 spaces per 100 m2 GFA	109.5 spaces for 8,425m ² (GFA)	159.5	+49.5 spaces
Warehouse	1.3 spaces per 100 m2 GFA	99.8 spaces 7,679m ² (GFA)	159.5	+59.5 spaces
Total		209.3 (210 rounded up)	319 spaces	+109 spaces

Note: The storage component of the development is ancillary to the warehouse use of the development and therefore it's not calculated separately for the purpose of the car parking calculation.

THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly effect threatened species, populations or ecological communities, or their habitats.

CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

POLICY CONTROLS

Warringah Section 94A Development Contribution Plan

The proposal is subject to the application of Council's Section 94A Development Contributions Plan.

The following monetary contributions are applicable:

Warringah Section 94 Development Contributions Plan		
Contribution based on a total development cost of \$ 2,012,310		
Contributions	Levy Rate	Payable
Total Section 94A Levy	0.95%	\$ 19,117
Section 94A Planning and Administration	0.05%	\$ 1,006
Total	1%	\$ 20,123

CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2000;
- All relevant and draft Environmental Planning Instruments;
- Warringah Local Environment Plan;
- Warringah Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2016/0775 for Alterations and Additions to a light industry and warehouse and distribution centre on land at Lot 3 DP 807013, 2 Minna Close, BELROSE, subject to the conditions printed below:

DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

1. Approved Plans and Supporting Documentation

The development must be carried out in compliance (except as amended by any other condition of consent) with the following:

a) Approved Plans

Architectural Plans - Endorsed with Council's stamp		
Drawing No.	Dated	Prepared By
01,02,03, 04, 20, 21, 22, 23, 24, 30, 31, 40, 41, 42, 43, 44, 45, 46, 50, and 51,	October 2015	Design Workshop Australia

Reports / Documentation – All recommendations and requirements contained within:		
Report No. / Page No. / Section No.	Dated	Prepared By
Bushfire Protection Assessment report and Schedule 1 - Bushfire Protection Measures	April 2016	Travers Bushfire & Ecology
Geotechnical and Land Stability Assessment Report	1 July 2016	Alliance Geotechnical
Arboricultural Impact Appraisal and Method Statement	18 March 2016	Naturally Trees
Building Code of Australia Report	12 July 2016	Design Right Consulting

b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.

c) No construction works (including excavation) shall be undertaken prior to the release of

the Construction Certificate.

d) The development is to be undertaken generally in accordance with the following:

Landscape Plans		
Drawing No.	Dated	Prepared By
LS, 101, 301,302,401,501,502,601, 701	21 March 2016	GreenPlan

Waste Management Plan		
Drawing No.	Dated	Prepared By
Waste Management Plan	2010	Warringah Council

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans. (DACPLB01)

2. **No Approval for any Signage**

No approval is granted under this Development Consent for signs (as defined under Warringah Local Environment Plan 2011 and State Environmental Planning Policy No. 64). A separate Development Application for any signs (other than exempt and signs permitted under Complying Development) must be submitted for the approval prior to the erection or display of any such signs.

Reason: Control of signage. (DACPLB06)

3. **Prescribed Conditions**

(a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

(b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);

(c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:

- (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
- (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
- (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

(d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:

- (i) in the case of work for which a principal contractor is required to be appointed:

- A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
- (ii) in the case of work to be done by an owner-builder:
- A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

(e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:

- (i) protect and support the adjoining premises from possible damage from the excavation, and
- (ii) where necessary, underpin the adjoining premises to prevent any such damage.
- (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
- (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative Requirement (DACPLB09)

4. **General Requirements**

(a) Unless authorised by Council:

Building construction and delivery of material hours are restricted to:

- 7.00 am to 5.00 pm inclusive Monday to Friday,
- 8.00 am to 1.00 pm inclusive on Saturday,
- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

(b) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.

- (c) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (d) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (e) Prior to the release of the Construction Certificate payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (f) Where works are to be carried out to a Class 1a building, smoke alarms are to be installed throughout all new and existing portions of that Class 1a building in accordance with the Building Code of Australia prior to the occupation of the new works.
- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No building, demolition, excavation or material of any nature and no hoist, plant and machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (j) All sound producing plant, equipment, machinery or fittings and the use will not exceed more than 5dB (A) above the background level when measured from any property boundary and/or habitable room(s) consistent with the Environment Protection Authority's NSW Industrial Noise Policy and/or Protection of the Environment Operations Act 1997.
- (k) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.
- (l) Prior to the commencement of any development onsite for:
- i) Building/s that are to be erected
 - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
 - iii) Building/s that are to be demolished
 - iv) For any work/s that is to be carried out
 - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition.

Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

(m) Any Regulated System (e.g. air-handling system, hot water system, a humidifying system, warm-water system, water-cooling system, cooling towers) as defined under the provisions of the Public Health Act 2010 installed onsite is required to be registered with Council prior to operating.

Note: Systems can be registered at www.warringah.nsw.gov.au

(n) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.

(1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2008
- (iv) Australian Standard AS1926 Swimming Pool Safety
- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.

(2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.

(3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewerred areas or managed on-site in unsewerred areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.

(4) Swimming pools and spas must be registered with the Division of Local Government.

(o) New solid fuel burning heaters or existing solid fuel heaters affected by building works must comply with the following:

- (1) AS 2918:2001 Domestic Solid Fuel Burning Appliances – Installation.
- (2) AS 4013:2014 Domestic Solid Fuel Burning Appliances – Method of Determination of Flue Gas Emissions.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community. (DACPLB10)

FEES / CHARGES / CONTRIBUTIONS

5. Policy Controls

Northern Beaches Council Section 94A Development Contribution Plan

The proposal is subject to the application of Council's Section 94A Development Contributions Plan.

The following monetary contributions are applicable:

NORTHERN BEACHES COUNCIL

Northern Beaches Council Section 94 Development Contributions Plan		
Contribution based on a total development cost of \$ 2,012,310.00		
Contributions	Levy Rate	Payable
Total Section 94A Levy	0.95%	\$ 19,116.95
Section 94A Planning and Administration	0.05%	\$ 1,006.16
Total	1%	\$ 20,123.10

The amount will be adjusted at the time of payment according to the quarterly CPI (Sydney - All Groups Index). Please ensure that you provide details of this Consent when paying contributions so that they can be easily recalculated.

This fee must be paid prior to the issue of the Construction Certificate. Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To provide for contributions in accordance with Northern Beaches Council's Development Contributions Plan.

6. Security Bond

A bond (determined from cost of works) of \$10,000 and an inspection fee in accordance with Council's Fees and Charges paid as security to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is located on Council's website at www.warringah.nsw.gov.au/your-council/forms).

Reason: To ensure adequate protection of Council's infrastructure.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

7. Structural Adequacy and Excavation Work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required.

All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: Safety. (DACENC19)

8. **On-site Stormwater Detention**

An On-site Stormwater Detention system must be designed and constructed in accordance with Council's current On-site Stormwater Detention Technical Specification, and generally in accordance with the concept drainage plans prepared by Northern Beaches Consulting Engineers Pty Ltd, drawing number 151104 D01, D02 and D03 Revision B dated 26.07.2016.

Detailed drainage plans are to be prepared by a suitably qualified Civil Engineer, who has membership to the Institution of Engineers Australia, National Professional Engineers Register (NPER) and registered in the General Area of Practice for civil engineering.

The drainage plans must address the following:

1. A minimum site storage required (SSR) of 70 cubic metres.
2. A maximum permissible discharge (PSD) for the 1 in 5 year ARI design storm of 50 litres per second.
3. A maximum PSD for the 1 in 100 year ARI design storm of 123 litres per second.
4. An orifice plate is to be designed for the OSD basin in accordance with the requirements of points 2 and 3. Details of the plate in accordance with Council's OSD Technical Specification are to be provided on the plans.
5. A detailed plan of the proposed OSD system including the basin dimensions and all proposed pipe connections from the new buildings and paved areas to ensure the required total development area enters the basin.
6. Two complete cross sections through the OSD basin including all dimensions and levels.

Detailed drainage plans, including engineering certification confirming the above requirements have been satisfied and complying with Council's current On-site Stormwater Detention Technical Specification, are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater and stormwater management arising from the development. (DACENC20)

9. **Shoring of Adjoining Property**

Should the proposal require shoring to support an adjoining property or Council land, owner's consent for the encroachment onto the affected property owner shall be provided with the engineering drawings. Council approval is required if temporary rock anchors are to be used within Council land.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that owners consent is obtained for ancillary works, and to ensure the protection of adjoining properties and Council land. (DACENCO5)

10. **Tree protection**

- (a) Existing trees which must be retained
 - i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
 - ii) Trees located on adjoining land
- (b) Tree protection
 - i) No tree roots greater than 50mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
 - ii) All structures are to bridge tree roots greater than 50mm diameter unless directed otherwise by a qualified Arborist on site.
 - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
 - iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
 - v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site. (DACLAC01)

11. **External Colours and Materials (Dwellings)**

The external finish to the roof shall have a medium to dark range in order to minimise solar reflections to neighbouring properties. Light colours such as off white, cream, silver or light grey colours are not permitted.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that excessive glare or reflectivity nuisance does not occur as a result of the development. (DACPLC03)

12. **External Colours and Materials (Industrial, Commercial, Mixed & Apartment Buildings)**

(a) External Glazing - The reflectivity index of external glazing for windows, walls or roof finishes of the proposed development is to be no greater than 20% (expressed as a per centum of the reflected light falling upon any surface).

(b) External Roofing - The external finish to the roof shall have a medium to dark range in order to minimise solar reflections to neighbouring properties. Light colours such as off white, cream, silver or light grey colours are not permitted.

(c) Anti Graffiti Coating - The finishes of the walls adjoining <STREET NAME> must be

finished in heavy duty long life, ultra violet resistant coating with a high resistance to solvents and chemicals as an anti-graffiti coating easily cleaned by solvent wipe.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that excessive glare or reflectivity nuisance from glazing does not occur as a result of the development. (DACPLC04)

13. **Sewer / Water Quickcheck**

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre prior to works commencing to determine whether the development will affect any Sydney Water asset's sewer and water mains, stormwater drains and/or easement, and if further requirements need to be met. Plans will be appropriately stamped.

Please refer to the website www.sydneywater.com.au for:

- Quick Check agents details - see Building Developing and Plumbing then Quick Check; and
- Guidelines for Building Over/Adjacent to Sydney Water Assets - see Building Developing and Plumbing then Building and Renovating.
- Or telephone 13 20 92.

Reason: To ensure compliance with the statutory requirements of Sydney Water. (DACPLC12)

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

14. **Bushland Protection Fencing**

Prior to the commencement of any onsite building works, the southern boundary of the property must be surveyed and fenced. The fence shall conform to the specification for bush protection fencing consisting of 1150mm high galvanised hinge joint fencing (8/115/30) (Stocktite or similar) fixed to fence with 3x strands 3.15mm galvanised fencing wire. Posts are to be capped, 50mm round galvanised pipe at 3m centres. End posts are to be stayed with galvanised pipe stay every 15m. Inline stays are to be fixed to 50mm post. Posts are to be concreted into the ground. This fence is to be constructed prior to any construction works.

The installation of the fence is required to prevent encroachment and rubbish dumping in the adjoining native vegetation.

Details demonstrating compliance is to be submitted to the Principal Certifying Authority.

Reason: Bushland Protection. (DACNED02)

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

15. **Maintenance of Road Reserve**

The public footways and roadways adjacent to the site shall be maintained in a safe condition at all times during the course of the work.

Reason: Public Safety. (DACENE09)

16. **Trees Condition**

During the construction period the applicant is responsible for ensuring all protected trees are maintained in a healthy and vigorous condition. This is to be done by ensuring that all identified tree protection measures are adhered to. In this regard all protected plants on this site shall not exhibit:

- (a) A general decline in health and vigour.
- (b) Damaged, crushed or dying roots due to poor pruning techniques.
- (c) More than 10% loss or dieback of roots, branches and foliage.
- (d) Mechanical damage or bruising of bark and timber of roots, trunk and branches.
- (e) Yellowing of foliage or a thinning of the canopy untypical of its species.
- (f) An increase in the amount of deadwood not associated with normal growth.
- (g) An increase in kino or gum exudation.
- (h) Inappropriate increases in epicormic growth that may indicate that the plants are in a stressed condition.
- (i) Branch drop, torn branches and stripped bark not associated with natural climatic conditions.

Any mitigating measures and recommendations required by the Arborist are to be implemented.

The owner of the adjoining allotment of land is not liable for the cost of work carried out for the purpose of this clause.

Reason: Protection of Trees. (DACLAEO3)

17. **Protection of rock and sites of significance**

- a) All rock outcrops outside of the area of approved works are to be preserved and protected at all times during demolition excavation and construction works.
- b) Should any Aboriginal sites be uncovered during the carrying out of works, those works are to cease and Council, the NSW Office of Environment and Heritage (OEH) and the Metropolitan Local Aboriginal Land Council are to be contacted.

Reason: Preservation of significant environmental features (DACLAEOG1)

18. **Weeds**

No noxious or environmental weeds, as listed on Northern Beaches Council's website are to be imported on to the site.

Any noxious weeds or environmental weeds on the site are to be managed continuously, in accordance with the Noxious Weeds Act 1993 for this development.

Details demonstrating compliance is to be submitted to the Principal Certifying Authority.

Reason: To ensure bushland and riparian management. (DACNEEO2)

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE**

19. **BCA and Fire Safety Upgrade**

A fire audit report from an *appropriately qualified Accredited Certifier** is to be submitted with the Construction Certificate for review and implementation into the plans for construction purposes where recommendations are made.

The report is to detail the extent to which the existing building does or does not comply with the deemed-to-satisfy provisions of Sections C, D and E of the Building Code of Australia and which also provides recommendations with respect to the work (if any) required to ensure that the measures contained in the existing building, including any modifications to be made by the proposed development are appropriate to adequately:

- a). protect persons using the building and to facilitate their egress from the building in the

event of fire, and

- b). restrict the spread of fire from the building to other buildings nearby.

Details demonstrating implementation are to be submitted to the Principal Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

*To be regarded as an "*appropriately qualified Accredited Certifier*" the certifier must hold the relevant level of accreditation that would enable the certifier to issue a construction certificate for the subject building.

Reason: Statutory requirement under Clause 93 and 94 of the Environmental Planning and Assessment Regulation 2000; and to ensure adequate provision is made for fire safety in the premises for building occupant safety. (DACBCF01)

20. **Authorisation of Legal Documentation Required for On-site Stormwater Detention**

The original completed request forms (Department of Lands standard forms 13PC and/or 13RPA) must be submitted to Council, with a copy of the Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan), hydraulic engineers certification and Compliance Certificate issued by an Accredited Certifier in Civil Works.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To create encumbrances on the land. (DACENF01)

21. **Registration of Encumbrances for On-site Stormwater Detention**

A copy of the certificate of title demonstrating the creation of the positive covenant and restriction for on-site storm water detention as to user is to be submitted.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To identify encumbrances on land. (DACENF02)

22. **Restriction as to User for On-site Stormwater Detention**

A restriction as to user shall be created on the title over the on-site stormwater detention system, restricting any alteration to the levels and/or any construction on the land. The terms of such restriction are to be prepared to Council's standard requirements, (available from Warringah Council), at the applicant's expense and endorsed by Council prior to lodgement with the Department of Lands. Warringah Council shall be nominated as the party to release, vary or modify such restriction.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure modification to the on-site stormwater detention structure is not carried without Council's approval. (DACENF04)

23. **Stormwater Disposal**

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority

prior to the issue of any interim / final Occupation Certificate.

Note: The following Standards and Codes applied at the time of determination:

- (a) Australian/New Zealand Standard **AS/NZS 3500.3** - 2003 - Plumbing and drainage - Stormwater drainage
- (b) Australian/New Zealand Standard **AS/NZS 3500.3** - 2003/Amdt 1 - 2006 - Plumbing and drainage - Stormwater drainage
- (c) National Plumbing and Drainage Code.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development. (DACENF05)

24. On-Site Stormwater Detention Compliance Certification

Upon completion of the on-site stormwater detention (OSD) system, certification from a consulting engineer and a “work as executed” (WAE) drawing certified by a registered surveyor and overdrawn in red on a copy of the approved OSD system plans are to be provided to Council. Additionally a Compliance Certificate is to be issued by an Accredited Certifier in Civil Works registered with the Institute of Engineers Australia, stating that the works are in accordance with the approved plans.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure stormwater disposal is constructed to Council’s satisfaction. (DACENF10)

25. Positive Covenant for On-site Stormwater Detention

A positive covenant shall be created on the title of the land requiring the proprietor of the land to maintain the on-site stormwater detention structure in accordance with the standard requirements of Council. The terms of the positive covenant are to be prepared to Council’s standard requirements, (available from Warringah Council), at the applicant’s expense and endorsed by Warringah Council’s delegate prior to lodgement with the Department of Lands. Warringah Council shall be nominated as the party to release, vary or modify such covenant.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure ongoing maintenance of the on-site stormwater detention system. (DACENF12)

26. Creation of Positive Covenant and Restriction as a User

Where any conditions of this Consent require the creation of a positive covenant and/or restriction as a user, the original completed request forms, (Department of Lands standard forms 13PC and/or 13RPA), shall be submitted to Warringah Council for authorisation.

A certified copy of the documents shall be provided to Warringah Council after final approval and registration has been affected by the “Department of Lands”.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of a Interim / Final Occupation Certificate.

Reason: To identify encumbrances on land. (DACENF14)

27. Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Interim / Final Occupation Certificate.

Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000. (DACPLF07)

I am aware of Warringah's Code of Conduct and, in signing this report, declare that I do not have a Conflict of Interest.

Signed

Lashta Haidari, Senior Development Planner

The application is determined under the delegated authority of:

Steven Findlay, Development Assessment Manager

NORTHERN BEACHES COUNCIL

ATTACHMENT A

No notification plan recorded.

ATTACHMENT B

	Notification Document	Title	Date
	2016/270311	Notification Map	15/08/2016

ATTACHMENT C

Reference Number	Document	Date
 2016/264386	Report - Annual Fire Safety Certificate	07/10/2015
 2016/264348	Plans - Survey	07/12/2015
 2016/264371	Plan - Bushfire Protection	14/04/2016
 2016/264367	Report - Bushfire Protection Assessment	27/04/2016
 2016/264345	Cost Summary Report	13/05/2016
 2016/264373	Report - Geotechnical and Stability Assessment	01/07/2016
 2016/264376	Report - Arborist	11/07/2016
 2016/264380	Report - Building Code of Australia	13/07/2016
 2016/264369	Report - Waste Management Plan	21/07/2016
 2016/264388	Plans - Swept Path Analysis	22/07/2016
 2016/264359	Report - Statement of Environmental Effects	22/07/2016
 2016/264354	Plan - Notification	27/07/2016
 DA2016/0775	2 Minna Close BELROSE NSW 2085 - Development Application - Alterations and Additions	28/07/2016
 2016/252648	DA Acknowledgement Letter - Nature'S Care	28/07/2016
 2016/264392	Plans - Stormwater	09/08/2016
 2016/264393	Plans - Landscape	09/08/2016
 2016/264396	Plans - Architecturals	09/08/2016
 2016/264146	Development Application Form	09/08/2016
 2016/264170	Pre-lodgement Notes - PLM2015/0095	09/08/2016
 2016/264165	Applicant Details	09/08/2016
 2016/264401	Plans - Master Set	09/08/2016
 2016/268864	Building Assessment - Fire and Disability upgrades - Assessment Referral - DA2016/0775 - 2 Minna Close BELROSE - PH	12/08/2016
 2016/269139	Environmental Investigations (Industrial) - Assessment Referral - DA2016/0775 - 2 Minna Close BELROSE NSW 2085	12/08/2016
 2016/270048	Notification Letter - 168	15/08/2016
 2016/270311	Notification Map	15/08/2016
 2016/272199	Environmental Investigations Referral Response - industrial use	17/08/2016
 2016/275641	Building Assessment Referral Response	20/08/2016
 2016/279921	Natural Environment Referral Response - Biodiversity	24/08/2016
 2016/280674	Development Engineering Referral Response	25/08/2016
 2016/288325	Landscape Referral Response	01/09/2016
 2016/304228	Traffic Engineer Referral Response	09/09/2016