

To:
Northern Beaches
Council

Annual/Supplementary Fire Safety Statement
Issued under Part 9 of the Environmental Planning and Assessment Act Regulation 2000

type of statement ☒ annual ☐ supplementary

annual statement
name owner / agent
address

I...HEATH RYTER.....
of..PO BOX 502 BONDI JUNCTION NSW 1355.....

certify :

- (a) that each of the essential fire safety measures specified in this statement has been assessed by a properly qualified and was found, when it was assessed, to be capable of performing:
- (i) in the case of an essential fire safety measure applicable by virtue of a fire safety schedule, to a standard no less than that specified in the schedule, or
- (ii) in the case of an essential fire safety measure applicable otherwise than by virtue of a fire safety schedule, to a standard no less than that to which the measure was originally designed and implemented, and
- (b) the building has been inspected by a properly qualified person and was found, when inspected, to be in a condition that did not disclose any grounds for a prosecution under Division 7 and
- (c) the information contained in this certificate is, to the best of my knowledge and belief, true and accurate.

identification of
building
location

house / unit no or name.39.....
street.....EAST ESPLANADE.....
suburb.....MANLY.....
description of part (where applicable).WHOLE.....

owner's details
name
address

E & C VIDOR.....
C/- D J WEAR & ASSOCIATES.....
GPO BOX Q843 QVB POST OFFICE 1230.....
phone: 02 9262 2256.....
fax: 02 9262 2714.....

essential/critical fire
safety measures

measures	standard of performance	date of assessment
1. AUTOMATIC FIRE DETECTION & ALARM SYSTEM	AS 1670	27/05/16
2. EMERGENCY LIGHTING	AS 2293.1	10/06/16
3. EXIT SIGNS	AS 2293.1	10/06/16
4. FIRE DOORSETS	AS 1905.1	02/06/16
5. HYDRANTS	AS 2419.1	02/06/16
6. HOSE REELS	AS 2441	02/06/16
7. PORTABLE FIRE EXTINGUISHERS	AS 2444	02/06/16


date of statement

15 JUNE 2016.....

signature

HEATH RYTER.....
print name owner / agent signature

- A copy of this statement must be forwarded to the Council and the Fire Commissioner of the New South Wales Fire Brigades Fire Safety Division, Locked Bag 12, PO GREENACRE NSW 2190.
- A copy of this statement must be prominently displayed in the building.



■ Sales & Installation
■ Maintenance
■ Service
■ Testing
■ Certification
1300 602 106