

ABN 23 039 013 724 Suite 1, Building 8 49 Frenchs Forest Road East Frenchs Forest NSW 2086

PO Box 652 Forestville, NSW, 2087 PH: (02) 9451 3455 FX: (02) 9451 3466 Email:info@dbce.com.au

3rd May 2018

Ref: 16335

Signpac 20/45 Leighton Place Hornsby, NSW, 2077

## Structural Design Certification Signpac Digital Sign

We, Dennis Bunt Consulting Engineers Pty Ltd, certify that we have designed the structural components for the single sided and double sided digital signs, as shown on our structural engineering drawings for job number 16335, S01 to S03 Revision 2.

We certify that the digital signs are structurally adequate for Wind Region A, B & C, Terrain Category 3 in accordance with relevant structural Australian Standards and relevant structural sections of the BCA.

We also certify that the footing has been designed for an allowable bearing pressure of 150 kPa in Wind Region A, B & C, Terrain Category 3.

This certificate shall not be construed as relieving any other party of their responsibilities, liabilities or obligations.

Yours Faithfully,

John Linsell BE(Hons), MIEAust, CPEng, NPER(Struct) for Dennis Bunt Consulting Engineers Pty Ltd.