

Preliminary Enquiry – Feasibility Letter



19/06/24

Webform ref: 1919054

INTEGRATED GROUP SERVICES PTY LTD
Attention: NIMA KHERADHOOSH
Via email: nima.kheradhoosh@igs.com.au

Premises address: **120-122 MONA VALE ROAD, WARRIEWOOD**
Ausgrid AE Reference: **700009230**

Dear NIMA,

I refer to your preliminary enquiry regarding the electricity connection at the above address and provide the following information.

- ☐ IGS on behalf of the developer prepared an electrical maximum demand estimate for the proposed subdivision of two lots into 64 plus a community lot. Based on the maximum demand estimates provided, it is assumed that out of the 64 lots, 60 of the lots will be low-density residential lots. The four remaining lots that require higher maximum demand are allowed for medium-density residential lots. The total maximum demand estimated by IGS is in the order of 1873kVA.
- ☐ Ausgrid has carried out a planning assessment to investigate the feasibility of connecting the proposed 1873kVA to Ausgrid's existing 11kV network. The only feeder available to connect the proposed load is located at Ausgrid pole TH-309. To provide adequate supply to this subdivision, the developer shall install kiosk substation(s) and extend 11kV feeder from Ausgrid pole TH-309, throughout the proposed subdivision.
- ☐ In accordance with Ausgrid ES1 "Premises Connection Requirements" Clause 3.1.3, Ausgrid will provide one point of supply to the development, subject to the limitation of voltage drop and the maximum size of the supply available.
- ☐ Alterations to the existing Ausgrid network (ie network extension) are Contestable and require the customer to engage accredited service providers to undertake the design and construction of the required works.
- ☐ Accordingly, based on the information provided to Ausgrid by IGS, it can be confirmed that the proposed network extension works to supply proposed development is feasible. Further details of Ausgrid's planning assessment can be found in the attachment.

It should be noted that the above advice is based on Ausgrid's policies and network status as of today and are subject to change.

Connections to the Ausgrid network are governed by a set of laws and rules referred to as the National Energy Customer Framework (NECF). Included in the NECF is the National Electricity Rules (NER). Under these rules, a binding contract may only be formed after a connection application is lodged and Ausgrid has made a connection offer in response to that application. Accordingly, to make arrangements for the electricity connection of the development to the Ausgrid network you should lodge a completed connection application.

Should you require any further information please contact me.

Yours sincerely,

Shanming Zhou

Ausgrid

Direct Telephone Number: 0294778357

Email: SZhou@ausgrid.com.au

Enclosures: Preliminary Enquiry – Asset Investment Planning Assessment – PI-2024_0623

Preliminary Enquiry – Asset Investment Planning Assessment

To Shanming Zhou
From Anthony Curran
Date 19th July 2024
Subject PI-2024_0623 - Preliminary Enquiry – 63 Lot subdivision, 120-122 Mona Vale Rd, Warriewood

Background

Asset Investment Planning (AIP) has received a preliminary application for the available capacity and required upstream augmentation (if required) for a proposed connection of 63 lot subdivision at the premises of 120-122 Mona Vale Rd, Warriewood.

Proposed Load

The total anticipated load requirement, as supplied by the customer's Maximum Demand information, is estimated to be approximately 2MVA or 106A at 11kV (2700 ALV). The proposed plan is shown in Figure 1.

11kV Network Existing Supply Considerations

The only feeder available to the proposed subdivision is Mona Vale PA14, a Short Rural feeder of approximately 18km in length, with the nearest supply point being Pole TH-309 (11kV UGOH), as shown in Figure 2.






Figure 1 – Proposed Subdivision





11kV Network Supply Connection

The following outlines, but is not limited to, the scope of works involved as per any network upgrade requirements for an N only connection of the proposed 63 lots:

- The existing network has the available capacity to supply the proposed subdivision.
- It is expected new 400kVA Kiosks with 3 to 4, 400ALV UG distributors to be installed with the appropriate HV and LV conductors to facilitate connection.
- Where necessary – Pole replacements to facilitate UGOH connections for looping in the proposed kiosks from supply point TH-309.
- If the load & number of subdivision lots change from the assumptions made in this preliminary response, then a new assessment will be required.




Fig.4 – Existing System Diag. Mona Vale PA14

Planning Considerations

There are many influencing factors that could affect the available supply capacity including but not limited to other developments, future network augmentation, load growth and policy changes.

This preliminary response is based on information available at the time and may change into the future.

It is expected that a connection application will be submitted by the applicant. Upon receipt of the connection application a more detailed planning study will be undertaken to enable a Design Information Package to be produced outlining the connection requirements.

The information in this response is for use by Contestability to enable a response to the preliminary enquiry by the applicant.

Electrical Maximum Demand Calculation
120-122 Mona Vale Road, Warriewood
 Subdivision of Lots 3, 4 & 5 D.P. 124602



IGS INTEGRATED
GROUP
SERVICES

Job No: EN-N24-021

| Spaces | Area (m2) | VA/m2 | VA | I (A) |
|---------------------------------------|-----------|-------|--------|--------|
| Lot 2 | 2630 | 40 | 105200 | 151.8 |
| Lot 3 | 2823 | 40 | 112920 | 162.9 |
| Lot 4 | 2548 | 40 | 101920 | 147.1 |
| Lot 5 | 2734 | 40 | 109360 | 157.8 |
| Lot 6 | 1540 | 30 | 46200 | 66.7 |
| Lot 7 | 1290 | 30 | 38700 | 55.8 |
| Lot 8 | 1387 | 30 | 41610 | 60.0 |
| Lot 9 | 700 | 20 | 14000 | 20.2 |
| Lot 10 | 701 | 20 | 14020 | 20.2 |
| Lot 11 | 1209 | 30 | 36270 | 52.3 |
| Lot 12 | 1075 | 30 | 32250 | 46.5 |
| Lot 13 | 1194 | 30 | 35820 | 51.7 |
| Lot 14 | 1187 | 30 | 35610 | 51.4 |
| Lot 15 | 1211 | 30 | 36330 | 52.4 |
| Lot 16 | 1187 | 30 | 35610 | 51.4 |
| Lot 17 | 1163 | 30 | 34890 | 50.3 |
| Lot 18 | 1230 | 30 | 36900 | 53.2 |
| Lot 19 | 944 | 30 | 28320 | 40.9 |
| Lot 20 | 1020 | 30 | 30600 | 44.2 |
| Lot 21 | 521 | 20 | 10420 | 15.0 |
| Lot 22 | 521 | 20 | 10420 | 15.0 |
| Lot 23 | 521 | 20 | 10420 | 15.0 |
| Lot 24 | 521 | 20 | 10420 | 15.0 |
| Lot 25 | 521 | 20 | 10420 | 15.0 |
| Lot 26 | 521 | 20 | 10420 | 15.0 |
| Lot 27 | 527 | 20 | 10540 | 15.2 |
| Lot 28 | 518 | 20 | 10360 | 14.9 |
| Lot 29 | 559 | 20 | 11180 | 16.1 |
| Lot 30 | 586 | 20 | 11720 | 16.9 |
| Lot 31 | 522 | 20 | 10440 | 15.1 |
| Lot 32 | 525 | 20 | 10500 | 15.2 |
| Lot 33 | 525 | 20 | 10500 | 15.2 |
| Lot 34 | 525 | 20 | 10500 | 15.2 |
| Lot 35 | 525 | 20 | 10500 | 15.2 |
| Lot 36 | 525 | 20 | 10500 | 15.2 |
| Lot 37 | 501 | 20 | 10020 | 14.5 |
| Lot 38 | 501 | 20 | 10020 | 14.5 |
| Lot 39 | 501 | 20 | 10020 | 14.5 |
| Lot 40 | 929 | 30 | 27870 | 40.2 |
| Lot 41 | 501 | 20 | 10020 | 14.5 |
| Lot 42 | 642 | 20 | 12840 | 18.5 |
| Lot 43 | 722 | 20 | 14440 | 20.8 |
| Lot 44 | 659 | 20 | 13180 | 19.0 |
| Lot 45 | 597 | 20 | 11940 | 17.2 |
| Lot 46 | 506 | 20 | 10120 | 14.6 |
| Lot 47 | 535 | 20 | 10700 | 15.4 |
| Lot 48 | 516 | 20 | 10320 | 14.9 |
| Lot 49 | 954 | 30 | 28620 | 41.3 |
| Lot 50 | 846 | 20 | 16920 | 24.4 |
| Lot 51 | 1655 | 30 | 49650 | 71.6 |
| Lot 52 | 563 | 20 | 11260 | 16.2 |
| Lot 53 | 672 | 20 | 13440 | 19.4 |
| Lot 54 | 1311 | 30 | 39330 | 56.8 |
| Lot 55 | 1196 | 30 | 35880 | 51.8 |
| Lot 56 | 1013 | 30 | 30390 | 43.9 |
| Lot 57 | 1243 | 30 | 37290 | 53.8 |
| Lot 58 | 1389 | 30 | 41670 | 60.1 |
| Lot 59 | 1270 | 30 | 38100 | 55.0 |
| Lot 60 | 554 | 20 | 11080 | 16.0 |
| Lot 61 | 501 | 20 | 10020 | 14.5 |
| Lot 62 | 500 | 20 | 10000 | 14.4 |
| Lot 63 | 531 | 20 | 10620 | 15.3 |
| Lot 64 | 531 | 20 | 10620 | 15.3 |
| Reserve(s), Community and Roads | 16510 | 20 | 330200 | 476.5 |
| Total (without ADMD) | | | | 2846.1 |
| Total (with ADMD after 95% Diversity) | | | | 2703.8 |
| kVA | | | | 1873.3 |