

Environmental Health Referral Response - unsewered land

Application Number: DA2022/0196

Date:	04/03/2022
Responsible Officer	Nick Keeler
• ` ` ,	Lot 242 DP 12749 , 17 Thompson Street SCOTLAND ISLAND NSW 2105

Reasons for referral

This application seeks consent for development upon unsewered land.

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments General Comments

Council has reviewed the wastewater report and is not satisfied that the appropriate / relevant standards will be met when accounting for the limitations on-site. Our view is that the following points require further consideration by the wastewater expert:

- Council considers 3 bedrooms plus a studio to be 4 bedrooms and therefore 6 people. Being, 2 in the master, 2 in the studio, one each in the remaining bedrooms.
- 6 people would equate to a daily load rate (DLR) of 720 L/day.
- A daily irrigation rate (DIR) of 3.5 mm/day has been used by the consultant, but the 40% slope is not accounted-for. As per Table M2 of the Australian Standard 1547, such a slope requires (at least) a 50% reduction in DIR.
- Based on the above points, the Australian Standard and E & H Guideline indicate that a land application area (LAA) of ~411 m² is required for the site. Whereas, 180 m² has been proposed.
- If Council agrees to recognise the total number of people on-site as 5, at a DLR of 120L/person, and using a DIR of 1.75, the smallest LAA we consider to be commensurate to the potential site use is \sim 342 m²

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

Nil.

DA2022/0196 Page 1 of 1