

## DEVELOPMENT APPLICATION ASSESSMENT REPORT

|                            |             |
|----------------------------|-------------|
| <b>Application Number:</b> | DA2022/1024 |
|----------------------------|-------------|

|                                           |                                                                  |
|-------------------------------------------|------------------------------------------------------------------|
| <b>Responsible Officer:</b>               | Nick Keeler                                                      |
| <b>Land to be developed (Address):</b>    | Lot 162 DP 13643, 33 Coolangatta Avenue ELANORA HEIGHTS NSW 2101 |
| <b>Proposed Development:</b>              | Construction of a secondary dwelling                             |
| <b>Zoning:</b>                            | C4 Environmental Living                                          |
| <b>Development Permissible:</b>           | Yes                                                              |
| <b>Existing Use Rights:</b>               | No                                                               |
| <b>Consent Authority:</b>                 | Northern Beaches Council                                         |
| <b>Land and Environment Court Action:</b> | No                                                               |
| <b>Owner:</b>                             | Joel Pearson<br>Moyra Elisa Pearson                              |
| <b>Applicant:</b>                         | Moyra Elisa Pearson                                              |

|                                  |                                    |
|----------------------------------|------------------------------------|
| <b>Application Lodged:</b>       | 25/07/2022                         |
| <b>Integrated Development:</b>   | No                                 |
| <b>Designated Development:</b>   | No                                 |
| <b>State Reporting Category:</b> | Residential - New second occupancy |
| <b>Notified:</b>                 | 03/08/2022 to 17/08/2022           |
| <b>Advertised:</b>               | Not Advertised                     |
| <b>Submissions Received:</b>     | 0                                  |
| <b>Clause 4.6 Variation:</b>     | Nil                                |
| <b>Recommendation:</b>           | Approval                           |

|                                 |               |
|---------------------------------|---------------|
| <b>Estimated Cost of Works:</b> | \$ 152,335.00 |
|---------------------------------|---------------|

### PROPOSED DEVELOPMENT IN DETAIL

The applicant seeks development consent for the construction of a detached secondary dwelling in the rear yard of the subject site.

### ASSESSMENT INTRODUCTION

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;

- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral to relevant internal and external bodies in accordance with the Act, Regulations and relevant Development Control Plan;
- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination);
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

## SUMMARY OF ASSESSMENT ISSUES

Pittwater 21 Development Control Plan - B6.3 Off-Street Vehicle Parking Requirements

## SITE DESCRIPTION

|                                   |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
|-----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Property Description:</b>      | Lot 162 DP 13643 , 33 Coolangatta Avenue ELANORA HEIGHTS NSW 2101                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| <b>Detailed Site Description:</b> | <p>The subject site consists of one (1) allotment located on the western side of Coolangatta Avenue.</p> <p>The site is irregular in shape with a splayed frontage of 17m along Coolangatta Avenue and a maximum depth of 61.915m. The site has a surveyed area of 943.8m<sup>2</sup>.</p> <p>The site is located within the C4 Environmental Living zone and accommodates a two-storey residential dwelling.</p> <p>The site falls approx. 5.5m from the east towards the west.</p> <p>The site contains a predominately landscaped dwelling curtilage with grass, several canopy trees and gardens throughout.</p> <p><b>Detailed Description of Adjoining/Surrounding Development</b></p> <p>Adjoining and surrounding development is characterised by low density residential dwellings, many with ancillary structures and/or outbuildings.</p> |

Map:



## SITE HISTORY

The land has been used for residential purposes for an extended period of time. A search of Council's records has revealed the following relevant history:

Application **N0566/04** for Alterations and additions to existing dwelling and new swimming pool was approved on 13/10/2004 by Council staff.

## ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

| Section 4.15 Matters for Consideration                                                                                    | Comments                                                                                                                                                                                                                                                                                                                                                                                           |
|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument                                             | See discussion on "Environmental Planning Instruments" in this report.                                                                                                                                                                                                                                                                                                                             |
| Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument                                      | There are no current draft environmental planning instruments.                                                                                                                                                                                                                                                                                                                                     |
| Section 4.15 (1) (a)(iii) – Provisions of any development control plan                                                    | Pittwater 21 Development Control Plan applies to this proposal.                                                                                                                                                                                                                                                                                                                                    |
| Section 4.15 (1) (a)(iia) – Provisions of any planning agreement                                                          | None applicable.                                                                                                                                                                                                                                                                                                                                                                                   |
| Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2021 (EP&A Regulation 2021) | <p>Part 4, <u>Division 2</u> of the EP&amp;A Regulation 2021 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent.</p> <p>Clause 29 of the EP&amp;A Regulation 2021 requires the submission of a design verification certificate from the building designer at lodgement of the development</p> |

| Section 4.15 Matters for Consideration                                                                                                                                             | Comments                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                                                                                                                                                                                    | <p>application. This clause is not relevant to this application.</p> <p><u>Clauses 36 and 94</u> of the EP&amp;A Regulation 2021 allow Council to request additional information. No additional information was requested in this case.</p> <p><u>Clause 61</u> of the EP&amp;A Regulation 2021 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent.</p> <p><u>Clauses 62 and/or 64</u> of the EP&amp;A Regulation 2021 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This clause is not relevant to this application.</p> <p><u>Clause 69</u> of the EP&amp;A Regulation 2021 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This matter has been addressed via a condition of consent.</p> <p><u>Clause 69</u> of the EP&amp;A Regulation 2021 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.</p> |
| Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social and economic impacts in the locality | <p>(i) <b>Environmental Impact</b><br/>The environmental impacts of the proposed development on the natural and built environment are addressed under the Pittwater 21 Development Control Plan section in this report.</p> <p>(ii) <b>Social Impact</b><br/>The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.</p> <p>(iii) <b>Economic Impact</b><br/>The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| Section 4.15 (1) (c) – the suitability of the site for the development                                                                                                             | The site is considered suitable for the proposed development.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs                                                                                             | See discussion on “Notification & Submissions Received” in this report.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Section 4.15 (1) (e) – the public interest                                                                                                                                         | No matters have arisen in this assessment that would justify the refusal of the application in the public interest.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |

## EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

## BUSHFIRE PRONE LAND

The site is not classified as bush fire prone land.

## NOTIFICATION & SUBMISSIONS RECEIVED

The subject development application has been publicly exhibited from 03/08/2022 to 17/08/2022 in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2021 and the Community Participation Plan.

As a result of the public exhibition of the application Council received no submissions.

## REFERRALS

| Internal Referral Body      | Comments                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
|-----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| NECC (Coast and Catchments) | <p>The application has been assessed in consideration of the <i>Coastal Management Act 2016</i>, State Environmental Planning Policy (Resilience and Hazards) 2021 and has also been assessed against requirements of the Pittwater LEP 2014 and Pittwater 21 DCP.</p> <p><b>Coastal Management Act 2016</b><br/>The subject site has been identified as being within the coastal zone and therefore <i>Coastal Management Act 2016</i> is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the <i>Coastal Management Act 2016</i>.</p> <p><b>State Environmental Planning Policy (Resilience &amp; Hazards) 2021</b><br/>The subject land has been slightly included on the 'Coastal Environment Area' map under the State Environmental Planning Policy (Resilience &amp; Hazards) 2021. Hence, Clauses 2.10 and 2.12 of the CM (R &amp; H) apply for this DA.</p> <p>Comment:</p> <p>On internal assessment, the DA satisfies requirements under clauses 2.10 and 2.12 of the SEPP R&amp;H.</p> <p>As such, it is considered that the application does comply with the requirements of the State Environmental Planning Policy (Resilience &amp; Hazards) 2021.</p> |

| Internal Referral Body | Comments                                                                                                                                                                                                                                                                         |
|------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                        | <p><b>Pittwater LEP 2014 and Pittwater 21 DCP</b></p> <p>No other coastal related issues identified.</p> <p>As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Pittwater LEP 2014 and Pittwater 21 DCP.</p> |

| External Referral Body | Comments                                                                                                                                                                                                                                                                            |
|------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Ausgrid: (SEPP Infra.) | <p>The proposal was referred to Ausgrid who provided a response stating that the proposal is acceptable subject to compliance with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice. These recommendations will be included as a condition of consent.</p> |

## ENVIRONMENTAL PLANNING INSTRUMENTS (EPIs)\*

All, Environmental Planning Instruments (SEPPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

## State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

### SEPP (Building Sustainability Index: BASIX) 2004

A BASIX certificate has been submitted with the application (see Certificate No. 1294364S, dated 01/06/2022).

The BASIX Certificate indicates that the development will achieve the following:

| Commitment             | Required Target | Proposed |
|------------------------|-----------------|----------|
| <b>Water</b>           | 40              | 40       |
| <b>Thermal Comfort</b> | Pass            | Pass     |
| <b>Energy</b>          | 50              | 50       |

A condition has been included in the recommendation of this report requiring compliance with the commitments indicated in the BASIX Certificate.

## **SEPP (Transport and Infrastructure) 2021**

### Ausgrid

Section 2.48 of Chapter 2 requires the Consent Authority to consider any development application (or an application for modification of consent) for any development carried out:

- within or immediately adjacent to an easement for electricity purposes (whether or not the electricity infrastructure exists).
- immediately adjacent to an electricity substation.
- within 5.0m of an overhead power line.
- includes installation of a swimming pool any part of which is: within 30m of a structure supporting an overhead electricity transmission line and/or within 5.0m of an overhead electricity power line.

### Comment:

The proposal was referred to Ausgrid who raised no objections, subject to conditions which have been included in the recommendation of this report.

## **SEPP (Resilience and Hazards) 2021**

### **Chapter 2 – Coastal Management**

The site is subject to Chapter 2 of the SEPP. Accordingly, an assessment under Chapter 2 has been carried out as follows:

#### **Division 3 Coastal environment area**

##### **2.10 Development on land within the coastal environment area**

- 1) Development consent must not be granted to development on land that is within the coastal environment area unless the consent authority has considered whether the proposed development is likely to cause an adverse impact on the following:
  - a) the integrity and resilience of the biophysical, hydrological (surface and groundwater) and ecological environment,
  - b) coastal environmental values and natural coastal processes,
  - c) the water quality of the marine estate (within the meaning of the Marine Estate Management Act 2014), in particular, the cumulative impacts of the proposed development on any of the sensitive coastal lakes identified in Schedule 1,
  - d) marine vegetation, native vegetation and fauna and their habitats, undeveloped headlands and rock platforms,
  - e) existing public open space and safe access to and along the foreshore, beach, headland or rock platform for members of the public, including persons with a disability,
  - f) Aboriginal cultural heritage, practices and places,
  - g) the use of the surf zone.

Comment:

The proposed development is not expected to cause adverse impact to the coastal environment area.

- 2) Development consent must not be granted to development on land to which this clause applies unless the consent authority is satisfied that:
- a) the development is designed, sited and will be managed to avoid an adverse impact referred to in subsection (1), or
  - b) if that impact cannot be reasonably avoided—the development is designed, sited and will be managed to minimise that impact, or
  - c) if that impact cannot be minimised—the development will be managed to mitigate that impact.

Comment:

Council is satisfied that the proposed development is appropriately designed and sited to ensure adverse impact to the items referred to in subsection (1) is avoided.

**Division 5 General**

**2.12 Development in coastal zone generally—development not to increase risk of coastal hazards**

Development consent must not be granted to development on land within the coastal zone unless the consent authority is satisfied that the proposed development is not likely to cause increased risk of coastal hazards on that land or other land.

Comment:

Council is satisfied the proposed development will not cause an increased risk of coastal hazards on the site or surrounding land.

As such, it is considered that the application complies with the requirements of Chapter 2 of the State Environmental Planning Policy (Resilience and Hazards) 2021.

**Chapter 4 – Remediation of Land**

Sub-section 4.6 (1)(a) of Chapter 4 requires the Consent Authority to consider whether land is contaminated. Council records indicate that the subject site has been used for residential purposes for a significant period of time with no prior land uses. In this regard it is considered that the site poses no risk of contamination and therefore, no further consideration is required under sub-section 4.6 (1)(b) and (c) of this Chapter and the land is considered to be suitable for the residential land use.

**Pittwater Local Environmental Plan 2014**

|                                                                                        |     |
|----------------------------------------------------------------------------------------|-----|
| Is the development permissible?                                                        | Yes |
| After consideration of the merits of the proposal, is the development consistent with: |     |
| aims of the LEP?                                                                       | Yes |
| zone objectives of the LEP?                                                            | Yes |

#### Principal Development Standards

| Standard             | Requirement            | Proposed | % Variation | Complies |
|----------------------|------------------------|----------|-------------|----------|
| Height of Buildings: | Subclause (2FA) - 5.5m | 4.96m    | N/A         | Yes      |

#### Compliance Assessment

| Clause                                                  | Compliance with Requirements |
|---------------------------------------------------------|------------------------------|
| 4.3 Height of buildings                                 | Yes                          |
| 5.4 Controls relating to miscellaneous permissible uses | Yes                          |
| 7.1 Acid sulfate soils                                  | Yes                          |
| 7.2 Earthworks                                          | Yes                          |
| 7.10 Essential services                                 | Yes                          |

#### Pittwater 21 Development Control Plan

##### Built Form Controls

| Built Form Control  | Requirement                | Proposed                   | % Variation* | Complies |
|---------------------|----------------------------|----------------------------|--------------|----------|
| Front building line | 6.5m                       | Behind dwelling            | N/A          | N/A      |
| Rear building line  | 6.5m                       | 7.86m                      | N/A          | Yes      |
| Side building line  | N - 2.5m                   | 9m                         | N/A          | Yes      |
|                     | S - 1m                     | 1m                         | N/A          | Yes      |
| Building envelope   | 3.5m                       | Within envelope            | N/A          | Yes      |
|                     | 3.5m                       | Within envelope            | N/A          | Yes      |
| Landscaped area     | 60% (566.3m <sup>2</sup> ) | 67% (632.4m <sup>2</sup> ) | N/A          | Yes      |

#### Compliance Assessment

| Clause                                                         | Compliance with Requirements | Consistency Aims/Objectives |
|----------------------------------------------------------------|------------------------------|-----------------------------|
| A1.7 Considerations before consent is granted                  | Yes                          | Yes                         |
| A4.5 Elanora Heights Locality                                  | Yes                          | Yes                         |
| B1.3 Heritage Conservation - General                           | Yes                          | Yes                         |
| B1.4 Aboriginal Heritage Significance                          | Yes                          | Yes                         |
| B3.6 Contaminated Land and Potentially Contaminated Land       | Yes                          | Yes                         |
| B4.5 Landscape and Flora and Fauna Enhancement Category 3 Land | Yes                          | Yes                         |
| B6.1 Access driveways and Works on the Public Road Reserve     | Yes                          | Yes                         |
| B6.2 Internal Driveways                                        | Yes                          | Yes                         |
| B6.3 Off-Street Vehicle Parking Requirements                   | No                           | Yes                         |
|                                                                |                              |                             |

| Clause                                                                                  | Compliance with Requirements | Consistency Aims/Objectives |
|-----------------------------------------------------------------------------------------|------------------------------|-----------------------------|
| B8.1 Construction and Demolition - Excavation and Landfill                              | Yes                          | Yes                         |
| B8.3 Construction and Demolition - Waste Minimisation                                   | Yes                          | Yes                         |
| C1.1 Landscaping                                                                        | Yes                          | Yes                         |
| C1.2 Safety and Security                                                                | Yes                          | Yes                         |
| C1.3 View Sharing                                                                       | Yes                          | Yes                         |
| C1.4 Solar Access                                                                       | Yes                          | Yes                         |
| C1.5 Visual Privacy                                                                     | Yes                          | Yes                         |
| C1.6 Acoustic Privacy                                                                   | Yes                          | Yes                         |
| C1.7 Private Open Space                                                                 | Yes                          | Yes                         |
| C1.11 Secondary Dwellings and Rural Worker's Dwellings                                  | Yes                          | Yes                         |
| C1.12 Waste and Recycling Facilities                                                    | Yes                          | Yes                         |
| C1.13 Pollution Control                                                                 | Yes                          | Yes                         |
| C1.23 Eaves                                                                             | Yes                          | Yes                         |
| D5.1 Character as viewed from a public place (Excluding Elanora Heights Village Centre) | Yes                          | Yes                         |
| D5.2 Scenic protection - General                                                        | Yes                          | Yes                         |
| D5.3 Building colours and materials (Excluding Elanora Heights Village Centre)          | Yes                          | Yes                         |
| D5.5 Front building line (Excluding Elanora Heights Village Centre)                     | Yes                          | Yes                         |
| D5.6 Side and rear building line (Excluding Elanora Heights Village Centre)             | Yes                          | Yes                         |
| D5.9 Landscaped Area - Environmentally Sensitive Land                                   | Yes                          | Yes                         |

#### Detailed Assessment

### **B6.3 Off-Street Vehicle Parking Requirements**

#### Description of non-compliance

Where a secondary dwelling is proposed, the control requires the addition of at least one parking space on the site.

The proposed development does not provide additional parking for the secondary dwelling.

#### Merit assessment

The underlying outcomes of the control are addressed as follows.

- *An adequate number of parking and service spaces that meets the demands generated by the development.*

#### Comment:

The proposal provides two off street parking spaces onsite, for the proposed dwelling house.

The site is located within a residential area where on-street parking is available and public transport is within close proximity to the site for the future residents of the secondary dwelling. Overall, adequate off street parking has been provided that will meet the demand generated by the development.

- *Functional parking that minimises rainwater runoff and adverse visual or environmental impacts while maximising pedestrian and vehicle safety.*

Comment:

To facilitate an additional car parking space a substantial increase in impervious area and removal of existing vegetation would also be required. The provision of additional housing, safe vehicular movement and compliant landscaped area is considered of greater importance than compliant off-street parking in this case, given the availability of on-street parking on surrounding streets.

- *Safe and convenient parking.*

Comment:

The subject site is supplied with safe and convenient parking.

Having regard to the above assessment, it is concluded that the proposed development is consistent with the relevant objectives of the P21 DCP and the objectives specified in s1.3 of the Environmental Planning and Assessment Act, 1979. Accordingly, this assessment finds that the proposal is supported, in this particular circumstance.

## **THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES**

The proposal will not significantly affect threatened species, populations or ecological communities, or their habitats.

## **CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN**

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

## **POLICY CONTROLS**

### **Northern Beaches Section 7.12 Contributions Plan 2022**

The proposal is subject to the application of Northern Beaches Section 7.12 Contributions Plan 2022.

A monetary contribution of \$ 762 is required for the provision of new and augmented public infrastructure. The contribution is calculated as 0.5% of the total development cost of \$ 152,335.

## **CONCLUSION**

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;
- Environmental Planning and Assessment Regulation 2021;
- All relevant and draft Environmental Planning Instruments;

- Pittwater Local Environment Plan;
- Pittwater Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPIs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

## RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2022/1024 for Construction of a secondary dwelling on land at Lot 162 DP 13643, 33 Coolangatta Avenue, ELANORA HEIGHTS, subject to the conditions printed below:

### DEVELOPMENT CONSENT OPERATIONAL CONDITIONS

#### 1. Approved Plans and Supporting Documentation

The development must be carried out in compliance with the endorsed stamped plans and documentation listed below, except as amended by any other condition of consent:

##### a) Approved Plans

| Architectural Plans - Endorsed with Council's stamp |            |             |
|-----------------------------------------------------|------------|-------------|
| Drawing No.                                         | Dated      | Prepared By |
| 22-25 Sheet 1 Issue A                               | 28/03/2022 | RK Designs  |
| 22-25 Sheet 2 Issue A                               | 28/03/2022 | RK Designs  |
| 22-25 Sheet 3 Issue A                               | 28/03/2022 | RK Designs  |

| Reports / Documentation – All recommendations and requirements contained within: |            |             |
|----------------------------------------------------------------------------------|------------|-------------|
| Report No. / Page No. / Section No.                                              | Dated      | Prepared By |
| 1294364S                                                                         | 01/06/2022 | RK Designs  |

b) Any plans and / or documentation submitted to satisfy the Conditions of this consent.

c) The development is to be undertaken generally in accordance with the following:

| <b>Waste Management Plan</b> |              |                    |
|------------------------------|--------------|--------------------|
| <b>Drawing No/Title.</b>     | <b>Dated</b> | <b>Prepared By</b> |
| Waste Management Plan        | 27/04/2022   | RK Designs         |

In the event of any inconsistency between conditions of this consent and the drawings/documents referred to above, the conditions of this consent will prevail.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans.

## 2. **Compliance with Other Department, Authority or Service Requirements**

The development must be carried out in compliance with all recommendations and requirements, excluding general advice, within the following:

| <b>Other Department, Authority or Service</b> | <b>EDMS Reference</b>     | <b>Dated</b> |
|-----------------------------------------------|---------------------------|--------------|
| Ausgrid                                       | Ausgrid Referral Response | 09/08/2022   |

(NOTE: For a copy of the above referenced document/s, please see Application Tracking on Council's website [www.northernbeaches.nsw.gov.au](http://www.northernbeaches.nsw.gov.au))

Reason: To ensure the work is carried out in accordance with the determination and the statutory requirements of other departments, authorities or bodies.

## 3. **Approved Land Use**

Nothing in this consent shall authorise the use of onsite structures as detailed on the approved plans for any land use of the site beyond the definition of a *dwelling house* and *secondary dwelling*, as defined by the Pittwater Local Environment Plan 2014 Dictionary.

Any variation to the approved land use beyond the scope of the above definition will require the submission to Council of a new development application.

Reason: To ensure compliance with the terms of this consent.

## 4. **Prescribed Conditions**

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
  - (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and

- (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
- (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
  - (i) in the case of work for which a principal contractor is required to be appointed:
    - A. the name and licence number of the principal contractor, and
    - B. the name of the insurer by which the work is insured under Part 6 of that Act,
  - (ii) in the case of work to be done by an owner-builder:
    - A. the name of the owner-builder, and
    - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
  - (i) protect and support the adjoining premises from possible damage from the excavation, and
  - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
  - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
  - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative requirement.

## 5. General Requirements

- (a) Unless authorised by Council:  
Building construction and delivery of material hours are restricted to:
  - 7.00 am to 5.00 pm inclusive Monday to Friday,
  - 8.00 am to 1.00 pm inclusive on Saturday,

- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) Should any asbestos be uncovered on site, its demolition and removal must be carried out in accordance with WorkCover requirements and the relevant Australian Standards.
- (c) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (d) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (e) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (f) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (g) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (h) No skip bins, building materials, demolition or excavation waste of any nature, and no hoist, plant or machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (i) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (j) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.
- (k) Prior to the commencement of any development onsite for:
  - i) Building/s that are to be erected
  - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
  - iii) Building/s that are to be demolished
  - iv) For any work/s that is to be carried out

- v) For any work/s that is to be demolished  
The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.
- (l) A "Road Opening Permit" must be obtained from Council, and all appropriate charges paid, prior to commencement of any work on Council property. The owner/applicant shall be responsible for all public utilities and services in the area of the work, shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.
- (m) The works must comply with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice.
- (n) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
  - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;  
  
Relevant legislative requirements and relevant Australian Standards (including but not limited) to:
    - (i) Swimming Pools Act 1992
    - (ii) Swimming Pools Amendment Act 2009
    - (iii) Swimming Pools Regulation 2018
    - (iv) Australian Standard AS1926 Swimming Pool Safety
    - (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
    - (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
  - (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
  - (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
  - (4) Swimming pools and spas must be registered with the Division of Local Government.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

## FEES / CHARGES / CONTRIBUTIONS

### 6. Policy Controls

Northern Beaches Section 7.12 Contributions Plan 2022

A monetary contribution of \$761.68 is payable to Northern Beaches Council for the provision of

local infrastructure and services pursuant to section 7.12 of the Environmental Planning & Assessment Act 1979 and the Northern Beaches Section 7.12 Contributions Plan 2022. The monetary contribution is based on a development cost of \$152,335.00.

The monetary contribution is to be paid prior to the issue of the first Construction Certificate or Subdivision Certificate whichever occurs first, or prior to the issue of the Subdivision Certificate where no Construction Certificate is required. If the monetary contribution (total or in part) remains unpaid after the financial quarter that the development consent is issued, the amount unpaid (whether it be the full cash contribution or part thereof) will be adjusted on a quarterly basis in accordance with the applicable Consumer Price Index. If this situation applies, the cash contribution payable for this development will be the total unpaid monetary contribution as adjusted.

The proponent shall provide to the Certifying Authority written evidence (receipt/s) from Council that the total monetary contribution has been paid.

The Northern Beaches Section 7.12 Contributions Plan 2022 may be inspected at 725 Pittwater Rd, Dee Why and at Council's Customer Service Centres or alternatively, on Council's website at [www.northernbeaches.nsw.gov.au](http://www.northernbeaches.nsw.gov.au)

This fee must be paid prior to the issue of the Construction Certificate. Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To provide for contributions in accordance with the Contribution Plan to fund the provision of new or augmented local infrastructure and services.

## **7. Security Bond**

A bond (determined from cost of works) of \$2,000 and an inspection fee in accordance with Council's Fees and Charges paid as security are required to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, and details demonstrating payment are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is located on Council's website at [www.northernbeaches.nsw.gov.au](http://www.northernbeaches.nsw.gov.au)).

Reason: To ensure adequate protection of Council's infrastructure.

## **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

## **8. Stormwater Drainage Disposal**

The stormwater drainage systems for the development are to be designed, installed and maintained in accordance with Council's Water Management for Development Policy.

All stormwater drainage systems must comply with the requirements of Council's Water Management for Development Policy. Any recommendations identified within a Geotechnical Report relevant to the development are to be incorporated into the design of the stormwater drainage system. Details demonstrating compliance from a qualified and practising Civil Engineer and where relevant a Geotechnical Engineer must be submitted to and approved by the Certifying Authority prior to the issue of a Construction Certificate.

When the proposed discharge point for the development in this consent cannot strictly comply with the Water Management for Development Policy, the Applicant must apply to verify the proposed discharge point by gaining Council approval via a Stormwater Drainage Application. Council approval must be provided to the Certifying Authority prior to the issue of a Construction Certificate when a Stormwater Drainage Application is required. The Stormwater Drainage Application form can be found on Council's website.

Compliance with this condition must not result in variations to the approved development or additional tree removal.

Reason: To ensure satisfactory management of stormwater.

9. **Boundary Identification Survey**

A boundary identification survey, prepared by a Registered Surveyor, is to be prepared in respect of the subject site.

The plans submitted for the Construction Certificate are to accurately reflect the property boundaries as shown on the boundary identification survey, with setbacks between the property boundaries and the approved works consistent with those nominated on the Approved Plans of this consent.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of any Construction Certificate.

Reason: To ensure all approved works are constructed within the subject site and in a manner anticipated by the development consent.

10. **Compliance with Standards**

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

11. **Sydney Water "Tap In"**

The approved plans must be submitted to the Sydney Water Tap in service, prior to works commencing, to determine whether the development will affect any Sydney Water assets and/or easements. The appropriately stamped plans must then be submitted to the Certifying Authority demonstrating the works are in compliance with Sydney Water requirements.

Please refer to the website [www.sydneywater.com.au](http://www.sydneywater.com.au) for:

- "Tap in" details - see <http://www.sydneywater.com.au/tapin>
- Guidelines for Building Over/Adjacent to Sydney Water Assets.

Or telephone 13 000 TAP IN (1300 082 746).

Reason: To ensure compliance with the statutory requirements of Sydney Water.

## **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

### **12. Removing, Handling and Disposing of Asbestos**

Any asbestos material arising from the demolition process shall be removed and disposed of in accordance with the following requirements:

- Work Health and Safety Act;
- Work Health and Safety Regulation;
- Code of Practice for the Safe Removal of Asbestos [NOHSC:2002 (1998)];
- Guide to the Control of Asbestos Hazards in Buildings and Structures [NOHSC: 3002 (1998);
- Clause 42 of the Protection of the Environment Operations (Waste) Regulation 2005; and
- The demolition must be undertaken in accordance with Australian Standard AS2601 – The Demolition of Structures.

Reason: For the protection of the environment and human health.

### **13. Survey Certificate**

A survey certificate prepared by a Registered Surveyor is to be provided demonstrating all perimeter walls columns and or other structural elements, floor levels and the finished roof/ridge height are in accordance with the approved plans.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To demonstrate the proposal complies with the approved plans.

### **14. Installation and Maintenance of Sediment Control**

Prior to any works commencing on site, including demolition, sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site.

### **15. Waste Management During Development**

The reuse, recycling or disposal of waste during works must be done generally in accordance with the Waste Management Plan for this development.

Details demonstrating compliance must be submitted to the Principal Certifying Authority.

Reason: To ensure demolition and construction waste is recycled or reused and to limit landfill.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

16. **Stormwater Drainage Disposal Certification**

Certification from an appropriately qualified and practising Civil Engineer demonstrating the stormwater drainage systems have been designed and installed in accordance with the requirements of Council's Water Management for Development Policy and where relevant a Geotechnical Engineer shall be provided to the Certifying Authority prior to the issue of an Occupation Certificate, and;

If any on site stormwater detention system is installed the Applicant shall lodge the Legal Documents Authorisation Application with Council.

The application is to include the completed request forms (NSW Land Registry standard forms 13PC and/or 13RPA) and a copy of the Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan), hydraulic engineers' certification. A guide to the process and associated Legal Document Authorisation Application form can be found on Council's website. The Applicant shall create on the Title a positive covenant in respect to the ongoing maintenance and restriction as to user over the on-site stormwater detention system within this development consent.

The terms of the positive covenant and restriction are to be prepared to Council's standard requirements at the applicant's expense and endorsed by Northern Beaches Council's delegate prior to lodgement with the NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant. A copy of the certificate of title demonstrating the creation of the positive covenant and restriction as to user for the on-site stormwater detention system is to be submitted.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of final Occupation Certificate.

Reason: To ensure satisfactory management of stormwater.

17. **Waste Management Confirmation**

Prior to the issue of a Final Occupation Certificate, evidence / documentation must be submitted to the Principal Certifying Authority that all waste material from the development site arising from demolition and/or construction works has been appropriately recycled, reused or disposed of generally in accordance with the approved Waste Management Plan.

Reason: To ensure demolition and construction waste is recycled or reused and to limit landfill.

In signing this report, I declare that I do not have a Conflict of Interest.

**Signed**



**Nick Keeler, Planner**

The application is determined on 29/08/2022, under the delegated authority of:



**Rodney Piggott, Manager Development Assessments**