



Robert Colombo <Robert@nastasiassociates.com.au>

To Kieran Smith; Sam Nastasi
Cc Pippo Giardina; Michelle Chen

You forwarded this message on 17/03/2022 11:45 AM.

Kieran,

Whether the pool is in the ground or above the ground the pool will be founded on sandstone. Similarly the dwelling will be piered to Sandstone. So both the pool and the dwelling will be piered approximately to 2.0 – 2.5m into the sandstone.

With this in mind, the pool will have no influence on bearing or undermining the dwelling. They both will be supported on Sandstone.

You may use this email as proof to any council/certifier and further, this office will be responsible for the design of both structures in

Accordance to my recommendation above. If they or you have any queries with any of the above, please feel free to call me.

Regards,

Nastasi & Associates Consulting Engineers
Structural - Civil - Stormwater - Geotechnical - Surveying - Site Services

Robert Colombo | Associate Director - Engineering
FlEAust CPEng NER APEC Engineer IntPE (Aust) (Civil/Structural Engineer)
CPEng, NPER,BPB, RPEQ, FAPI

Email: robert@nastasiassociates.com.au
Phone: 02 9607 2864
Mobile: 0416 219 757

NSW - Head Office
Unit 5, 1-3 Whyalla Place
Prestons NSW 2170

QLD - Head Office
1175 Logan Road
Holland Park QLD 4121

Postal
PO Box 6048
Hammondville NSW 2170

Operating in NSW/ QLD/ VIC/ TAS

Connect with Nastasi & Associates