

## Engineering Referral Response

<b>Application Number:</b>	DA2021/2350
<b>Date:</b>	09/03/2022
<b>To:</b>	Stephanie Gelder
<b>Land to be developed (Address):</b>	Lot 3 DP 245112 , 28 Inglebar Avenue ALLAMBIE HEIGHTS NSW 2100

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m<sup>2</sup> or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

#### 23/02/2022:

The application seeks approval for the demolition of the existing dwelling including an attached single garage and construction of a new dwelling with integral double garage and swimming pool at rear of site.

#### Access

Currently site is accessed via a concrete driveway from Inglebar Avenue.  
Proposal is to replace old driveway with new. Applicant to apply for vehicle crossing application.

#### Stormwater

It is a low level site, proposal is that stormwater runoff from the dwelling will be captured and diverted to an above ground basin at rear and finally discharged to a level spreader.

But before Council consider these drawings applicant is advised as below:

a) The Stormwater drainage for the site shall demonstrate compliance with Council's Water Management for Development Policy, particularly Stormwater Drainage from Low Level Properties Technical Specification Section 5.5. As the subject site falls to the rear, an easement to drain water is to be created in favor of the site over the downstream properties. Evidence of owners consent by the property owners (1 Moresby Place ALLAMBIE HEIGHTS)) shall be submitted with the Development Application. The Application shall be supported by a long section of the inter-allotment drainage to the connection with Council's road drainage system.

b) Should this method of stormwater disposal not be possible, evidence shall be submitted with the Application.

For sample letter refer Appendix 2, Easement Letter of Council's Water Management for Development Policy.

**9/3/2022:**

Photographic evidence of posting the request for easement letter to neighbor property (1 Moresby Place ALLAMBIE HEIGHTS) along with Statutory Declaration is provided.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Engineering Conditions:**

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

**On-site Stormwater Detention Details**

The Applicant is to provide a certification of drainage plans detailing the provision of on-site stormwater detention in accordance with Northern Beaches Council's WATER MANAGEMENT for DEVELOPMENT POLICY and generally in accordance with the concept drainage plans prepared by Peninsula Consulting Engineers, Job No : 21-0722, Rev: P1, Drawing No: H01 & H02, Dated: 27-9-2021. Detailed drainage plans are to be prepared by a suitably qualified Civil Engineer, who has membership to the Institution of Engineers Australia, National Professional Engineers Register (NPER) and registered in the General Area of Practice for civil engineering.

The drainage plans must address the following:

- i) OSD to be provided in accordance with Clause 9.0 of Council's Water Management for Development.
- ii) Applicant must install a rainwater tank of at least 3000l capacity (BASIX).
- iii) Above Ground basin's walls to be masonry and watertight.
- iv) Level spreader to be at least 3m away from any site boundary.
- v) Level spreader at rear has to be in line with contours for it to allow to flow.
- vi) Detailed drainage plans, including engineering certification, are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater and stormwater management arising from the development.

**Vehicle Driveway Gradients**

The Applicant is to ensure driveway gradients within the private property are not to exceed a gradient of 1 in 4 (25%) with a transition gradient of 1 in 10 (10%) for 1.5 metres prior to a level parking facility. Access levels across the road reserve are to comply with the allocated vehicle profile detailed in this consent.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure suitable vehicular access to private property.

**Structural Adequacy and Excavation Work**

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

**Vehicle Crossings Application**

The Applicant is to submit an application for driveway levels with Council in accordance with Section 138 of the Roads Act 1993. The fee associated with the assessment and approval of the application is to be in accordance with Council's Fee and Charges.

An approval is to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To facilitate suitable vehicular access to private property.

**CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK****Road Reserve**

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

**Vehicle Crossings**

The Applicant is to construct one vehicle crossing 3 metres wide at kerb with 600mm wings on both sides in accordance with Northern Beaches Council Drawing No A4-3330/ 3NL and the driveway levels application approval. An Authorised Vehicle Crossing Contractor shall construct the vehicle crossing and associated works within the road reserve in plain concrete. All redundant laybacks and crossings are to be restored to footpath/grass. Prior to the pouring of concrete, the vehicle crossing is to be inspected by Council and a satisfactory "Vehicle Crossing Inspection" card issued.

A copy of the vehicle crossing inspection form is to be submitted to the Certifying Authority.

Reason: To facilitate suitable vehicular access to private property.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE  
OCCUPATION CERTIFICATE****Positive Covenant and Restriction as to User for On-site Stormwater Disposal Structures**

The Applicant shall lodge a Legal Documents Authorisation Application (for On-site Stormwater system of main dwelling and for Cabana at rear) with Council. The application is to include the original completed request forms (NSW Land Registry standard forms 13PC and/or 13RPA) and a copy of the

Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan by a Registered Surveyor) and Hydraulic Engineers' final certification and photographic evidence for the completed onsite stormwater detention system works. A guide to the process can be found on Council's website using the following link:

<https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detentionsystems/guide-submitting-ldaa-nov19.pdf>

The form for the application can be found on Council's website using the following link:

<https://files.northernbeaches.nsw.gov.au/sites/default/files/documents/pdfforms/legaldocumentsauthoris:-on-site-stormwater-detention-systems/4023-legal-documentsauthorisationoct19.pdf>

The Applicant shall create on the Title a positive covenant in respect to the ongoing maintenance and restriction as to user over the on-site stormwater detention system within this development consent. The terms of the positive covenant and restriction are to be prepared to Council's standard requirements at the applicant's expense and endorsed by Northern Beaches Council's delegate prior to lodgement with the NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant. A copy of the certificate of title demonstrating the creation of the positive covenant and restriction as to user for the on-site stormwater detention system is to be submitted.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of final Occupation Certificate.

Reason: To ensure the on-site stormwater disposal system is maintained to an appropriate operational standard and not altered.