



Certis (NSW) Pty Ltd Level 16, Suite 25, 327 Pitt Street Sydney NSW

Ph: 02 8570 9100

Fax: 02 8570 9199

ACN: 128 682 557

ABN: 14 128 682 557

Thu, 05 November 2015

Customer Service Department

Pittwater Council

Unit 11

5 Vuko Place

Warriewood

NSW 1660

Warriewood NSW 2102

Dear Sir/Madam,

Jacksons RD Warriewood NSW 2102

COMPLYING DEVELOPMENT CERTIFICATE NO:

3903/0

FINAL CERTIFICATE NO:

3903/0

In accordance with Clause 151(2) of the Environmental Planning and Assessment Regulation 2000 please find enclosed the following documentation for Occupation Certificate for the above premises:

- · Occupation Certificate.
- · Documentation used to determine the application for the Occupation Certificate.
- · A cheque for Council's registration fee.

Should you need to discuss any issues, please do not hesitate to contact the office on 02 8570 9100.

Regards

Peter Hofstetter Team Leader NSW

PRVC \$36-00 Rec: 387484

10/11/15



Certis (NSW) Pty Ltd

Level 16, Suite 25, 327 Pitt Street Sydney NSW

2000

Ph: 02 8570 9100

Fax: 02 8570 9199

ACN: 128 682 557

ABN: 14 128 682 557

FINAL OCCUPATION CERTIFICATE No:

3903/0

Issued under Part 4A Sections 109(1)C & 109(H) of the Environmental Planning and Assessment Act 1979

APPLICANT

Name:

SIMIK Projects

Address:

PO Box 447

Glenmore Park NSW 2745

Contact Details:

Scott Cooper

Phone:

0419667073

Fax:

Email:

scooper@simik.com.au

PROPOSAL

Description of

proposal:

Alterations to existing tenancy SP023 as Australian Geographic

Exclusion:

Address of

Jacksons RD

Development:

Warriewood NSW 2102

Property Title

Class:

6

Description:

Lot:

220

DP:

1159968

STATUTORY CONSENTS

Complying

CDC No:

3903

Development

Dated:

Consent:

24-Sep-2015

PRINCIPLE CERTIFYING AUTHORITY

That I, Tony Griffin, as the certifying authority, certify that:

- (i) the health and safety of the occupants of the building have been taken into consideration where an interim occupation certificate is being issued, and
- (ii) a current development consent or complying development certificate is in force for the building, and
- (iii) if any building work has been carried out, a current construction certificate (or complying development certificate) has been issued with respect to the plans and specifications for the building, and
- (iv) the building is suitable for occupation or use in accordance with its classification under the Building Code of Australia, and
- (v) a fire safety certificate has been issued for the building, and
- (vi) a report from the Fire Commissioner has been considered (if required).

Signature:

Date of certificate:

05-Nov-2015

Accreditation No:

BPB2373

Name:

Tony Griffin

DECISION OF THE PRINCIPLE CERTIFYING AUTHORITY

This certificate

✓ With relevant certificates listed in Attachment A

is issued:

✓ With Fire Safety Schedule listed in Attachment B

ATTACHMENT A - Endorsed Specifications & Documents

Title	Prepared By	Date
Security Closure Installation	Dynamic Closures	30-Oct-2015
Certificate of Compliance- Electrical work	R Yannakis	30-Oct-2015
Flooring test report	AWTA Product Testing	23-Jun-2010
Certificate of Compliance - Glazing	O'Brien Glass with Care	28-Oct-2015
Application for Occupation Certificate	SIMIK Projects	10-Sep-2015
nstallation Certificate-Essential Services	Force Fire & Safety	26-Oct-2015
nstallation Certificate-Mechanical Services	Baratech Pty Ltd	27-Oct-2015
Emergency & Exit Fire Safety certificate	RKM Electrical	31-Oct-2015
Final Fire Safety Certificate	Readyfit Pty Ltd	04-Nov-2015
Installation Certificate-Structural	Abbot Design (Aust) Pty Ltd	02-Nov-2015
Certificate of Completion- Plumbing	RG Smith Plumbing Pty Ltd	03-Nov-2015
Installation Certificate- Detection & Alarm	Force Fire & Safety	05-Nov-2015

Attachment B - Final Fire Safety Schedule

Fire Safety Measure	Standard of Performance
Automatic fire suppression system (Sprinkler)	BCA E1.5, Spec E1.5 & AS2118.1-1999
Emergency lighting	BCA E4.2, E4.4 & AS/NZS2293.1-2005
Exit signs	BCA E4.5, E4.6, E4.8 & AS/NZS2293.1-2005
Mechanical air handling system	BCA E2.2, Spec E2.2b & AS/NZS1668.1-1998
Portable fire extinguishers	BCA E1.6 & AS2444-2004
Sound systems & intercom systems for emergency purposes	BCA E4.9 & AS1670.4-2004



Certis (NSW) Pty Ltd Level 16, Suite 25, 327 Pitt Street Sydney NSW 2000

Ph: 02 8570 9100

Fax: 02 8570 9199

ACN: 128 682 557

ABN: 14 128 682 557

INSPECTION REPORT

In accordance with Clause 162B of the Environmental Planning & Assessment Regulation 2000

PART 1 - Development Details

Development

CDC No: Dated: 3903/0

Approval Details

24-Sep-2015

Principal

Name/Company: Readyfit Pty Ltd

Contractor Details

24 Horizon Drive

Beenleigh QLD 4207

Contact details:

07 3804 7485

Address

Jacksons RD Warriewood NSW 2102

PART 2 - Result of Inspection

Date of Inspection

29-Oct-2015

Inspection Type

Final

Result

Satisfactory

PART 3 - Notes

1. All works are generally in accordance with approved plans.

Signature

Accredited Certifier:

Tony Griffin

Accreditation No:

BPB2373

Installation Certificate - Detection and Alarm

I hereby certify that:

The works have been inspected during construction and have been in completed in accordance with the design, specifications and the nominated Standards of Performance.

Measure and/or system	Standards of Performance
Smoke detection and Alarm	BCA 2013 Part E2, Specification E2.2a
System	AS1668.1-1998, AS 1670.1-2004, AS 3786-1993
Building Occupant Warning System	BCA Spec. E1.5, BCA Spec. E2.2a & AS 1670.1 – 2004 – Clause 3.22
Sound System for	BCA 2013 Clause E4.9
Emergency Purposes	AS 1670.4-2004

I am a properly qualified person and have a good working knowledge of the relevant codes and standards referenced above. (My qualifications and accreditations are listed below)

Relevant qualifications and accreditations:

ASS DIP WEW BNG.

CORRE V FIRE TECH

18 YORL EXPERIENCE.

The information contained in this statement is true and accurate to the best of my knowledge.

Name of Certifier:

PANN PURCHASTI

FORCE FIRE + SAFETM .

WIT 41 , 11-21 UN

Fax No. 1300 66 77 31

Signature

Date

CERTIFICATE OF COMPLIANCE -**ELECTRICAL WORK**

Customer COPY

CERTIFICATE NO: 2309208

cust	OMER DETAILS						
Name A	stralian C	reograph	ric	Т	elephone C	Contact	99132967
Site Address Wa	stralian (square			Me	ter No:	
,	cksons Rd				NMI (Mand	latory)	4103386536
INSTALLATION V	VORK DETAILS Indic	ate the type of ir	nstallation and	types of w	ork perform	ned und	er this Notice
Type of Installation	Residential	Commercia			☐ Rural		☐ Other
Special Conditions	over 100 amps	☐ High Voltag	je 🗆 Haza Area	rdous	☐ Gener	rator	☐ Unmetered Supply
Work of the follow New Installation	terations to a switchb	pe notified to the	ELECTRICIT	Y DISTRIB Netv Defe	BUTOR (DN work conne ect Rectifica rease of the	ection or ation No	metering : ffected by this Notice
EQUIPMENT	RATING	No. F	PARTICULARS			space at	tach separate sheets
☐ Switchboards			EXISTING				
Circuits			x Power,	1 x Exit	Emg. 1	x Control	1 Cet, 4x Lighting
Lighting			× 30w LED	43 *	26w	LED	, ,
Socket-outlets			17 x twin	GPO			
☐ Appliances							•
Estimated increas							llation/service mains
Work is connec	cted to supply		☐ Work is not	connected	d to supply	pending	inspection by DNSP
The work has been or sup TEST REPORT	carried out pervised by:	Yannakis	relevant tests		cence No:		2495 c erformed on the work
IESI REPURI		mulcate the					ch as separate sheets
Earthing system	m integrity ()	TV Res	sidual current o				
Insulation resis						e for con	nection to supply
Polarity	Starioe Will		nd-alone power				
Correct circuit	connections		ılt loop impeda				
I confirm that I ha		bove tests and	visually che	cked that	the install	ation w	ork described in this
Name: R.	Yannakis			Licer	ice No:	824	.95c
Signature:	ged			Date of T	Testing:	30.	10.2015
(Name of DNSP o	ontractor give notic r OFT), that the wor umer Safety) Regula	k described in		te has bee		ted in a	ccordance with the
Name: R	/annakis			Licer	nce No:	182	495c
Signature:					N/		16.2015
	BOX 3391,		2234	or Other (one No. Contact	1414	421000
	TRIBUTOR (DNSP)			h	TT		af CTOW
Inspected by:			ALCOHOL STATE OF THE STATE OF T				of STOIK vww.stoik.m
a ma ma a maa.		1.10	שווה החמי	Cocai	11161 11	OHIV	V VV VV S LOHRAGHE

INSTALLATION CERTIFICATE - MECHANICAL SERVICES

SUBJECT PREMISES:

Shop SP023, 12 Jacksons Road, Warriewood NSW 2102

PROJECT DESCRIPTION:

Internal shop fit out for 'Australian Geographic'

Certification:

Work or Services installed with this development	Standards of Performance
Mechanical Ventilation (General)	BCA Clause NSW F4.5(b) & AS1668.2

I, the undersigned, certify that:

- The mechanical ventilation services / systems that form part of this development have been installed, inspected, tested and commissioned and were found to perform in accordance with the following:
 - Tested prototypes /systems specific for each application and complying with relevant Building Code of Australia requirements and manufacturers' instructions.
 - The relevant Australian Standards listed in the Building Code of Australia, in particular AS 1668 Parts 1 & 2;
 - Required acoustic provisions as required under Part F of the BCA, consent conditions and relevant Council Local Environmental Plan and Development Control Plan requirements.
- All fire dampers, smoke dampers, fire stopping materials, fire/smoke seals and other proprietary items related to the above mechanical ventilation systems (where required) have been installed in accordance with tested prototypes and manufacturers' specifications.
- I am an appropriately qualified and competent person and have a thorough understanding of the relevant codes and standards referenced above. I have recognised relevant experience in the area of work being certified. I am / my employer is holding appropriate current insurance policy to the satisfaction of the building owner or the principal authorising the installation work being certified.
- The information contained within this statement is true and accurate to the best of my knowledge. d)

0

Mechanical Services Page 1 of 1

AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N. 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O. Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

KARNDEAN INTERNATIONAL PTY LTD CLIENT :

835 STUD ROAD

KNOXFIELD VIC 3180

TEST NUMBER : 7-573400-CV

ISSUE DATE : 24/06/2010 : 24/06/2010 PRINT DATE

ORDER NUMBER: 40352

SAMPLE DESCRIPTION Client ref: "Karndean Opus"

Floor tile and planks

Colour: Cream

Approx Total Thickness: 2.5mm

Material Specification:

Nominal composition: PVC / Vinyl Nominal total mass: 4340g/m2

ASISO 9239.1-2003

Reaction to Fire Tests for Floorings Determination of the Burning Behaviour

using a Radiant Heat Source

Date of sample arrival:

31/05/2010 23/06/2010

Date tested: Results:

Part 1

CHF (Critical Heat Flux / Critical Radiant Flux)

Non directional 9.1

3 2

9.1 9.1

Non directional 54

Smoke Value 69

62 % min

kW/m2

Mean

9.1

Observations: blistering

Note: Sample was conditioned in accordance with BSEN 13238-2001 at a temperature of 23+/-2degC and Relative Humidity of 50+/-5% for a minimum of 48 hours prior to testing

No directional properties, three specimens tested only

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Karndean Mega-Bond adhesive an clamped prior to testing

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use

182065

END OF REPORT) PAGE

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



This Laboratory is accredited by the National Association of Testing Authorities, Australia, for Chemical Testing of Textiles & Related Products Accreditation No. 983 Mechanical Testing of Textiles & Related Products Accreditation No.

 Heat & Temperature Measurement Accreditation No. 1356 This document is issued in accordance with NATA's accreditation requirements. Samples, and their

identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.

JACKSON B Sc (Hons)

FINAL FIRE SAFETY CERTIFICATE Issued Clause 170 & 173 under the Environmental Planning and Assessment Regulation 2000 TYPE OF CERTIFICATE Interim (See Note 1) **Final DETAILS** Name Owner/ Agent Address (a) Each of the essential fire measures listed below: (See Note 2 Assessment Requirements) has been assessed by a person (chosen by me) who was properly qualified to do so, and was found, when it was assessed, to have been properly implemented and to be capable of performing to a standard not less than that required by the most recent fire safety schedule (copy attached) for the building for which the certificate is issued. (b) The information contained in this certificate is, to the (See Note 3 relevant fire safety Schedule) best of my knowledge and belief, true and accurate. **IDENTIFICATION OF BUILDING** Warriewood Square Jacksons Road Warriewood NSW 2102 PARTICULARS OF BUILDING Whole of building (Description of Part) Part of building (Shop no.) SP023 DATE OF ASSESSMENT **OWNER'S DETAILS** Name Address al **ESSENTIAL FIRE SAFETY** Automatic fire detection and alarm system **MEASURES** BCA E2.2, Spec E2.2a & AS1670.1-2004 (See Note 3) Automatic fire suppression system (sprinkler) BCA E1.5, Spec E1.5 & AS2118.1-1999 **Emergency lighting** BCA E4.2, E4.4 & AS/NZS2293.1-2005 Exit signs BCA E4.5, E4.6, E4.8 & AS/NZS2293.1-2005 Fire seals (prot4ecting openings in fire resisting components of the building) BCA C3.15 Mechanical air handling systems BCA E2.2, Spec E2.2b & AS/NZS1668.1-1998 Portable fire extinguishers BCA2008 E1.6 & AS2444-2004 Sound Systems & Intercom Systems for Emergency Purpose (EWIS) BCA E4.9 & AS1670.4-2004

DATE OF CERTIFICATE

4/11/15

SIGNATURE

NAC

- A copy of this certificate together with the relevant fire safety schedule must be forwarded to Council and the Commissioner of the New South Wales Fire Brigades.
- A copy of this certificate together with the relevant fire safety schedule must be prominently displayed in the building.

NOTES

For Completing Interim/Final Fire Safety Certificate

Note 1 An interim fire safety certificate or a final fire safety certificate is required before:

- interim occupation certificate can be issued to allow a partially completed new building (including an altered portion of, or an
 extension to, a new building) to be occupied or used, or
- an interim occupation certificate can be issued to allow a change of building use for part of an existing building.

A final fire safety certificate is required:

- before a final occupation certificate can be issued to allow a new building (including an altered portion of, or extension to, a new building) to be occupied or used, or
- before a final occupation certificate can be issued to allow a change of building use for an existing building, or
- in accordance with a fire safety order given by Council.

An interim fire safety certificate is issued for part of the building and may deal only with those essential fire safety measures appearing on the most recent fire safety schedule (see note 3) relevant to the part of the building for which an interim occupation certificate will be sought.

A final fire safety certificate must deal with all essential fire safety measures appearing on the most recent fire safety schedule (see note 3), subject to the following.

An interim fire safety certificate or a final fire safety certificate need not deal with those essential fire safety measures which have been the subject of some other final fire safety certificate or annual fire safety statement within the previous 6 months, unless the person or authority responsible for determining the relevant development consent, complying development certificate, construction certificate or fire safety order, has specified otherwise in the schedule (See also Note 3).

Note 2 The person who carries out the assessment:

- must inspect and verify the performance of each fire safety measure being assessed, and
- in the case of a (interim or final) fire safety certificate for a new building (not an alteration to, or enlargement or extension of an existing building) must test the operation of each item of fire safety equipment installed in the building.
- Note 3 The relevant essential fire safety measures are those specified in the most recent fire safety schedule, attached to one of the following:
 - development consent for a change of building use,
 - complying development certificate for the erection of a building or a change of building use,
 - construction certificate for proposed building work, including building work associated with a change of building use, or
 - a fire safety order.

The fire safety schedule will also identify the required standard of performance for each essential fire safety measure.



RG Smith Plumbing Pty Ltd

ABN 23 000 694 459

LICENCE No A3645

PLUMBING & DRAINAGE CONTRACTORS

UNIT 7/13 PONDEROSA PARADE WARRIEWOOD NSW 2102

Phone: Fax:

9979 3333 9979 7766

Email: rgs@optusnet.com.au Web: www.rgsplumbing.com.au

Tuesday 3rd November, 2015

Readyfit 24 Horizon Drive Beenleigh QLD 4207

National Geographic - Warriewood Square

All plumbing works completed to AS3500.

Regards

Barry Zieren Managing Director





www.dynamicclosures.com.au

30/10/2015

Readyfit Pty Ltd 24 Horizon Drive BEENLEIGH QLD 4207

RE: Australian Geographic - Tenancy 23 - Warriewood Square - Warriewood - NSW

SUBJECT: Security Closure Installation

This is to certify that the Dynamic security closure (Dynaview) was installed by Dynamic Closures (Aust) Pty Ltd on 30th October, 2015. The security closure only was installed to our specifications.

The polycarbonate was supplied by Dynamic Closures and is 1.5mm 'extruded polycarbonate as specified and meets the Australian Standards rules and regulations.

The folding security closure was fixed to an overhead support structure. The structure is not covered by this certificate. The structure was supplied by Readyfit Pty Ltd.

Dynamic Closures (Aust) Pty Ltd offers a full 12 month warranty on its product as set out on the following sheet.

Yours sincerely

DEAN UMSTAD

DYNAMIC CLOSURES (AUST) PTY LTD

All

DYNAMIC CLOSURES (AUST.) PTY. LTD.

ABN 90 007 220 466

VICTORIA **NEW SOUTH WALES** QUEENSLAND WESTERN AUSTRALIA 58 Industrial Park Drive, (P.O. Box 384), Lilydale VIC, 3140 Tel: (03) 9739 5222 Fax: (03) 9739 5599

P.O. Box 6619, Baulkham Hills N.S.W, 2153 P.O. Box 934, Beenleigh QLD, 4207

P.O. Box 3217, Malaga DC W.A, 6945

Tel: (02) 9899 2216 Fax: (02) 9899 2246

Tel: (07) 3805 8055 Fax: (07) 3805 8015

Tel: (08) 9343 8329 Fax: (08) 9343 1725

INSTALLATION CERTIFICATE – ESSENTIAL SERVICES

SUBJECT PREMISES: PROJECT DESCRIPTION: Shop SP023, 12 Jacksons Road, Warriewood NSW 2102

Internal shop fit out for "Australian Geographic"

Certification:

Work or Services installed with this development	Standards of Performance	
Automatic fire suppression (Sprinklers)	AS 2118.1-2005, AS 1851.3-1985	

I, the undersigned, certify that:

- a. The above works / services implemented into this development have been installed, inspected, assessed and tested in accordance with:
 - Tested prototypes /systems specific for each application and complying with relevant Building Code of Australia requirements and manufacturers' instructions.
 - Approved architectural drawings, base building fire engineering requirements, conditions of consent, specifications and relevant Australian Standards.
- b. I am an appropriately qualified and competent person and have a thorough understanding of the relevant codes and standards referenced above. I have recognised relevant experience in the area of work being certified. I am / my employer is holding appropriate current insurance policy to the satisfaction of the building owner or the principal authorising the installation work being certified.
- c. The information contained within this statement is true and accurate to the best of my knowledge.

Name: PAUL RICHETTI
Qualification/s: CERT IV FIRE TECH
Business name: FORCE FIRE & SAFETY
Business address: 49/11-21 UNDERWOOD RD
Business telephone: 1306 66 77 C4
Signature
Dated: 26.10.15

Essential Services Page 1 of 1



Final/Interim Fire Safety Certificate

the building for which the certificate is issued (see **note 3**).

the information contained in this certificate is, to the best of my knowledge and belief, true and accurate.

was found, when it was assessed, to have been properly implemented and to be capable of performing to a standard not less than that required by the most recent **fire safety schedule** (copy attached), for

Identification of Building

Street No. or Building Name Warriewood Shopping Central	Street Name: Jacksons Road
Suburb: Warriewood	Council: Pittwater Council
Nearest Cross Street:	Building Use: Shopping Centre
Does Certificate cover whole or part of building: Part	Describe part:
Facential Fire Cafety Mesource	(if applicable)

Essential Fire Safety Measures (See Note 3)

Measure/Item	Standard of Performance	Assessment Date
Emergency Exit No: 1	AS/NZS - 2293.1	31.10.2015
Emergency Exit No: 2	AS/NZS - 2293.1	31.10.2015
Emergency Spitfire No: 3	AS/NZS - 2293.1	31.10.2015
Emergency Spitfire No: 4	AS/NZS - 2293.1	31.10.2015
•		
•		
•		
•		
•		
•		
•		
•		
•		

Signature Owner/Agent: 77

Date: 31.10.2015



Notes for completing Final/Interim Fire Safety Certificate

Note 1

An **interim fire safety certificate** is issued for part of the building and may deal only with those **essential fire safety measures** appearing on the most recent **fire safety schedule** (see note 3) relevant to the part of the building for which an interim occupation certificate will be sought.

A final fire safety certificate is required:

- before a final occupation certificate can be issued to allow a new building (including an altered portion of, or extension to a new building) to be occupied or used, or
- before a final occupation certificate can be issued to allow a change of building use for an existing building, or
- · in accordance with a fire safety order given by a council.

A final fire safety certificate must deal with all essential fire safety measures appearing on the most recent fire safety schedule (see note 3), subject to the following.

An interim fire safety certificate or a final fire safety certificate need not deal with those essential fire safety measures which have been the subject of some other final fire safety certificate or annual fire safety statement within the previous 6 months, unless the person or authority responsible for determining the relevant development consent, complying development certificate, construction certificate or fire safety order, has specified otherwise in the schedule. See also note 3.

Note 2

The person who carries out the assessment:

- · must inspect and verify the performance of each fire safety measure being assessed, and
- in the case of a (interim or final) fire safety certificate for a new building (not an alteration to, or enlargement or
 extension of an existing building) must test the operation of each item of fire safety equipment installed in the
 building.

Note 3

The relevant **essential fire safety measures** are those specified in the most recent **fire safety schedule**, issued by the consent authority and attached to / included in one of the following:

- development consent for a change of building use,
- · complying development certificate for the erection of a building or a change of building use,
- construction certificate for proposed building work, including building work associated with a change of building use, or
- · a fire safety order.

The fire safety schedule will also identify the required standard of performance for each essential fire safety measure.

In accordance with Clause 172 of the EP&A Regulation 2000, the owner of the building must cause a copy of this Certificate, together with a copy of the current Fire Safety Schedule:

- to be forwarded to the Commissioner of the New South Wales Fire Brigades, Locked Bag 12, Greenacre, NSW, 2190;
- to be prominently displayed within the building.



Letter of Compliance to Australian Standard®: AS1288-2006 as at 28/10/2015

To: READYFIT P/L

Job Certificate #:3154802

ATT: NATHAN/Chris

Installed: O'Brien®, Sydney

Order Ref: 1366

Property: Australian Geographic SP023 Warriewood Square

Jackson Rd Warriewood NSW-2102

Contact- Nathan/Chris

Ph:

0423652757

The 3 panels of 12.38mm A Grade Laminated safety glass supplied and installed at the above certificate reference was manufacturer and properly marked to conform to the requirements of Australian Standard/New Zealand AS/NZS 2208:1996

This one panel of 12mm A Grade toughen safety glass supplied and installed at the above certificate reference was manufacturer and properly marked to conform to the requirements of Australian Standard/New Zealand AS/NZS 2208:1996

These Panels of 12.38mm Safety Laminated safety glass and 12mm toughen safety glass when glazed at the above property address are the correct type and thickness glazing to compley with requirements of Australian Safety Standards AS1288-2006 Glass and building-selection and installation.

Exclusions:

All other glazed panels at above property location not glazed by O'Brien.

Sean Geraghty Field manager

sean geraghty@obrienglass.com.au 0439071623



RECEIVED 23/09/2015 By: Certis NSW Pty Ltd

Certis NSW Pty Ltd

Lvl16, Suite 25, 329 Pitt Street, Sydney NSW 2007

Ph: 02 8570 9100 Fax: 02 8570 9199 ACN: 090 667 548 ABN: 82 090 667 548

APPLICATION FOR

OCCUPATION CERTIFICATE

Part 1	Interim Certificate				
Type of	× Final Certificate				
Application	Building Occupation / Use of a New Building				
Part 2	Change of Building Use of an Existing				
CDC Details	Complying Development 3903 Certificate no.:				
	Determination Date: 24/09/20	15			
Part 3	Internal alterations to existing SI	non SP023			
Description of development Detailed description required		, op 0. 020			
Part 4	Building Name: Warriewood Sqaure				
Identification of Building	Shop no: 023 Tena	ancy Name: Australian Geographic			
Bulluling	Address: Jacksons Road	Warriewood			
	State: NSW Post	Code: 2102			
	Property Title Description (Lot/DP): Lo	t : 220 DP: 1159968			
Part 4a	Existing Classification: 6				
Classification	Proposed Classification: 6				
Part 5	Name: Scott Cooper				
Applicant	Company: SIMIK Projects				
Note: The applicant must be the property owner or a person	Address: PO Box 447	Emu Plains			
authorized by the owner to lodge the application. However a building contractor cannot be the applicant	State: NSW	Post Code: 2750			
unless they are the owner of the property	Phone: 0419667073	Fax:			
	Mobile:	E-mail: scott@simik.com.au			
	Assessment Act 1979, for determinati 2. Certify that the works have been compound. Consent.	Date: 10-Sep-2015 Dolication under the Environmental Planning & con by the Principal Certifying Authority. Deleted in accordance with the relevant Development a relevant, for the subject building work in accordance			

ABBOT DESIGN (AUST) PTY LTD

A.B.N 79 164 816 997

Consulting Civil, Structural, Hydraulic & Design Engineers Project Managers

02 November 2015

Ready Fit 24 Horizon Drive Beenleigh QLD 4207

CERTIFICATION

Re: Shopfront Ceiling, Signage and Bulkhead Inspection
For: Australian Geographic, Shop 023, Warriewood Square Shopping Centre,
Jackson Road, Warriewood, NSW

Dear Sirs,

This is to certify that a Structural Engineering examination of the above premises has been carried out by this company.

The shop is occupied by Australian Geographic. This certificate does not cover any other elements of the shop fit out where carried out by others, including and not limited to any glazing elements, mechanical parts or proprietary manufactured items.

Certification is hereby given to the structural adequacy of the work carried out.

Yours faithfully,

M. J. McDonald

Accredited Structural Certifier Chartered Structural Engineer

N.P.E.R.3. Reg.No.393553

BPB0257 (NSW)