

17 October 2007

Peter Princi Architects
PO BOX 615
FRENCHS FOREST NSW 1640

2006/1218 «DA_NO»MOD2
GF (PAS)

Dear Sir / Madam,

**RE: 33 EDINBURGH ROAD, FORESTVILLE
MODIFICATION 2 OF DEVELOPMENT CONSENT NO. 2006/1218
WINDOW CHANGES TO THE LOWER GROUND FLOOR PLAN**

We are writing to advise that the request to modify the above-mentioned Development Consent has been approved on 2 October 2007 and determined as follows:

- Addition of Condition 1a as follows:

1a. Approved Plans and Supporting Documentation

The development is to be carried out in compliance with the following plans and endorsed with Council's stamp, except where amended by other conditions of consent:

Drawing No.	Drawing Title	Revision No	Revision Date	Prepared By
06.013 DA02	Lower ground floor plan	C	Aug 07	Peter Princi Architects
06.013 DA05	North elevation	C	Aug 07	Peter Princi Architects
06.013 DA06	East elevation	C	Aug 07	Peter Princi Architects

No construction works (including excavation) shall be undertaken prior to the release of the Construction Certificate.

Note: Further information on Construction Certificates can be obtained by contacting Council's Call Centre on 9942 2111, Council's website or at the Planning and Assessment Counter.

Reason: *To ensure the work is carried out in accordance with the determination of Council and approved plans. [A1 (1)]*

This letter should therefore be read in conjunction with Development Consent 2006/1218 dated 30 March 2007 and Modification 1 dated 3 August 2007. Please find attached a consolidated set of conditions incorporating all modifications of consent.

Please note that on site works cannot proceed unless a Construction Certificate application for the modified proposal has been lodged with and approved by Council or

***Consolidated Conditions of Modification No.1 Approved 3 August 2007,
of Development Consent 2006/1218 Approved 30 March 2007***

an accredited certifier, and relevant conditions of the Development Application have been carried out.

Section 96(6) of the Environmental Planning and Assessment Act confers on an applicant who is not satisfied with the determination of the Consent Authority a right of appeal to the Land and Environment Court.

Should you require any further information on this matter, please contact **Keith Wright** between the hours of 9.30am and 10.30am or 3.00pm and 4.00pm, Monday to Friday, on telephone number **9942 2111**, or at any time on facsimile number **9971 4522**.

Details of development applications lodged after July 1, 2005 are also available online, to access this facility please visit our DA's Online System at www.warringah.nsw.gov.au.

Yours sincerely

Keith Wright
**Acting Team Leader, Development Assessment
Planning & Development Services**



GENERAL CONDITIONS

CONDITIONS THAT IDENTIFY APPROVED PLANS

1. Approved Plans And Supporting Documentation

The development is to be carried out in compliance with the following plans and documentation listed below and endorsed with Council's stamp, except where amended by other conditions of consent:

Drawing No.	Drawing Title	Revision No.	Revision Date	Prepared By
DA01	Site plan	B	March 2007	Peter Princi Architects
DA02	Lower ground floor plan	B	Feb 2007	Peter Princi Architects
DA03	Ground floor plan	B	Nov 2006	Peter Princi Architects
DA04	Upper floor plan	B	Nov 2006	Peter Princi Architects
DA05	North elevation	B	Mar 2007	Peter Princi Architects
DA06	East & west elevation	B	Mar 2007	Peter Princi Architects
DA07	South elevation	B	Mar 2007	Peter Princi Architects
DA08	Sections	B	Mar 2007	Peter Princi Architects
DA10	Landscape plan	B	Mar 2007	Peter Princi Architects
DA11	Driveway section	B	Mar 2007	Peter Princi Architects
M01	Site plan & elevation	A	Mar 2007	Peter Princi Architects

No construction works (including excavation) shall be undertaken prior to the release of the Construction Certificate.

Note: Further information on Construction Certificates can be obtained by contacting Council's Call Centre on 9942 2111, Council's website or at the Planning and Assessment Counter.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans. **[A1 (1)]**

1a. Approved Plans and Supporting Documentation

The development is to be carried out in compliance with the following plans and endorsed with Council's stamp, except where amended by other conditions of consent:

Drawing No.	Drawing Title	Revision No	Revision Date	Prepared By
06.013 DA02	Lower ground floor plan	C	Aug 07	Peter Princi Architects
06.013 DA05	North elevation	C	Aug 07	Peter Princi Architects
06.013 DA06	East elevation	C	Aug 07	Peter Princi Architects

**Consolidated Conditions of Modification No.2 Approved 2 October 2007,
Modification No.1 Approved 3 August 2007,
of Development Consent 2006/1218 Approved 30 March 2007**

No construction works (including excavation) shall be undertaken prior to the release of the Construction Certificate.

Note: Further information on Construction Certificates can be obtained by contacting Council's Call Centre on 9942 2111, Council's website or at the Planning and Assessment Counter.

Reason: To ensure the work is carried out in accordance with the determination of Council and approved plans. [A1 (1)]

2. Plans on Site

A copy of all stamped approved plans, specifications and documents (including the Construction Certificate if required for the work incorporating certification of conditions of approval) shall be kept on site at all times so as to be readily available for perusal by any officer of Council or the Principal Certifying Authority.

Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council, Public Information and to ensure ongoing compliance. [A2]

CONDITIONS THAT REQUIRE 'ANCILLARY' MATTERS TO BE COMPLETED TO THE SATISFACTION OF COUNCIL OR ANOTHER NOMINATED PERSON PRIOR TO ISSUE OF CONSTRUCTION CERTIFICATE

3. Vehicle Crossing

Driveway gradients within the private property not exceeding a maximum ratio of 1:4 with transient slopes of 1.5 metres at a grade not steeper than 1:10. Access levels across road reserve to comply with Warringah Council access requirements.

Reason: To facilitate suitable vehicular access to private property. [B6]

CONDITIONS THAT REQUIRE SUBSIDIARY MATTERS TO BE COMPLETED PRIOR TO ISSUE OF A CONSTRUCTION CERTIFICATE

4. Stormwater Disposal

Plans indicating all details relevant to the collection and disposal of stormwater from the site, buildings, paved areas and adjacent areas, shall be submitted with the application for Construction Certificate. The plans must indicate the provision of a rainwater tank in accordance with the Basix certificate. Stormwater shall be conveyed from the site to the kerb in Ferguson Street. The completed works shall be certified as compliant with Australian Standard 3500.3.2, National Plumbing and Drainage Code upon completion. (C8)

Reason: To ensure appropriate provision for disposal and stormwater management and Basix requirements arising from the development. [C8]

5. Pump-Out System Design for Stormwater Disposal

The design of the pump-out system for stormwater disposal will be permitted for drainage of basement areas only, and must be designed in accordance with the following criteria:

- (a) The pump system shall consist of two pumps, connected in parallel, with each pump being capable of emptying the holding tank at the rate equal to the rate of inflow for the one-hour duration storm. The holding tank shall be capable of holding one hour's runoff from a one-hour duration storm of the 1 in 20 year storm.
- (b) The pump system shall be regularly maintained and serviced, every six (6) months.
- (c) Any drainage disposal to the street gutter from a pump system must have a stilling sump provided at the property line, connected to the street gutter by a suitable gravity line.

Engineering details demonstrating compliance with these criteria, and certified by an appropriately qualified and practising Civil Engineer shall be provided to the Council / Accredited Certifier for approval with the Construction Certificate.

Reason: *To ensure adequate provision is made for the discharge of sub-surface stormwater from the excavated parts of the site. [C10]*

6. Kerb Security Bond

A bond of \$1100.00 shall be deposited with Council and inspection fees paid, prior to the issue of any construction certificate, against the potential for damage to Council's footpath and road reserve infrastructure during the construction process. (See Schedule)

Reason: *To ensure appropriate security is in place for the protection or repair of Public Infrastructure. [C16]*

7. Vehicle Crossings

Provision of 1 vehicle crossing/s 4 metres wide in accordance with Warringah Council Drawing No A4-3330/ 1 Normal and specifications. An Application for Street Levels is to be made prior to the issue of the Construction Certificate. Vehicle crossings and associated works within the road reserve shall be constructed in **plain concrete** by an Authorised Vehicle Crossing Contractor, for details see Warringah Council's website <<http://www.warringah.nsw.gov.au>> or phone (02) 9942 2111. All redundant laybacks and crossings are to be restored to footpath/grass.

Prior to the pouring of concrete, the vehicle crossing/s are to be inspected by Council and a satisfactory "Vehicle Crossing Inspection" card issued.

Reason: *To facilitate suitable vehicular access to private property. [C32]*



8. Structural Adequacy of Adjoining Properties

A certificate prepared by an appropriately qualified and practising Structural Engineer, at no cost to the Council, detailing the structural adequacy of adjoining properties numbers 31 Edinburgh Road & 71A Ferguson Street, and certifying their ability to withstand the proposed excavation and any measures required to be incorporated into the work to ensure that no damage will occur to adjoining properties during the course of the works, shall be submitted to the Council / Accredited Certifier with the Construction Certificate application.

Reason: To ensure the protection and structural integrity of adjoining properties. [C48]

9. Asbestos & Hazardous Material

A person taking down, demolishing or causing to be taken down or demolished any building or part thereof shall, upon identifying or suspecting that asbestos is present in the building, immediately notify the Work Cover Authority. The Authority is the controlling body for the safe removal, handling and disposal of asbestos. The Authority supervises and monitors contractors engaged in asbestos removal. The requirements and standards imposed by the Authority, its consultants or contractors shall be complied with.

Reason: To ensure the long term health of workers on site and occupants of the building is not put at risk unnecessarily. [C53 (2)]

10. Security Bond Schedule

All fees and security bonds in accordance with the schedule below must be paid or in place prior to the issue of the required Construction Certificate:

SECURITY BOND & FEE SCHEDULE	
33 Edinburgh Road, Forestville	
DEVELOPMENT APPLICATION NUMBER 2006/1218	
SECURITY BONDS	AMOUNT (\$)
Builders Road/Kerb Security Bond	\$1100.00
TOTAL BONDS	\$1100.00
FEES	
Kerb Security Inspection Fee	\$200.00
Section 94A contribution	\$4380.00
Long Service Levy	\$1533.00
TOTAL FEES	\$6113.00
Progress Inspections if Council is appointed the PCA	\$1650.00

Reason: Compliance with the development consent. [C71]

11. BASIX Certification

Prior to the issue of the Construction Certificate, certification is to be provided by

**Consolidated Conditions of Modification No.2 Approved 2 October 2007,
Modification No.1 Approved 3 August 2007,
of Development Consent 2006/1218 Approved 30 March 2007**

the architect/design consultant to the Council / Accredited Certifier stating that the plans and specifications for the development meet the commitments of the BASIX Certificate lodged with the Development Application.

Reason: To ensure the development complies with the requirements of the SEPP (Building sustainability index: BASIX 2004). [C81]

12. S94A Contribution

The payment of \$4380.00 as a 94A levy prior to the approval/release of the Construction Certificate.

This amount has been calculated using the Warringah Section 94A Development Contributions Plan 2006. It is current at the time of issue of this Consent. The amount will be adjusted at the time of payment according to the quarterly CPI (Sydney - All Groups Index). Please ensure that you provide details of this Consent when paying contributions so that they can be easily recalculated. (see schedule)

The basis for the contributions is as follows:

<i>Warringah Section 94A Development Contributions Plan</i>			
Contribution based on total development cost of	\$	438,000.00	
Contribution - all parts Warringah	Levy Rate	Contribution Payable	Council Code
S94A Levy	0.95%	\$4,161	6923
S94A Planning and Administration	0.05%	\$219	6924
Total	1.0%	\$4,380	

Reason: To retain a level of service for the existing population and to provide the same level of service for the population resulting from new development. [C82]

13. Structural Design Certificate

That structural drawings and certificate from a qualified structural engineer, certifying that the design is in accordance with the relevant Australian Standards and design codes shall be submitted prior to issue of the construction certificate.

Reason: To ensure the safety and structural adequacy of the approved development and compliance with the appropriate Australian Standards. [C83]

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

14. Silt & Sediment Control

Provision shall be made throughout the period of demolition / Excavation &

Construction to prevent transmission of soil to the public road and drainage system by vehicles leaving the site.

Reason: To avoid siltation to adjoining properties and waterways. [D1]

15. Construction Certificate

A Construction Certificate is required to be approved and issued by either Council or an Accredited Certifier, prior to the commencement of any works on the site.

Reason: Legislative requirements. [D3]

16. Notice of Commencement

At least 2 days prior to work commencing on site Council must be informed, by the submission of a Notice of Commencement in Accordance with section 81A of EP & A Act 1979 of the name and details of the Principal Certifying Authority and the date construction work is proposed to commence.

Reason: Legislative requirement for the naming of the PCA. [D4]

17. WorkCover

Your attention is directed to the need to seek advice of your obligations from the WorkCover Authority prior to the commencement of any works on the site.

Reason: Statutory requirement. [D5]

18. Road opening permit

The developer/applicant is to obtain a "Road Opening Permit" from Council and pay all appropriate charges prior to commencement of any work on Council property. The developer/applicant shall be responsible for all public utilities and services in the area of the work, and as such shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.

Reason: Statutory requirement (Roads Act 1993) [D6]

19. Structural adequacy and Excavation work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required.

All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) comply with AS3700, AS3600 and AS1170 and timber walls with AS1720



and AS1170.

Before excavation, the responsible person must notify their intention to the adjoining owner/s and shall at the same time furnish to such owner/s particulars of the work proposed to be carried out.

Reason: *Safety. [D9]*

20. Excavation/Building Works

No excavation or building works shall be carried out until a Construction Certificate has been issued.

Reason: *To ensure compliance with statutory provisions. [D13]*

21. Inspection Fees

Where Council is acting as the Principal Certifying Authority and where an inspection of building, civil or landscape work is required by these conditions, inspection fees and component certification fees must be paid to Council before Council will undertake any inspections. These fees may be paid at the time of submission of the required Notice of Commencement of works. This condition applies regardless of whether a Certification fee is also payable.

Note: The submission of a Notice of Commencement of works form to Council at least two (2) days prior commencing works is a statutory requirement.

Reason: *Statutory requirement and information. [D14]*

22. Public Liability Insurance - Works on Public Land

Any person or contractor undertaking works on public land must take out Public Risk Insurance with a minimum cover of \$10 million in relation to the occupation of, and approved works within Council's road reserve or public land, as approved in this consent. The Policy is to note, and provide protection for Warringah Council, as an interested party and a copy of the Policy must be submitted to Council prior to commencement of the works. The Policy must be valid for the entire period that the works are being undertaken on public land.

(Note: Applications for hoarding permits, vehicular crossings etc will require evidence of insurance upon lodgement of the application.)

Reason: *To ensure the community is protected from the cost of any claim for damages arising from works on public land. [D17]*

CONDITIONS THAT MUST BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

23. Road Reserve works

Lighting, fencing, traffic control and advanced warning signs shall be provided for

the protection of the works and for the safety and convenience of the public and others, to the satisfaction of the Principal Certifying Authority, and in accordance with Council's standard specifications for engineering works. Traffic movement in both directions on public roads, and vehicular access to private properties is to be maintained at all times during the works. This Condition must be complied with during demolition and building work.

Reason: *Public Safety. [E4]*

24. Progress Inspections (Class 1 and 10 Buildings)

The Principal Certifying Authority (PCA) SHALL BE given a minimum of forty-eight (48) hours notice for mandatory inspection of the following, where applicable:

- (a) At the commencement of the work, and after excavation for, and prior to the placement of any footings, and prior to pouring any in-situ reinforced concrete building element, including for the swimming pool, and
- (b) Prior to covering of the framework for any floor, wall roof or other building element, and
- (c) Prior to covering over waterproofing in any wet areas, and
- (d) Upon completion of the swimming pool safety fencing prior to the filling of the pool with water; and
- (e) Prior to covering over stormwater drainage connections, absorption pits and other drainage works, and
- (f) After the building work has been completed and prior to any Occupation Certificate being issued in relation to the building.

The appointed Principal Certifying Authority MUST do the first inspection at the commencement of building work, and at completion of building work.

Notes:

- (1) The appointed Principal Certifying Authority has a discretion to determine additional inspections, or nominate other Accredited Certifiers to undertake inspections other than the first and last inspections, which are required to ensure compliance or otherwise with relevant codes and standards. In any event, the Principal Certifying Authority MUST be advised at all of the stages of construction identified above.
- (2) The PCA must advise the person with the benefit of the consent of the mandatory critical stage inspections referred to in the EP & A Regulations.
- (3) Where Warringah Council is acting as the Principal Certifying Authority for the project, notice is to be given by telephone to Council on 9942 2111 and requesting an relevant inspection. Failure to advise Council at the stages of construction identified above may result in fines being imposed.



- (4) Failure to advise the Principal Certifying Authority of the need for MANDATORY INSPECTIONS at the critical stages of construction detailed above may result in fines being imposed, works being required to be demolished, or delays experienced in obtaining final certification and occupation of the development in order to resolve issues.

Reason: Prescribed mandatory inspections under legislation. [E7]

25. Replacement of Principal Certifying Authority

If the person exercising the benefits of a development consent changes or replaces the Principal Certifying Authority (PCA) during works on the site, the replacement PCA must notify Warringah Council within two (2) days of appointment. If the original PCA was Warringah Council, written approval from Council must be obtained for any change to the PCA role.

(Note: Special legislative provisions in the Environmental Planning and Assessment Act 1979 apply to the procedure for replacing a PCA)

Reason: Statutory requirement. [E11]

26. Replacement of Builder- (Class 1, 2, 3 and 4 buildings)

If the builder is replaced while residential building work is being carried out, the Principal Certifying Authority (PCA) must give Warringah Council written notice of the name, licence number, and insurer of head contractor (or name and permit number of the owner-builder) within two (2) days of their appointment/replacement.

Reason: Statutory requirement. [E12]

27. Progress Survey - Minor Development

In order to ensure compliance with approved plans, a Survey Certificate, to Australian Height Datum, shall be prepared by a Registered Surveyor as follows:

- (a) At the completion of each of the structural floor levels indicating the level of that floor and the relationship of the building to the boundaries;
- (b) At the completed height of the building, prior to the placement of concrete inform work, or the laying of roofing materials;
- (c) At completion, the relationship of the building, and any projections thereto, to the boundaries.

Progress certifications in response to points (a) through (c) shall be provided to the Principal Certifying Authority at the time of carrying out relevant progress inspections. Under no circumstances will work be allowed to proceed should such survey information be unavailable or reveal discrepancies between the approved plans and the proposed works.

Reason: To ensure compliance with approved plans. [E14]

28. Noise and Vibration

Noise emissions and vibration must be minimised where possible and work is to be carried out in accordance with Environment Protection Authority guidelines for noise emissions from construction/demolition works and must also comply with the provisions of the Protection of the Environment Operations Act 1997. This Condition must be complied with during demolition and building work.

Reason: *To ensure residential amenity is maintained in the immediate vicinity.*
[E17]

29. Dust Emission and Air Quality

Materials must not be burnt on the site.

Vehicles entering and leaving the site with soil or fill material must be covered.

Dust suppression measures must be carried out to minimise wind-borne emissions in accordance with the NSW Department of Housing's 1998 guidelines - Managing Urban Stormwater: Soils and Construction. Odour suppression measures must be carried out so as to prevent nuisance occurring at adjoining properties. This Condition must be complied with during demolition and building work.

Reason: *To ensure residential amenity is maintained in the immediate vicinity.*
[E18]

30. Construction Hours

Building construction shall be restricted to within the hours of 7.00 am to 5.00 pm Monday to Friday and on Saturday to within the hours of 8.00 am to 1.00 pm inclusive, with no work on Sundays and Public Holidays.

Demolition and excavation works shall be restricted to within the hours of 8.00 am to 5.00 pm Monday to Friday only. (Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

The builder and excavator shall display, on-site, their twenty-four (24) hour contact telephone number, which is to be clearly visible and legible from any public place adjoining the site.

Reason: *To ensure that works do not interfere with reasonable amenity expectations of residents and the community.* **[E26]**

31. Installation and Maintenance of Sediment Control

Techniques used for erosion and sediment control on building sites are to be adequately maintained at all times and must be installed in accordance with Warringah Council guidelines. All techniques shall remain in proper operation



until all development activities have been completed and the site fully stabilised. This Condition must be complied with during demolition and building work.

Reason: *To protect the environment from the effects of sedimentation and erosion from development sites. [E28]*

32. Health and Safety

The work undertaken must satisfy applicable occupational health and safety and construction safety regulations, including any WorkCover Authority requirements to prepare a health and safety plan. Site fencing must be installed sufficient to exclude the public from the site. Safety signs must be erected that; warn the public to keep out of the site, and provide a contact telephone number for enquiries. This Condition shall be complied with during demolition and building work.

Further information and details regarding occupational health and safety requirements for construction sites can be obtained from the Internet at www.WorkCover.nsw.gov.au.

Reason: *To ensure the health and safety of the community and workers on the site. [E30]*

33. Prohibition on Use of Pavements

Building materials shall not be placed on Council's footpaths, roadways, parks or grass verges and a suitable sign to this effect shall be erected adjacent to the street alignment.

Reason: *To ensure public safety and amenity on public land. [E35]*

34. Plant & Equipment Kept Within Site

All plant and equipment used in the erection of the building, including concrete pumps, wagons, lifts, mobile cranes, etc, shall be situated within the boundaries of the site and so placed that all concrete slurry, water, debris and the like shall be discharged onto the building site, and is to be contained within the site boundaries. This condition shall be complied with during demolition and building work.

Reason: *To ensure public safety and amenity on public land. [E36]*


35. Applicant's Cost of Work on Council Property

The applicant shall bear the cost of all works associated with the development that occurs on Council's property.

Reason: *To ensure the proper management of public land and funds. [E38]*

36. Maintenance of Road Reserve

The public footways and roadways adjacent to the site shall be maintained at all times during the course of the work in a safe condition.



Reason: Public Safety [E39]

37. Demolition Works

All Demolition Work shall be carried out in a safe manner by trained personnel under the management of a licensed demolisher who is registered with the WorkCover Authority, in accordance with the:-

- (a) Approved Demolition Work Method Statement;
- (b) Australian Standard AS2601 Demolition of Structures;
- (c) Relevant Codes of Practice and guidelines of the WorkCover Authority (NSW);
- (d) Relevant provisions of the *Occupational Health and Safety Act 2000 and the Occupational Health and Safety Regulation 2001*; and
- (e) All other relevant Acts and Regulations.

Reason: To ensure a satisfactory standard of demolition works.

(2) All demolition works shall comply with the following requirements:

- (a) Demolished materials shall not be stockpiled and are to be removed from the site within seven (7) days of demolition unless such material is to be re-used in the development on the site in which case all such material to be re-used is to be stored in a clean and tidy manner and not within the dripline of any tree;
- (b) Materials shall not be used for the purposes of fill;
- (c) Burning off of any demolition material on site is not permitted;
- (d) Demolition is not to commence until required fences, hoardings and sedimentation control measures are in place (refer to other conditions of this consent);
- (e) Adequate fire precautions are to be taken at all times to prevent the possibility of fire;
- (f) The site is to be kept free from vermin at all times and control measures implemented prior to demolition commencing should vermin be present on the site;
- (g) Waste containers are to be stored wholly within the property and not on the public footpath, place or road unless otherwise approved in writing by Council;
- (h) The site is to be cleared of all debris and left in a clean and tidy condition at the completion of all works;
- (i) The use of explosives is not permitted;
- (j) All spillage of materials on the public footpaths or roadways are to be removed immediately.

Reason: To ensure residential amenity is maintained in the immediate vicinity, a satisfactory standard of demolition works and that all waste materials are disposed of adequately. [E45]

**OPERATIONAL CONDITIONS IMPOSED UNDER EP&A ACT AND REGULATIONS
AND OTHER RELEVANT LEGISLATION**

38. Building Code of Australia

All building work must be carried out in accordance with the provisions of the Building Code of Australia.

Reason: *Prescribed - Statutory. [F1]*

39. Home Building Act

- (1) Building work that involves residential building work (within the meaning and exemptions provided in the Home Building Act) must not be carried out unless the Principal Certifying Authority for the development to which the work relates:
- (a) in the case of work to be done by a licensee under that Act:
 - (i) has been informed in writing of the licensee's name and contractor licence number, and
 - (ii) is satisfied that the licensee has complied with the requirements of the Home Building Act, or
 - (b) in the case of work to be done by any other person:
 - (i) has been informed in writing of the person's name and owner-builder permit number, or
 - (ii) has been given a declaration, signed by the owner of the land, that states that the reasonable market cost of the labour and materials involved in the work is less than the amount prescribed for the purposes of the definition of owner-builder work in section 29 of that Act, and is given appropriate information and declarations under paragraphs (a) and (b) whenever arrangements for the doing of the work are changed in such a manner as to render out of date any information or declaration previously given under either of those paragraphs.

Note: The amount referred to in paragraph (b)(ii) is prescribed by regulations under the Home Building Act 1989. As at the date on which this Regulation was gazetted, that amount was \$3,000. As those regulations are amended from time to time, that amount may vary.

- (2) A certificate purporting to be issued by an approved insurer under Part 6 of the Home Building Act 1989 that states that a person is the holder of an insurance policy issued for the purposes of that Part is, for the purposes of this clause, sufficient evidence that the person has complied with the requirements of that Part.
- (3) If arrangements for doing residential building work are changed while the work is in progress so that the information submitted to Council is out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the



Council), has given the Council written notice of the updated information.

Reason: Prescribed - Statutory. [F2]

Note: Evidence of insurance required PRIOR to commencement of work.

40. Excavation / Backfilling

- (1) All excavations and backfilling associated with the erection or demolition of a building must be executed safely and in accordance with appropriate professional standards.
- (2) All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.

Reason: To ensure that work is undertaken in a professional and responsible manner and protect adjoining property and persons from potential damage. [F5]

41. Demolition

Demolition work must be undertaken in accordance with the provisions of Australian Standard AS2601- Demolition of Structures.

Reason: To ensure that work is undertaken in a professional and responsible manner and protect adjoining property and persons from potential damage. [F6]

42. Support for Neighbouring Buildings

- (1) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:
 - (a) must preserve and protect the building from damage;
 - (b) if necessary, must underpin and support the adjoining building in an approved manner Subject to adjoining owner's consent; and
 - (c) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
- (2) The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.
- (3) In this clause, allotment of land includes a public road and any other public place.

Reason: To ensure adjoining owner's property rights are protected and protect

adjoining properties from potential damage. [F7]

43. Site Sign

- (1) A sign must be erected in a prominent position on any work site on which work involved in the erection or demolition of a building is being carried out:
 - (a) stating that unauthorised entry to the work site is prohibited;
 - (b) showing the name of the principal contractor (or person in charge of the work site), and a telephone number at which that person may be contacted at any time for business purposes and outside working hours; and
 - (c) showing the name, address and telephone number of the Principal Certifying Authority for the work.
- (2) Any such sign must be maintained while building work or demolition work is being carried out, but must be removed when the work has been completed.
- (3) This condition does not apply to building works being carried out inside an existing building.

Reason: Statutory requirement. [F9]

44. Toilets

- (1) Toilet facilities are to be provided, at or in the vicinity of the work site on which work involved in the erection or demolition of a building is being carried out, at the rate of one toilet for every 20 persons or part of 20 persons employed at the site.
- (2) Each toilet provided:
 - (a) must be a standard flushing toilet, and
 - (b) must be connected:
 - (i) to a public sewer; or
 - (ii) if connection to a public sewer is not practicable, to an accredited sewage management facility approved by the Council, or
 - (iii) if connection to a public sewer or an accredited sewage management facility is not practicable, to some other sewage management facility approved by the Council.
- (3) The provision of toilet facilities in accordance with this clause must be completed before any other work is commenced.
- (4) In this clause:

accredited sewage management facility means a sewage management facility to which Division 4 Sub-division 5 of the Local Government (General) Regulation 2005 applies, being a sewage management facility that is installed or constructed to a design or plan the subject of a certificate of accreditation referred to in of the Regulation.

approved by the Council means the subject of an approval in force under the Local Government (General) Regulation 2005.

public sewer has the same meaning as it has in the Local Government (General) Regulation 2005.

sewage management facility has the same meaning as it has in the Local Government (General) Regulation 2005.

Reason: *To ensure adequate facilities are provided for workers on the site. [F10]*

45. Long Service Levy

Payment of the Long Service Levy is required prior to the release of the Construction Certificate. This payment can be made at Council or to the Long Services Payments Corporation.

Advisory note: The rate of the Long Service Levy at the time of consent is 0.35% of the building construction works. At the time of consent, payment is not required where the value of the works is less than \$25,000. For works that are \$25,000 or over, a fee is required at the prescribed rate. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply and is based on the building construction works identified in the Construction Certificate.

Reason: *Prescribed - Statutory. [F12]*

46. Sydney Water

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre prior to issue of the Construction Certificate to determine whether the development will affect any Sydney Water asset's sewer and water mains, stormwater drains and/or easement, and if further requirements need to be met. Plans will be appropriately stamped.

Please refer to the website www.sydneywater.com.au <<http://www.sydneywater.com.au>> for:

- Quick Check agents details - see Building Developing and Plumbing then Quick Check; and
- Guidelines for Building Over/Adjacent to Sydney Water Assets - see Building Developing and Plumbing then Building and Renovating.

Or telephone 13 20 92.

Reason: *To ensure compliance with the statutory requirements of Sydney Water. [F15]*



**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO ISSUE OF
OCCUPATION CERTIFICATE**

47. Occupation Certificate Required

An Interim / Final Occupation Certificate shall be obtained in relation to the approved works prior to any use or occupation of those parts of the building.

Reason: *To ensure compliance with the provisions of the Environmental Planning and Assessment Act. [G1]*

48. Termite Control

- (1) Termite control measures being installed in accordance with AS 3660.1-2000 "Termite Management: New Building Work."

Reason: *Termite control. [G6 (1)]*

- (2) A durable notice is to be permanently fixed to the building in a prominent location, such as the meter box or the like, indicating: The method of termite protection; date of installation; life expectancy of chemical barrier (if used); and installer's or manufacturer's recommendations for the scope and frequency of future inspections for termite activity.

Reason: *Termite control. [G6 (2)]*

49. Reinstatement of Kerb

All redundant lay-backs and vehicular crossings shall be reinstated to conventional kerb and gutter, foot-paving or grassed verge as appropriate. All costs shall be borne by the applicant, and works shall be completed prior to the issue of an Occupation Certificate.

Reason: *To facilitate vehicular access to private sites, without disruption to pedestrian and vehicular traffic, and the preservation of on street parking spaces. [G9]*

50. Swimming Pool Water to Sewer

The swimming pool including overflow water shall be drained to the sewer. The consent of Sydney Water to dispose of wastewater shall be obtained and compliance with any conditions imposed in connection therewith.

Reason: *Water from a swimming pool is classified as wastewater and cannot be legally disposed of into the stormwater system. [G17]*

51. Pool Access

Access to the pool shall be restricted by a child resistant barrier in accordance with the regulations prescribed in the Swimming Pools Act, 1992 and Swimming Pools Regulation 1998;

- (a) The pool shall not be filled with water or be allowed to collect stormwater until the installation of the child resistant barrier is completed; and
- (b) The barrier is to conform to the requirements of AS 1926 Fences and Gates for Private Swimming Pools.

Reason: To ensure that any person acting upon this consent is aware of their obligations under the provisions of the Swimming Pools Act, to prevent young children from accidental death by drowning. [G18]

52. Pool Safety Requirements

The owner of the pool shall display a notice showing:

- (a) Appropriate instructions of artificial resuscitation methods.
- (b) A warning stating 'YOUNG CHILDREN SHOULD BE SUPERVISED WHEN USING THIS POOL'.

Note: This notice shall be kept in a legible condition and at the poolside.

Reason: To ensure an adequate level of safety for young pool users. [G19]

53. Swimming Pools

The filtration motor, pump and moving parts shall be enclosed in a sound-proofed structure of masonry or similar materials, with the noise level of any filtration equipment or pumps to not exceed 5dBA above the ambient background noise level measured at the nearest property boundary.

Reason: Noise control [G20]

54. Pool Fencing (Gates)

In accordance with Australian Standards any gates in the fence shall open outwards away from the pool area and be self closing and fitted with a latch which shall be automatic and of a type which cannot be easily manipulated by small children. Latches must be on the inside of the gate and as near as possible to the top.

Reason: To ensure compliance with the relevant standards. [G21]

55. BASIX Compliance Certification

Prior to the issue of the Occupation Certificate, a compliance certificate is to be prepared by an Accredited Certifier and submitted to the Principal Certifying Authority stating that all the selected BASIX commitments as detailed in the BASIX Certificate, lodged with the Development Application, and the approved plans/specifications have been completed.

Reason: To ensure the development complies with the requirements of the SEPP (Building sustainability index: BASIX 2004). [G31]



56. Bushfire protection

Construction shall comply with AS3959 - 1999 level 3 'Construction of Buildings in bushfire prone areas'.

Reason: *Protection from bushfire and safety. [G33]*

57. Bushfire protection

Roofing shall have leafless guttering to prevent the build up of flammable material.

Reason: *Protection from bushfire and safety. [G35]*

58. Bushfire protection

All new fencing shall be constructed of non-combustible materials.

Reason: *Protection from bushfire and safety. [G36]*

59. Bushfire Protection

The entire property shall be managed as an 'Inner Protection Area' as outlined within section 4.2.2 in Planning for Bushfire Protection 2001.

Reason: *Protection from bushfire and safety. [G38]*

60. Site Stabilisation

Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully re-turfed and the site must be maintained in a safe and clean state until such time as new construction works commence.

Reason: *To retain topsoil and minimise dust pollution. [G37]*

61. Smoke Alarms

Smoke alarms are to be installed throughout the new and existing portions of the Class 1a building in accordance with the Building Code of Australia prior to the occupation of the new works.

Reason: *Compliance with BCA and safety of occupancies. [G40]*

62. Bushfire Protection

There is to be no exposed timber on the proposed structure.

Reason: *Protection from bushfire and safety. [Special Condition]*



63. Bushfire Protection

Roller doors, tilt-a-doors and the like shall be sealed to prevent the entry of embers into the structure.

Reason: Protection from bushfire and safety. **[Special Condition]**

64. Bushfire Protection

Access to the rear of the property shall be provided for fire fighting purposes.

Reason: Protection from bushfire and safety. **[Special Condition]**

65. Bushfire Protection

All glazing towards the bushfire hazard shall be fire rated glass or glazing constructed to withstand 40kw/m² radiant heat exposure for 3 minutes or toughened glass with non combustible shutters to be installed on all windows directly exposed to the bushfire hazard.

Reason: Protection from bushfire and safety. **[Special Condition]**

CONSOLIDATED CONDITIONS

