NORTHERN BEACHES COUNCIL

ALTERATIONS AND ADDITIONS 3 OCEAN GROVE, COLLAROY NSW 2097

STORMWATER DRAINAGE PLAN

STORMWATER DRAINAGE NOTES

- 1. ALL LINES ARE TO BE MIN. 100¢ UPVC @ MIN 1.0% GRADE UNLESS NOTED OTHERWISE.
- 2. IT IS THE CONTRACTORS RESPONSIBILITY TO LOCATE & LEVEL ALL EXISTING SERVICES PRIOR TO THE COMMENCEMENT OF ANY EARTHWORKS. ALL DESIGN LEVELS SHOWN ON PLAN SHALL BE VERIFIED ON SITE PRIOR TO THE COMMENCEMENT OF ANY WORK.
- 3. EXISTING STORMWATER DRAINAGE SYSTEM TO BE CCTV CAMERA TESTED BY LICENSED PLUMBER PRIOR TO CONSTRUCTION.
- 4. ALL PIPES MINIMUM GRADIENT AND COVER TO BE IN ACCORDANCE WITH AS/NZ 3500.3:2018.
- 5. ENSURE ALL PIT GRATES ARE SET BELOW FINISHED SURFACE LEVEL WITHIN THE PROPERTY.
- 6. TOP OF PIT RL'S ARE APPROXIMATE ONLY AND MAY BE VARIED SUBJECT TO APPROVAL OF THE ENGINEER. ALL INVERT LEVELS ARE TO BE ACHIEVED.
- 7. ALL PITS IN DRIVEWAYS BE HEAVY DUTY GRATES. DIRECT SURFACE FLOW TO ALL GRATED SURFACE INLET PITS.
- 8. ALL WORK DO BE DONE IN ACCORDANCE WITH AS/NZ 3500.3:2018 AND COUNCIL SPECIFICATIONS.
- 9. LOCATION OF DOWNPIPES & FLOOR WASTES ARE INDICATIVE ONLY.
 DOWNPIPE & FLOOR WASTE SIZE, LOCATION & QUANTITY TO BE
 DETERMINED BY BUILDER & IN ACCORDANCE WITH RELEVANT AUSTRALIAN
 STANDARDS.
- 10. THIS PLAN IS TO BE READ IN CONJUNCTION WITH THE ARCHITECTURAL, HYDRAULIC. LANDSCAPE AND STRUCTURAL PLANS.
- 11. ANY DISCREPANCIES OR OMISSIONS SHALL BE REFERRED TO THE DESIGN ENGINEER FOR RESOLUTION PRIOR PROCEEDING CONSTRUCTION.
- 12. THE SITE SHALL BE GRADED AND DRAINED SO THAT STORMWATER WILL BE DIRECTED AWAY FROM THE BUILDING PLATFORM.
- 13. SITE TO BE GRADED AS SUCH SO WATER CAN NOT POND ON THE SURFACE.
- 15. PROVIDE EMERGENCY OVERFLOW TO ALL PLANTER BOX AND BALCONIES.
- 16. ALL PITS WITH DEPTH MORE THAN 1M MUST HAVE IRON STEPS.

14. ALL PITS OR GRATES IN TRAFFICABLE AREAS TO BE HEAVY DUTY.

- 17. ADEQUATE SUB-SOIL DRAINAGE CONNECTING TO THE STORMWATER DRAINAGE SYSTEM SHALL BE PROVIDED TO ALL RETAINING WALLS & EMBANKMENTS.
- 18. PROVIDE STORMWATER GRATE 150Wx150D AT THE BASE OF ALL MECHANICAL SHAFTS AND UNCOVERED STAIRS OR OPENINGS.
- 19. ENSURE ALL DRAINAGE WORKS ARE AWAY FROM TREE ROOTS.

AS3500.3:2021 MIN. REQUIREMENTS

MINIMUM GRADIENT OF PIPES		
MINIMUM GRADIENT		
1:100		
1:100		
1:200		
1:250		
1:300		

MINIMUM PIPE COVERSLOCATIONPLASTIC PIPES MINIMUM COVER (mm)1. NO VEHICULAR LOADING-(a) NOT PAVED-(i) SINGLE DWELLING100(ii) OTHERS300(b) PAVED100 BELOW UNDERSIDE OF PAVEMENT2. VEHICULAR LOADING (NOT ROAD)-(i) NOT PAVED450(ii) PAVED100 BELOW UNDERSIDE OF PAVEMENT

MINIMUM INTERNAL DIMENSIONS FOR PITS		
DEPTH TO INVERT OF OUTLET	MINIMUM PIT SIZE (mm)	
≤ 450mm	350 x 350	
≤ 600mm	450 × 450	
< 600mm ≤ 900mm	600 x 600	
< 900mm ≤ 1200mm	600 × 900	
> 1200mm	900 x 900	

RAINWATER REUSE NOTES

- 1. EVERY FIXTURE SERVICED FROM THE RECYCLED WATER SUPPLY MUST BE NOTED WITH A PLAQUE FOR IDENTIFICATION AND MARKED WITH "NOT FOR HUMAN CONSUMPTION" OR "NON-POTABLE WATER".
- 2. RAINWATER TANK TO BE CONNECTED TO AT LEAST ONE OUTDOOR TAP.
- 3. OVERFLOW FROM RAINWATER TANK TO BE CONNECTED TO STORMWATER DRAINAGE SYSTEM. NO OTHER CONNECTIONS TO THE OVERFLOW PIPELINE SUCH AS SURFACE WATER INLETS.
- 4. ALL RECYCLE WATER PIPES TO BE COLOUR CODED FOR IDENTIFICATION.
- 5. FIRST-FLUSH DEVICES ARE REQUIRED TO BE CHECKED AND CLEANED REGULARLY.
- 6. WATER AUTHORITY MUST BE CONTACTED REGARDING RECYCLED WATER ON THE BUILDING AND FOR THE BACKFLOW PREVENTION REQUIREMENTS AND TOP-UP SYSTEM
- 7. ANY GARDEN OR CARWASH TAPS CONNECTED RECYCLE SYSTEM MUST BE LOCATED 1.5m MIN. ABOVE THE
- 8. FOR PERIOD OF LOW WATER LEVEL IN THE RAINWATER TANK, A CONNECTION TO WATER MAIN IS NEEDED AND TO BE PROVIDED IN ACCORDANCE WITH THE WATER AUTHORITY.
- 9. PUMPS AND FILTERS ON OUTLETS FROM RECYCLE SYSTEM TO BE SUPPLIED AS MAY BE REQUIRED.

GRAHAM DICKSON



SITE LOCATION PLAN

LEGEND

• DP# DOWNPIPE

• U/DP# DOWNPIPE UNDER

• EX. DP# EXISTING DOWNPIPE

■ SW ■ STORMWATER PIPE

■ SW ■ EXISTING STORMWATER PIPE

■ SW ■ EXISTING STORMWATER PIPE

■ AG ■ SUBSOIL DRAINAGE AG PIPE

■ PIPED FLOW DIRECTION

■ SURFACE FALL/OVERLAND FLOW DIRECTION

■ GRATED PIT


■ STRIP DRAIN

■ FW FLOOR WASTE

⑤ PD PLANTER BOX DRAIN

DRAWING SCHEDULE

DWG NO.	DWG TITLE
D000	COVER SHEET
D010	LOWER GROUND AND GROUND FLOOR STORMWATER DRAINAGE CONCEPT PLAN
D020	LEVEL 1 AND ROOF STORMWATER DRAINAGE CONCEPT PLAN



CLIENT

ARCHITECT


arkh design







	DRAWN	H.P.	PROJ
			AL
	DESIGNED	H.P.	3 (
	CHECKED	O.S.	DRAV
	SCALE	AS INDICATED	CC
8	SIZE	A1	


PROJECT	DRAWING NO.	REV.
ALTERATION AND ADDITIONS 3 OCEAN GROVE, COLLAROY NSW 2097	D000	В
DRAWING TITLE	JOB NO.	
COVER SHEET	25068	3









1. ALL DOWNPIPE LOCATIONS TO BE CHECKED BY ARCHITECT AND CONTRACTOR PRIOR TO CONSTRUCTION.



PLANTER BOX DRAIN TYPICAL DETAIL
SCALE: NTS



FLOOR WASTE TYPICAL DETAIL
SCALE: NTS



CLIENT

GRAHAM DICKSON



ARCHITECT



	DRAWN	H.P.	PROJECT
	DESIGNED	H.P.	ALTER 3 OCE
Į	CHECKED	O.S.	DRAWING TIT
	SCALE	AS INDICATED	LEVEL
	SIZE	A1	PLAN

ALTERATION AND ADDITIONS
3 OCEAN GROVE, COLLAROY NSW 2097

DRAWING TITLE

LEVEL 1 AND ROOF STORMWATER DRAINAGE CONCEPT

D020 BJOB NO.

DRAWING NO.

25068

RISE CONSULTING ENGINEERS PTY. LTD.