

Natural Environment Referral Response - Flood

Application Number:	Mod2018/0528
To:	Luke Perry
Land to be developed (Address):	Lot 12 DP 1229780 , 18 Howard Avenue DEE WHY NSW 2099

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed development is not considered to increase flood risk. Conditions are recommended to manage the flood risk from future services located in the proposed storage area and the storage of hazardous goods.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Flooding

In order to protect property and occupants from flood risk the following is required:

Building Components and Structural Soundness – C3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level.

Storage of Goods – D1

Hazardous or potentially polluting materials shall not be stored below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.