

Reference: 2018/211883
Enquiries: Development Assessment

Total Pages: 15

K Reader
C/- Vaughan Milligan Development Consulting P/L
Po Box 49
NEWPORT NSW 2106

Dear Sir/Madam,

NOTICE OF DETERMINATION

Pursuant to Section 81(1)(a) of the *Environmental Planning and Assessment Act 1979*

Development Application No.	253/2017
Proposed Development	Alterations and additions to the existing dwelling house
Land to be developed	Lot A in DP 373783; 11 Beatty Street, Balgowlah Heights
Determination	Approved by DEL
Date of Determination	29 March 2018
Consent is to operate from	29 March 2018
Consent is to lapse on	29 March 2023

Council determined this application under delegated authority on 29 March 2018 when it was determined:

That Development Application No. 253/2017 for Alterations and additions to the existing dwelling house at 11 Beatty Street, Balgowlah Heights be **approved** subject to the following conditions:-

GENERAL CONDITIONS

1. The development, except where modified by the conditions of this consent, is to be carried out in accordance with the following plans and reference documentation;

Drawings affixed with Council's 'Development Consent' stamp relating to Development Consent No. 253/2017:

Plan No. / Title	Issue/ Revision & Date	Prepared By
Sheet 02 / Site Plan	Rev. C, September 2017	Paul Carrick & Associates
Sheet 03 / Ground Floor Plan	Rev. B, September 2017	Paul Carrick & Associates
Sheet 04 / Upper Floor Plan	Rev. B, September 2017	Paul Carrick & Associates
Sheet 05 / Roof Plan	Rev. B, September 2017	Paul Carrick & Associates
Sheet 06 / Elevations – Front North & Streetscape	Rev. B, September 2017	Paul Carrick & Associates
Sheet 07 / Elevations – Side West & Section	Rev B, September 2017	Paul Carrick & Associates
Sheet 08 / Elevations Rear South & Section	Rev. B, September 2017	Paul Carrick & Associates
Sheet 09 / Elevations Side East & Section	Rev. B, September 2017	Paul Carrick & Associates
Sheet 20 / Carport Entry Floor Plan	Rev. C, September 2017	Paul Carrick & Associates

Reference Documentation relating to Development Consent No. 253/2017:

- Bushfire Report prepared by Sydney Bushfire Consultants dated 10 July 2017.
- BASIX Certificate No. A294596 dated 29 September 2017.

In the event of any inconsistency between the approved plans and supplementary documentation, the plans will prevail.

Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council

2. Prescribed Conditions

- All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);



northern
beaches
council

- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
- (i) showing the name, address and telephone number of the Principal Certifying Authority for the work, and
 - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
 - (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
- (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
 - (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifying Authority for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
- (i) protect and support the adjoining premises from possible damage from the excavation, and
 - (ii) where necessary, underpin the adjoining premises to prevent any such damage.
 - (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
 - (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative Requirement (DACPLB09)



northern
beaches
council

3. General Requirements

(a) Unless authorised by Council:

Building construction and delivery of material hours are restricted to:

7.00 am to 5.00 pm inclusive Monday to Friday,

8.00 am to 1.00 pm inclusive on Saturday,

No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) At all times after the submission the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of a final Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (c) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (d) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (e) Prior to the release of the Construction Certificate, payment of the Long Service Levy is required. This payment can be made at Council or to the Long Services Payments Corporation. Payment is not required where the value of the works is less than \$25,000. The Long Service Levy is calculated on 0.35% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
- (f) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (g) No building, demolition, excavation or material of any nature and no hoist, plant and machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (h) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (i) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged



northern
beaches
council

during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.

- (j) Prior to the commencement of any development onsite for:
- i) Building/s that are to be erected
 - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
 - iii) Building/s that are to be demolished
 - iv) For any work/s that is to be carried out
 - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

- (k) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
- (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;
Relevant legislative requirements and relevant Australian Standards (including but not limited) to:
- (i) Swimming Pools Act 1992
 - (ii) Swimming Pools Amendment Act 2009
 - (iii) Swimming Pools Regulation 2008
 - (iv) Australian Standard AS1926 Swimming Pool Safety
 - (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools
 - (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.
Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.



northern
beaches
council

GENERAL CONDITIONS RELATING TO APPROVAL

1 (1AP04)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

Reason: To ensure compliance with the approved development.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

ANS01

An Erosion and Sediment Management Plan which provides adequate measures for erosion and sediment control, must be submitted with the Construction Certificate and approved by the Council/Accredited Certifier. The Erosion and Sediment Management Plan shall comply with the requirements for Erosion and Sediment Management plans contained with Clause 2.1.11 of the Manly Development Control Plan, 2013 and Manly Council's Guidelines for Sediment and Erosion Controls on Building Sites, 2005.

Reason: To protect the environment from the effects of sedimentation and erosion from development sites.

ANS02

The external finish to the roof shall have a medium to dark range in order to minimise solar reflections to neighbouring properties. Light colours such as off white, cream, silver or light grey colours are not permitted.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure that excessive glare or reflectivity nuisance does not occur as a result of the development.

ANS03

The proposal is to comply with all relevant provisions of Council's Drainage Easement Policy – D100. Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure compliance with Council policy.

2 (2AP03)

Consent given to build in close proximity to the allotment boundary is in no way to be construed as permission to build on or encroach over the allotment boundary. Your attention is directed to the provisions of the Dividing Fences Act 1991 which gives certain rights to adjoining owners, including use of the common boundary.



northern
beaches
council

In the absence of the structure standing well clear of the common boundary, it is recommended you make yourself aware of your legal position which may involve a survey to identify the allotment boundary.

Reason: To advise developers of their responsibilities and to protect the interests of adjoining owners.

3 (2CD01)

Pursuant to Section 97 of the Local Government Act, 1993, Council requires prior to the issue of Construction Certificate, or commencement of any excavation and demolition works, payment of a Trust Fund Deposit as per the current rates in Council's Fees and Charges. The Deposit is required as security against damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development. All building work must be carried out in accordance with the provisions of the Building Code of Australia.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicants interest for it to be as full and detailed as possible.

Where by Council is not the Principal Certifying Authority, refund of the trust fund deposit will also be dependent upon receipt of a final Occupation Certificate by the Principal Certifying Authority and infrastructure inspection by Council.

Reason: To ensure security against possible damage to Council property.

4 (2CD05)

Detailed engineering drawings of all work must be submitted for approval by the Council/Accredited Certifier prior to the release of the Construction Certificate.

Reason: To ensure the provision of public infrastructure of an appropriate quality arising from the development works to service the development.

5 (2CD07)

A Certificate of Adequacy signed by a practising structural engineer stating the existing structure is capable of supporting the proposed additions, is to be submitted to the Council/Accredited Certifier prior to the issue of the Construction Certificate.

Reason: The existing building must be able to support proposed additional loading.



northern
beaches
council

6 (2DS01)

A detailed stormwater management plan is to be prepared to fully comply with Council's Specification for On-site Stormwater Management 2003 and Specification for Stormwater Drainage 2003 and must be submitted to Council prior to issue of the Construction Certificate. The stormwater management plan and designs are to be prepared by a suitably qualified engineer with experience in hydrology and hydraulics.

Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure that infrastructure reverting to Council's care and control is of an acceptable standard.

7 (2FP02)

Detailed drawings and specifications of all works (including but not limited to structures, road works, driveway crossings, footpaths and stormwater drainage) within existing roads, must be submitted to and approved by Council under the Roads Act 1993, before the issue of any Construction Certificate. Specific works include:

- 1) Full width vehicular crossings having a maximum width, at the back of layback, and in accordance with the current policy of Council and Specifications for the construction of vehicle crossings; and
- 2) Longitudinal sections for both sides of the vehicular crossing and driveway commencing at the centre line of the road carriageway must be provided for assessment. Gradients and transitions must be in accordance with Australian Standard AS 2890.1 – 2004, Part 1 – Off-Street Car Parking. The driveway profile submitted to Council must be to scale at 1:25 (for template checking purposes) and contain all relevant details: reduced levels, proposed grades and distances.

Driveway to be designed to provide for existing or future footpaths across driveway, in accordance with Council's Specification for Civil Infrastructure Works, Developments & Subdivisions 2003 and Australian Standard AS 1428.1:2001 - Design for access and mobility.

Reason: To facilitate suitable vehicular access to private sites.

8 (2LD03)

Details are to be provided of the existing or proposed native trees for the site which are typically expected to reach a height at maturity of 10 metres, to bring the proposal into compliance with Figure 37 of the Manly Development Control Plan 2013. A list of appropriate native trees for the Manly area may be obtained at Council's Customer Service desk and the Manly Council website. Details of new planting are to include appropriate siting and pot size (minimum of 25 litres) in accordance with section 2.1.3 of the Manly Development Control Plan 2013. Details are to be submitted with the Construction Certificate to the satisfaction of the Council/Accredited Certifier.

Reason: This is to ensure the planting of endemic trees back onto the site.



northern
beaches
council

9 (2PT02)

All driveways, car parking areas and pedestrian paths are to be suitably surfaced. Details of the treatment to these areas are to be submitted to the Council/Accredited Certifier prior to issue of the Construction Certificate.

Reason: To provide suitable stormwater disposal and to prevent soil erosion and runoff.

10 (2WM02)

A Waste Management Plan is to be submitted with the application prior to a Construction Certificate being issued in accordance with the Manly Development Control Plan 2013.

The plan should detail the type and estimate the amount of demolition and construction waste and nominate how these materials will be sorted and dealt with. Weight dockets and receipts must be kept as evidence of approved methods of disposal and recycling. All demolition and excess construction materials are to be recycled where ever practicable. It should include consideration of the facilities required for the ongoing operation of the premises' recycling and waste management services after occupation. A template is available from the Manly Council website.

Reason: To plan for waste minimisation, recycling of building waste and on-going waste management.

CONDITIONS TO BE SATISFIED PRIOR TO ANY COMMENCEMENT

11 (3BM01)

The floor surfaces of bathrooms, shower rooms, laundries and WC compartments are to be of an approved impervious material properly graded and drained and waterproofed in accordance with Australian Standard AS 3740. Certification is to be provided to the Principal Certifying Authority from a licensed applicator prior to the fixing of any wall or floor tiles.

Reason: To prevent the penetration of dampness through walls and floors.

12 (3CD01)

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued.

Reason: To ensure compliance with statutory provisions.

13 (3CD03)

An adequate security fence is to be erected around the perimeter of the site prior to commencement of any excavation or construction works, and this fence is to be maintained in a state of good repair and condition until completion of the building project.

Reason: To protect the public interest and safety.



northern
beaches
council

14 (3FP01)

The applicant must complete an application form and pay applicable fees for an application to Council for the construction of a Vehicular Crossing, for the design, specification and inspection by Council. Applications are to be made a minimum of two (2) working days prior to commencement of proposed works on Council's property.

Reason: To provide suitable vehicular access to private sites, without disruption to pedestrian and vehicular traffic.

15 (3LD01)

All healthy trees and shrubs identified for retention on the submitted landscape drawing are to be suitably marked for protection before any construction works start.

Reason: To ensure the trees conditioned to stay on the site are suitably protected during any construction works.

16 (3PT01)

In accordance with the Roads Act 1993, written consent from Council must be obtained and must be in hand prior to any track equipped plant being taken in or onto any roadway, kerb & gutter, footway, nature strip, or other property under Council's control.

Reason: To ensure appropriate protection of public infrastructure and facilitate access for public and vehicular traffic.

17 (3PT02)

Applications for a construction zone on a local road require 28 days notice to Council indicating location and length. All construction zones require the approval of the Manly Traffic Committee.

Reason: To ensure Council and the Traffic Committee have sufficient time and information to assess the traffic and access implications of a proposed construction zone and to develop appropriate responses to those implications.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

18 (4FP01)

The existing footpath level and grade at the street alignment of the property must be maintained.

Reason: To ensure appropriate access and infrastructure protection.

19 (4LD02)

All healthy trees and shrubs identified for retention on the drawing are to be:

- (a) suitably protected from damage during the construction process, and
- (b) retained unless their removal has been approved by Council.

Reason: This is to ensure that the trees on the site which do not have approval to be removed on the site are suitably protected during any construction works.



northern
beaches
council

Internal Note: This condition is to be imposed with 3LD01.

20 (4LD03)

The felling, lopping, topping, ringbarking, wilful destruction or removal of any tree/s unless in conformity with this approval or subsequent approval is prohibited.

Reason: To prohibit the unnecessary damage or removal of trees without permission from Council during any construction.

21 (4LD04)

The following precautions must be taken when working near trees to be retained:

- harmful or bulk materials or spoil must not be stored under or near trees,
- prevent damage to bark and root system,
- mechanical methods must not be used to excavate within root zones,
- topsoil from under the drip line must not be added and or removed,
- ground under the drip line must not be compacted, and
- trees must be watered in dry conditions.

Reason: This is to ensure no damage is caused to trees from various methods of possible damage.

22 (4LD07)

Where development/construction necessitates the pruning of more than 10% of existing tree canopy, a permit application must be lodged with the Council's Civic Services Division, subject to the Tree Preservation Order 2001.

Reason: To ensure those trees are maintained appropriately and compliance with Australian Standard AS 4373:2007 – Pruning of Amenity Trees.

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

23 (5DS01)

Stormwater drainage from the proposed addition/extension must be disposed of to the existing drainage system. All work is to be carried out in accordance with Council standards and specifications for stormwater drainage. Work is to be completed prior to the issue of the Occupation Certificate.

Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure infrastructure reverting to Council's care and control is of an acceptable standard.

24 (5FP01)

All surplus vehicular crossings and/or kerb laybacks must be removed and the kerb and nature strip reinstated prior to issue of the Occupation Certificate.

Reason: To provide on-street parking, suitable vehicular access to private sites, and infrastructure protection.



northern
beaches
council

ONGOING CONDITIONS RELATING TO THE OPERATION OF THE PREMISES OR DEVELOPMENT

ANS04

The proposed carport is to remain as a lightweight structure that can be dismantled to allow access to the Council Stormwater Pipe located below when required. The owner of the property is responsible for any costs incurred in the removal of the carport and concrete slab in order to provide access to the pipe.

Reason: To ensure the ongoing provision of access to the Council assets located on the site.

25 (6FC01)

The erection of dividing fences under this consent does not affect the provisions of the Dividing Fences Act 1991. Council does not adjudicate civil disputes relating to the provision of, or payment for, the erection of dividing fences.

Note: Further information can be obtained from the NSW Department of Lands. Community Justice Centres provide a free mediation service to the community to help people resolve a wide range of disputes, including dividing fences matters. Their service is free, confidential, voluntary, timely and easy to use. Mediation sessions are conducted by two impartial, trained mediators who help people work together to reach an agreement. More than 85% of mediations result in an agreement being reached. Mediation sessions can be arranged at convenient times during the day, evening or weekends. Contact the Community Justice Centre either by phone on 1 800 990 777 or at <http://www.cjc.nsw.gov.au/>.

Reason: To ensure the applicant is aware the Dividing Fences Act 1991 may be used to resolve disputes about dividing fences.

26 (6LP04)

Leighton Green Cypress Cupressocyparis leylandii or any of its cultivars, must not be planted on the site for the life of the development. In the event of any inconsistency between this condition and the development application documents, this condition will prevail to the extent of the inconsistency.

Reason: To reduce the potential for adverse amenity effects such as overshadowing, loss of views, and loss of plant diversity.

27 (6MS02)

No person shall use or occupy the building or alteration which is the subject of this approval without the prior issue of an Occupation Certificate.

Reason: Statutory requirement, Environmental Planning and Assessment Act 1979.

WARNING: Failure to obtain a Construction Certificate prior to the commencement of any building works is a serious breach of Section 81A(2) of the *Environmental Planning & Assessment Act 1979*. It is also a criminal offence which attracts substantial penalties and may also result in action in the Land and Environment Court and orders for demolition.



northern
beaches
council

Please note that all building work must be carried out fully in accordance with this development consent and conditions of approval. It is an offence to carry out unauthorised building work or building work that is not in accordance with this consent.

In accordance with Clause 284 of the *Environmental Planning and Assessment Regulation 2000*, non compliance with the above conditions may result in Council issuing a Penalty Notice which may incur a fine.

Notes:

Review of Determination

1. If you are dissatisfied with this decision, Section 82A of the *Environmental Planning and Assessment Act 1979* gives the applicant the right of review by Council within six (6) months of the date of determination. Please note that this review must be completed within the six (6) month period after the date of determination. A determination in respect of integrated development or designated development cannot be reviewed by Council.

Right of Appeal

2. If you are dissatisfied with this decision, Section 97 of the *Environmental Planning and Assessment Act 1979* gives the applicant the right to appeal to the Land and Environment Court of New South Wales (their address being Level 4, 225 Macquarie Street, Sydney NSW 2000) within six (6) months after the date on which the applicant received notice of the determination of that application.

Modification of the Consent

3. You are advised that any modification to the approved building(s) or structure(s), changes to the layout of buildings or structures on the site, modification of any conditions of this consent or changes to the operation of an approved use may require the lodgement of modification to the consent under Section 96 of the *Environmental Planning and Assessment Act 1979*.
4. Please be advised that in order to lodge an application to modify the consent pursuant to this section, the development must be substantially the same development for which consent was originally granted. If Council is not satisfied that the development is substantially the same, a new development application for the works/use will be required.

Before the Commencement of Building / Subdivision Work

5. A Long Service Levy is payable prior to the issue of all Construction Certificates or Complying Development Certificates, on building works in NSW, where the value of works is \$25,000 (inclusive of GST) and above. The levy is presently calculated by multiplying the value of works (including GST) by 0.35%. When calculating the levy round down to the nearest dollar, for example, if the cost of works is \$485,260 multiply this by 0.35% = \$1,698.41. The levy payable is therefore \$1,698.



northern
beaches
council

Please be advised that the levy is a state government levy and the percentage at which it is charged, can change without notice. The levy funds a portable long service scheme for workers in the building and construction industry. For further information see www.lspc.nsw.gov.au or contact the Corporation on 13 14 41.

6. The erection of a building in accordance with this development consent **must not be commenced until:**
- (a) detailed plans and specifications of the building have been endorsed with a **Construction Certificate** by:
 - (i) the Consent Authority, or
 - (ii) an Accredited Certifier, and
 - (b) the person having the benefit of the development consent:
 - (i) has appointed a **Principal Certifying Authority**, and
 - (ii) has notified the Consent Authority and the Council (if the Council is not the consent authority) of the appointment, and
 - (c) the person having the benefit of the development consent has given at least two days notice to the Council of the person's intention to commence the erection of the building.

Details in regard to **Notice of Commencement of Building / Subdivision Work** (Form 7 attached to this consent) and appointment of the Principal Certifying Authority are to be submitted to Council following issue of the Construction Certificate and two (2) working days prior to commencement of building works.

Other approvals

7. It is advised that your plans must be submitted to Sydney Water for approval at least fourteen (14) days before commencement of works. Please phone Sydney Water on 13 20 92 for information regarding an office closest to you.

Letter Box

8. Any new letter box is to comply with requirements outlined in the Australia Post 'General Post Guide' dated September 2007 or later.

Australia post delivers only in to mail boxes of an approved size. Australia Post recommends a separate aperture, box or tube to accommodate newspapers and non-mail articles.

The approved dimensions of the mail boxes are:-

Internal width (left to right) - minimum 230mm

Internal depth (front to back) - minimum 330 mm

Internal height - minimum 160mm

Horizontal aperture – minimum 230mm x 30mm and minimum 130mm above base



northern
beaches
council

Vertical aperture – minimum 330mm x 30mm and minimum 40mm above internal base

Elevation of aperture above ground level –

Single mail box – between 900mm and 1200mm

Group mail boxes – between 600mm and 1600mm.

For single residential or commercial premises the mail box is to be located on the boundary of the property with the footpath or road. The mail box aperture must face the footpath or road.

For further details please refer to Australia Post website auspost.com.au.

Reason: To comply with Australia Post requirements.

Dial Before You dig

9. Underground assets may exist in the area that is subject to your application. In the interests of health and safety and in order to protect damage to third party assets please contact *Dial Before You Dig* at www.1100.com.au or Telephone on 1100 before excavating or erecting structures (This is the law in NSW). If alterations are required to the configuration, size, form or design of the development upon contacting the *Dial Before You Dig* service, an amendment to the development consent (or a new development application) may be necessary. Individuals owe asset owners a duty of care that must be observed when working in the vicinity of plant or assets. It is the individual's responsibility to anticipate and request the nominal location of plant or assets on the relevant property via contacting the *Dial Before You Dig* service in advance of any construction or planning activities.

Telecommunications Act 1997 (Commonwealth)

10. Telstra (and its authorised contractors) are the only companies that are permitted to conduct works on Telstra's network and assets. Any person interfering with an availability or installation owned by Telstra is committing an offence under the Criminal Code Act 1995 (Cth) and is liable for prosecution. Furthermore, damage to Telstra's infrastructure may result in interruption to the provision of essential services and significant costs. If you are aware of any works or proposed works which may affect or impact on Telstra's assets in any way, you are required to contact:- Telstra's network Integrity Team on Phone Number 1 800 810 443.

Should you have any questions in relations to the matter, please contact Council's Planning, Place & Community, on (02) 9976 1414, during business hours.

Signed below on behalf of the consent authority.

Yours faithfully,

Date: 3 April 2018

Rodney Piggott
Planning Assessment Manager
Northern Beaches Council