



Alteration and Additions 39 Pine Street Manly, NSW 2095 Richard Parkes



DRAWING LIST

No.	TITLE	
SWCC 1.1	COVER SHEET	
SWCC 1.2	STORMWATER MANAGEMENT PLAN & GENERAL NOTES	
SWCC 1.3	EROSION AND SEDIMENT CONTROL PLAN & DETAILS	
SWCC 1.4	EXISTING & PROPOSED SITE PLAN AND IMPERVIOUS AREAS	
SWCC 1.5	STORMWATER DRAINAGE LAYOUT & DETAIL - GROUND FLOOR	



partridge.com.au partridge@partridge.com.au Partridge Hydraulic Pty Ltd ABN 71 124 297 883

Copyright: The design and details shown on this drawing are specific to this project only and may not be reproduced in whole or in part or be used for any other project or purpose without the written consent of Partridge Structural Pty Ltd.

RICHARD PARKES

Architect
STUDIO P ARCHITECTS
LEVEL 1/31A PLAYFAIR ST THE ROCKS NSW
TEL 0414 434 848

Project
ALTERATIONS AND ADDITIONS
39 PINE STREET

Title STORMWATER SERVICES

COVER PAGE & DRAVING LIST

MANLY NSW 2095

DO NOT SCALE: USE FIGURED DIMENSIONS

The presence of this signature signifies that this is the certified drawing issued for construction.	Designed J.P.	Drawn J.Z.
	Job No. 2023H0103	Scale at A1 N/A
Date NOV 2023	Drawing No. SWDA 1.1	Revision 1

NOT FOR CONSTRUCTION

STORMWATER MANAGEMENT PLAN

PARTRIDGE HYDRAULIC SERVICES WERE ENGAGED TO CARRY OUT A STORMWATER MANAGEMENT PLAN FOR THE PROPOSED SITE AT 39 PINES STREET, MANLY NSW. THE BELOW ADDRESSES THE MANAGEMENT OF STORMWATER WITHIN THE PROPOSED SITE BOUNDARIES.

1. INTRODUCTION - SITE DETAILS

EXISTING SITE DETAILS

THE SUBJECT SITE IS FULLY DEVELOPED WITH AN EXISTING SINGLE DWELLING, LOCATED AT 39 PINE STREET, MANLY. THE OVERALL SITE HAS AN APPROXIMATE AREA OF 650 m2. THE LOT CURRENTLY COMPRISES:

- UNCOVERED CAR PARKING SPACE AND ASSOCIATED DRIVEWAY
- AN EXISTING SINGLE DWELLING
- TERRACE, POOL AND POOL CABANA TO THE BACK OF THE HOUSE
- ASSOCIATED LANDSCAPE TO THE REAR OF THE HOUSE

THE SITE IS REAR FALLING TOWARDS PUBLIC RESERVE TO THE SOUTH AND IS BOUND BY AN ADJACENT PRIVATE PROPERTIES FROM THE EAST AND THE WEST. AND PINE STREET TO THE NORTH, BOTH PEDESTRIAN AND THE VEHICLE ACCESS ARE FROM PINE STREET.

PROPOSED NEW DEVELOPMENT

IT IS PROPOSED TO UNDERTAKE FOLLOWING ALTERATIONS AND ADDITIONS:

- CONSTRUCTION OF NEW BASKETBALL AREA AT THE REAR OF THE PROPERTY WITH ASSOCIATED LANDSCAPE.
- CONSTRUCTION OF EXTENSION TO DINING AREA WITH NEW ROOF OVER

2. EXISTING STORMWATER NETWORK AND DISCHARGE

THE SITE IS CURRENTLY DEVELOPED WITH ON-SITE INGROUND STORMWATER DRAINAGE SYSTEM DISCHARGE TO KERB AND GUTTER AT PINE STREET, ROOF AREAS ARE COLLECTED TO RAINWATER TANKS PRIOR OVERFLOW TO PUBLIC SYSTEM. HARDSTAND IS DRAINED VIA SURFACE LEVEL OVERFLOW TOWARDS THE RESERVE AT THE REAR BOUNDARY WITH NO CONTROL.

3. PROPOSED STORMWATER NETWORK CONCEPT AND DISCHARGE

IT IS PROPOSED TO CONSTRUCT ADDITIONAL STORMWATER SYSTEM ON FOLLOWING PRINCIPLES:

- REPLACE THE EXISTING ROUND RAINWATER TANK AND INSTALL TWO SLIMLINE RAINWATER TANKS (VOLUME TO MATCH)
- NEW BOX GUTTER TO BE INSTALLED TO COLLECT ROOF WATER AT THE DINING EXTENSION
- NEW ROOF RUNOFFS TO BE CONNECTED TO RAINWATER TANK.
- NO CHANGES TO SITE DISCHARGE ARRANGEMENT.

5. STORMWATER QUANTITY MANAGEMENT

ACCORDING TO NORTHERN BEACHES COUNCIL - WATER MANAGEMENT FOR DEVELOPMENT POLICY (2020), SITE WITHIN REGION 3 - ZONE 1 DO NOT REQUIRED OSD TANK WHEN THE DEVELOPMENT IS A ONE-OFF EXTENSION OR AN ADDITION INVOLVING AN INCREASE IN IMPERVIOUS AREA OF LESS THAN 50 m2. TOTAL INCREASE IN IMPERVIOUS AREA IS ONLY 30 m2.

6. STORMWATER QUALITY MANAGEMENT

NO STORMWATER WATER QUALITY DEVICE HAS BEEN PROPOSED FOR THIS MINOR DEVELOPMENT. NEW ROOF ARE COLLECTED INTO RAINWATER TANKS. 20 m² OF HARDSTAND DRAINED INTO NEARBY LANDSCAPING AND TOWARDS RESERVE.


7. COUNCIL DOCUMENTS REFERENCE


THE ABOVE ASSESSMENT HAS BEEN PREPARED AND BASED ON PUBLISHED TOPOGRAPHIC MAPS, PHYSICAL LAND SURVEY, HYDRAULIC AND HYDROLOGICAL CALCULATIONS, AVAILABLE AERIAL PHOTOGRAPHY OF THE SITE AND IN ACCORDANCE WITH RELEVANT AUSTRALIA STANDARDS AND COUNCIL DEVELOPMENT CONTROL PLANS BELOW:

- AS 3500 PLUMBING AND DRAINAGE
- NORTHERN BEACHES COUNCIL WATER MANAGEMENT DEVELOPMENT POLICY AUG 2020

GENERAL NOTES

- 1. THIS IS A STORMWATER DRAINAGE PLAN ONLY, REFER TO ARCHITECTURAL DRAWINGS FOR ALL SETOUT INFORMATION.
- 2. ALL STORMWATER RUNOFF FROM SURFACE, PITS, SUMPS AND UNDERGROUND PIPE NETWORK TO BE COLLECTED VIA ON-SITE DRAINAGE SYSTEM PRIOR TO DISCHARGE FROM THE SITE.
- 3. ALL PIPES ARE TO BE 100DIA UPVC LAID AT 1.0% MIN GRADE. UPVC PIPES TO BE SOLVENT WELDED JOINTS U.N.O.
- 4. ALL PIPES ARE TO BE PROPRIETARY PRE-CAST ITEMS, COVER LEVELS TO MATCH U.N.O.
- 5. ALL GRATED DRAINS TO HAVE BASE GRADED 1.0% MIN WITH HEAVY DUTY GRATES.
- 6. IT IS THE BUILDER'S RESPONSIBILITY TO LAY ALL PIPES IN ACCORDANCE WITH ALL RELEVANT AUTHORITY REQUIREMENTS (EG. COUNCIL, EPA, SYDNEY WATER).
- 7. THE CONTRACTOR SHALL LOCATE EXISTING SERVICES ON SITE PRIOR TO CONSTRUCTION AND SHALL TAKE EXTREME CAUTION DURING CONSTRUCTION.
- 8. ALL WORKS ARE TO BE UNDERTAKEN IN ACCORDANCE WITH THE LOCAL AUTHORITY'S CIVIL SPECIFICATION AND STANDARDS TO THE SATISFACTION OF THE LOCAL AUTHORITY OR PRIVATE CERTIFYING AUTHORITY'S REPRESENTATIVE. ANY DISCREPANCY, VARIATION OR ADDITIONAL WORKS SHALL BE APPROVED BY THE BUILDER'S REPRESENTATIVE BEFORE COMMENCEMENT OF WORKS.
- 9. THE LOCAL AUTHORITY OR PRIVATE CERTIFYING AUTHORITY'S INSPECTION OF WORKS SHALL BE NOTIFIED AT LEAST 48 HOURS BEFORE INSPECTOR'S INSPECTION SCHEDULE REQUIREMENTS AND ENSURE THAT EACH IDENTIFIED STAGE OF WORKS IN ACCORDINGLY INSPECTED.
- 10. THESE DRAWINGS ARE DIAGRAMMATIC REPRESENTATION OF WORKS TO BE CARRIED OUT ONLY AND ARE NOT TO BE SCALED OFF.
- 11. ALL LEVELS SHALL BE OBTAINED FROM ESTABLISHED BENCH MARKS ONLY. DATUM USED ON THESE DRAWINGS IN AUSTRALIA HEIGHT DATUM (AHD) UNLESS NOTED OTHERWISE.
- 12. UTILITY INFORMATION SHOWN ON THE PLANS IS NOT INTENDED TO DEPICT MORE THAN THE PRESENCE OF ANY SERVICES. ACTUAL LOCATIONS SHOULD BE VERIFIED BY HAND EXCAVATION PRIOR TO CONSTRUCTION.
- 13. EROSION AND SEDIMENT CONTROL MEASURES ARE TO BE PROVIDED WHERE SHOWN ON THE DRAWINGS, IN ACCORDANCE WITH THE SPECIFICATION AND THE CONSTRUCTION ENVIRONMENTAL MANAGEMENT PLAN (IF APPLICABLE).





JP ES 15.11.23

shown on this drawing are specific to

reproduced in whole or in part or be

used for any other project or purpose

F.S.

N/A

Revision

2023H0103

SWDA 1.2

Drawing No.


NOT FOR CONSTRUCTION

Scale at A1

this project only and may not be


without the written consent of

Partridge Structural Pty Ltd.




EROSION AND SEDIMENT CONTROL PLAN

- 1. MEASURES PROVIDED WILL BE TO THE SATISFACTION OF THE PRINCIPAL'S REPRESENTATIVE IN ACCORDANCE WITH THE LOCAL AND STATUTORY REQUIREMENTS UNLESS NOTED OTHERWISE. ALL WORKS SHALL BE ERECTED AND CONSTRUCTED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE 'BLUE BOOK'- MANAGING URBAN STORMWATER (MUS): SOILS AND CONSTRUCTION, LANDCOM (VOL 1) AND DECCW (VOL 2) AND COUNCIL'S DEVELOPMENT CONTROL PLAN (DCP).
- 2. ALL EXCAVATION WORKS ARE TO BE IN ACCORDANCE WITH THE GEOTECHNICAL REPORT, IF AVAILABLE, AND THE STRUCTURAL ENGINEER'S DRAWINGS.
- 3. INSTALL EROSION AND SEDIMENT CONTROL MEASURES PRIOR TO COMMENCEMENT OF CONSTRUCTION WORKS.
- 4. MESH AND GRAVEL INLET FILTERS (SD 6-12) TO BE INSTALLED UPSTREAM OF PROPOSED STORMWATER PITS AS WELL AS EXISTING STORMWATER PITS DOWNSTREAM OF DISTURBED AREAS.
- 5. TOP SOIL WILL BE STRIPPED AND STOCKPILED (SD 4-1) FOR LATER USE IN LANDSCAPING.
- 6. ALL STOCKPILES TO BE CLEAR FROM DRAINS, GUTTERS AND FOOTPATHS.
- 7. TOP SOIL WILL BE RE SPREAD AND ALL DISTURBED AREAS WILL BE REHABILITATED WITHIN 20 WORKING DAYS OF THE COMPLETION OF WORKS.
- 8. ALL SEDIMENT TO BE STORED AND COLLECTED BY A LIQUID WASTE COMPANY FOR DISPOSAL AT A LICENSED TREATMENT FACILITY.
- 9. ROADS AND FOOTWAYS TO BE SWEPT AT THE END OF THE DAY.
- 10. ALL EROSION AND SEDIMENT CONTROLS WILL BE CHECKED AT LEAST WEEKLY AND AFTER RAINFALL EVENTS TO MAKE SURE THEY ARE MAINTAINED TO A FULLY FUNCTIONAL CONDITION.



- 1. Place stockpiles more than 2 (preferably 5) metres from existing vegetation, concentrated
- water flow, roads and hazard areas. 2. Construct on the contour as low, flat, elongated mounds.
- Where there is sufficient area, topsoil stockpiles shall be less than 2 metres in height. 4. Where they are to be in place for more than 10 days, stabilise following the approved
- ESCP or SWMP to reduce the C-factor to less than 0.10.
- 5. Construct earth banks (Standard Drawing 5-5) on the upslope side to divert water around
- stockpiles and sediment fences (Standard Drawing 6-8) 1 to 2 metres downslope.

STOCKPILES SD 4-1



Drive 1.5 metre long star pickets into ground at 2.5 metre intervals (max) at the downslope

Fix self-supporting geotextile to the upslope side of the posts ensuring it goes to the base of

the trench. Fix the geotextile with wire ties or as recommended by the manufacturer. Only

use geotextile specifically produced for sediment fencing. The use of shade cloth for this

SD 6-8


6. Backfill the trench over the base of the fabric and compact it thoroughly over the geotextile.

edge of the trench. Ensure any star pickets are fitted with safety caps.

Join sections of fabric at a support post with a 150-mm overlap.

purpose is not satisfactory.


SEDIMENT FENCE



- In waterways, artificial sag points can be created with sandbags or earth banks as shown
- in the drawing. Do not cover the inlet with geotextile unless the design is adequate to allow for all waters

SD 6-12

GEOTEXTILE INLET FILTER



- Cover the area with needle-punched geotextile.
- Construct a 200 mm thick pad over the geotextile using road base or 30 mm aggregate.
- Ensure the structure is at least 15 metres long or to building alignment and at least 3 metres
- Where a sediment fence joins onto the stabilised access, construct a hump in the stabilised access to divert water to the sediment fence.

STABILISED SITE ACCESS SD 6-14



partridge.com.au partridge@partridge.com.au Partridge Hydraulic Pty Ltd ABN 71 124 297 883

shown on this drawing are specific to this project only and may not be reproduced in whole or in part or be used for any other project or purpose without the written consent of Partridge Structural Pty Ltd.

RICHARD PARKES

STUDIO P ARCHITECTS LEVEL 1/31A PLAYFAIR ST THE ROCKS NSW TEL 0414 434 848


ALTERATIONS AND ADDITIONS 39 PINE STREET MANLY NSW 2095

STORMWATER SERVICES **EROSION AND SEDIMENT COTROL** PLAN & DETAILS

DO NOT SCALE: USE FIGURED DIMENSIONS

The presence of this signature signifies that this is the certified drawing issued for construction.	Designed J.P.	Drawn J.Z.
	Job No. 2023H0103	Scale at A1 1:100
Date NOV 2023	Drawing No. SWDA 1.3	Revision

NOT FOR CONSTRUCTION



JP ES 15.11.23

Copyright: The design and details shown on this drawing are specific to this project only and may not be reproduced in whole or in part or be used for any other project or purpose without the written consent of

J.Z.

2023H0103

SWDA 1.4


Drawing No.

Scale at A1

AS SHOWN

Partridge Structural Pty Ltd.





GROUND FLOOR LAYOUT

P1 PRELIMINARY
Rev. Issue / Amendment By App. Date

partridge.com.au partridge@partridge.com.au Partridge Hydraulic Pty Ltd ABN 71 124 297 883

au shown on this drawing are specific to this project only and may not be reproduced in whole or in part or be used for any other project or purpose without the written consent of Partridge Structural Pty Ltd.

RICHARD PARKES

STUDIO P ARCHITECTS
LEVEL 1/31A PLAYFAIR ST THE ROCKS NSW
TEL 0414 434 848

ALTERATIONS AND ADDITIONS
39 PINE STREET
MANLY NSW 2095

STORMWATER SERVICES
PROPOSED STORMWATER DRAINAGE LAYOUT
PLAN & DETAIL - GROUND FLOOR

DO NOT SCALE: USE FIGURED DIMENSIONS

The presence of this signature signifies that this is the certified drawing issued for construction.

Designed J.P. J.Z.

Job No. Scale at A1 2023H0103 1:100

Date Drawing No. Revision SWDA 1.5 1

NOT FOR CONSTRUCTION