

Natural Environment Referral Response - Riparian

Application Number:	DA2025/1139
Proposed Development:	Demolition works and construction of a dwelling house including swimming pool
Date:	11/09/2025
To:	Brittany Harrison
Land to be developed (Address):	Lot 1 DP 1176452 , 133 Riverview Road AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land, and located within 40 metres of land, containing a watercourse, or
- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposal is located within 40 metres of a mapped waterway, and is therefore subject to a Controlled Activity Approval under the Water Management Act 2000.

The proposed new stormwater pipe outlet is not exempt and must be referred to DPIE Water for assessment and approval.

The development application is an integrated development.

Supported in principle, subject to:

Receipt of formal comments and General Terms of Approval from the NSW Department of Planning and Environment – Water

Incorporation of GTA into the final development consent

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Erosion and Sediment Control Plan

An Erosion and Sediment Control Plan (ESCP) shall be prepared by an appropriately qualified person and implemented onsite prior to commencement. The ESCP must meet the requirements outlined in the Landcom publication Managing Urban Stormwater: Soils and Construction - Volume 1, 4th Edition (2004). The ESCP must include the following as a minimum:

- Site Boundaries and contours
- Approximate location of trees and other vegetation, showing items for removal or retention (consistent with any other plans attached to the application)
- Location of site access, proposed roads and other impervious areas (e.g. parking areas and site facilities)
- Existing and proposed drainage patterns with stormwater discharge points
- Locations and methods of all erosion and sediment controls that must include sediment fences, stabilised site access, materials and waste stockpiles locations, location of any stormwater pits on the site and how they are going to be protected.
- North point and scale.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval prior to the issue of the Construction Certificate.

Reason: To protect the receiving environment.

Stormwater Outlet Structure to Waterway

Stormwater outlet structures to the waterway must be designed in accordance with DPE Water's Guidelines for Outlet Structures on Waterfront land. Guidelines can be found on the DPE website.

No mortar is to be used on the outlet. Rocks must be placed using an interlocking system with varying rock sizes. The surface should be a textured finish to break up and dissipate sheet flows.

This design is to be submitted to the Principal Certifier prior to the release of the Construction Certificate.

Reason: To protect the surrounding creek bank from the effects of localised erosion.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: To protect the receiving environment.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Maintenance of Stormwater Treatment Measures

Stormwater treatment measures must be maintained at all times in accordance with manufacturer's specifications and as necessary to achieve the required stormwater quality targets for the development.

Northern Beaches Council reserves the right to enter the property and carry out appropriate maintenance of the device at the cost of the property owner.

Reason: To protect the receiving environment.